

SCHOOL NAME: School #18 750 West Avenue								75 Outlets	
Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L	
1	S23707.01	4/28/2021	Basement - Boiler Room	Faucet	Initial	<0.001	5/11/2021	N/A	
2	S23707.02	4/28/2021	Basement - Room B17 Faucet	Faucet	Initial	0.002	5/11/2021	N/A	
3	S23707.03	4/28/2021	Basement - Faculty Bathroom by B18	Faucet	Initial	<0.001	5/11/2021	N/A	
4	S23707.04	4/28/2021	Basement - Room B19 Faucet	Faucet	Initial	0.002	5/11/2021	N/A	
5	S23707.05	4/28/2021	Basement - Faculty Bathroom Faucet	Faucet	Initial	<0.001	5/11/2021	N/A	
6	S23707.06	4/28/2021	Basement - Room B13 Faucet	Faucet	Initial	0.002	5/11/2021	N/A	
7	S23707.07	4/28/2021	Basement - Room B01 Faucet	Faucet	Initial	<0.001	5/11/2021	N/A	
8	S23707.08	4/28/2021	Basement - Bathrm Faucet by B07 Eng. Office	Faucet	Initial	0.004	5/11/2021	N/A	
9	S23707.09	4/28/2021	1st Floor - Cafeteria Boys Bathrm Faucet	Faucet	Initial	<0.001	5/11/2021	N/A	
10	S23707.10	4/28/2021	1st Floor - Cafeteria Girls Bathrm Faucet	Faucet	Initial	<0.001	5/11/2021	N/A	
11	S23707.11	4/28/2021	1st Floor - Cafeteria Fountain 1	Fountain	Initial	0.020	5/11/2021	TURND OFF	
12	S23707.12	4/28/2021	1st Floor - Cafeteria Fountain 2	Fountain	Initial	0.001	5/11/2021	N/A	
13	S23707.13	4/28/2021	1st Floor - Kitchen Dish Sink 1	Faucet	Initial	<0.001	5/11/2021	N/A	
14	S23707.14	4/28/2021	1st Floor - Kitchen Dish Sink 2	Faucet	Initial	<0.001	5/11/2021	N/A	
15	S23707.15	4/28/2021	1st Floor - Kitchen Hand Sink by Main Door	Faucet	Initial	<0.001	5/11/2021	N/A	
16	S23707.16	4/28/2021	1st Floor - Kitchen Hand Sink by Warmer	Faucet	Initial	0.027	5/11/2021	SIGNAGE	
17	S23707.17	4/28/2021	1st Floor - Kitchen Serving Line	Faucet	Initial	0.002	5/11/2021	N/A	
18	S23707.18	4/28/2021	Basement - Room B02 Faucet	Faucet	Initial	0.002	5/11/2021	N/A	
19	S23707.19	4/28/2021	Room 100 Main Office Faucet	Faucet	Initial	<0.001	5/11/2021	N/A	
20	S23707.20	4/28/2021	Room 100A Main Office	Faucet	Initial	0.002	5/11/2021	N/A	
21	S23707.21	4/28/2021	Room 102 Faucet	Faucet	Initial	0.003	5/11/2021	N/A	
22	S23707.22	4/28/2021	Room 102 Nurse Bathroom Faucet	Faucet	Initial	<0.001	5/11/2021	N/A	
23	S23707.23	4/28/2021	Room 102 Faucet	Faucet	Initial	0.021	5/11/2021	SIGNAGE	
24	S23707.24	4/28/2021	First Floor near 103 Drinking Fountain	Fountain	Initial	<0.001	5/11/2021	N/A	

SCHOOL NAME: School #18 750 West Avenue**75 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
25	S23707.25	4/28/2021	First Floor near 103 Drinking Fountain	Fountain	Initial	<0.001	5/11/2021	N/A
26	S23707.26	4/28/2021	Room 103 Bottle Filler	Bottle Filler	Initial	<0.001	5/11/2021	N/A
27	S23707.27	4/28/2021	1st Floor Girls Bathrm Faucet	Faucet	Initial	<0.001	5/11/2021	N/A
28	S23707.28	4/28/2021	1st Floor Girls Bathrm Faucet	Faucet	Initial	<0.001	5/11/2021	N/A
29	S23707.29	4/28/2021	1st Floor Girls Bathrm Faucet	Faucet	Initial	0.002	5/11/2021	N/A
30	S23707.30	4/28/2021	Room 104 Faucet	Faucet	Initial	0.002	5/11/2021	N/A
31	S23707.31	4/28/2021	Room 106 Faucet	Faucet	Initial	0.001	5/11/2021	N/A
32	S23707.32	4/28/2021	Room 105 Faucet	Faucet	Initial	<0.001	5/11/2021	N/A
33	S23707.33	4/28/2021	Room 105 Fountain	Fountain	Initial	0.017	5/11/2021	TURNUED OFF
34	S23707.34	4/28/2021	Room 107 Fountain	Fountain	Initial	<0.001	5/11/2021	N/A
35	S23707.35	4/28/2021	Room 107 Faucet	Faucet	Initial	<0.001	5/11/2021	N/A
36	S23707.36	4/28/2021	Room 108 Faucet	Faucet	Initial	<0.001	5/11/2021	N/A
37	S23707.37	4/28/2021	1st Floor Fauculty Womens	Faucet	Initial	<0.001	5/11/2021	N/A
38	S23707.38	4/28/2021	1st Floor Mens Bathrm Faucet	Faucet	Initial	0.001	5/11/2021	N/A
39	S23707.39	4/28/2021	1st Floor Boys Bathrm Faucet	Faucet	Initial	0.001	5/11/2021	N/A
40	S23707.40	4/28/2021	1st Floor Boys Bathrm Faucet	Faucet	Initial	<0.001	5/11/2021	N/A
41	S23707.41	4/28/2021	Room 111 Faucet	Faucet	Initial	0.001	5/11/2021	N/A
42	S23707.42	4/28/2021	Room 112 Faucet	Faucet	Initial	<0.001	5/11/2021	N/A
43	S23707.43	4/28/2021	Fountain near 112	Fountain	Initial	<0.001	5/11/2021	N/A
44	S23707.44	4/28/2021	Room 113 Fountain	Fountain	Initial	0.003	5/11/2021	N/A
45	S23707.45	4/28/2021	Room 113 Faucet	Faucet	Initial	<0.001	5/11/2021	N/A
46	S23707.46	4/28/2021	Room 114 Fountain	Fountain	Initial	0.010	5/11/2021	N/A
47	S23707.47	4/28/2021	Room 114 Faucet	Faucet	Initial	<0.001	5/11/2021	N/A
48	S23707.48	4/28/2021	Room 115 Faucet	Faucet	Initial	0.007	5/11/2021	N/A

SCHOOL NAME: School #18 750 West Avenue								75 Outlets	
Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L	
49	S23707.49	4/28/2021	2nd Floor Fountain near 204	Fountain	Initial	<0.001	5/11/2021	N/A	
50	S23707.50	4/28/2021	2nd Floor Fountain near 204	Fountain	Initial	<0.001	5/11/2021	N/A	
51	S23707.51	4/28/2021	2nd Floor Girls Bathrm Faucet	Faucet	Initial	0.001	5/11/2021	N/A	
52	S23707.52	4/28/2021	2nd Floor Girls Bathrm Faucet	Faucet	Initial	0.001	5/11/2021	N/A	
53	S23707.53	4/28/2021	2nd Floor Girls Bathrm Faucet	Faucet	Initial	0.001	5/11/2021	N/A	
54	S23707.54	4/28/2021	2nd Floor Womens Bathrm Faucet	Faucet	Initial	<0.001	5/11/2021	N/A	
55	S23707.55	4/28/2021	2nd Floor Mens Bathrm Faucet	Faucet	Initial	<0.001	5/11/2021	N/A	
56	S23707.56	4/28/2021	2nd Floor Boys Bathroom	Faucet	Initial	<0.001	5/11/2021	N/A	
57	S23707.57	4/28/2021	2nd Floor Boys Bathroom	Faucet	Initial	<0.001	5/11/2021	N/A	
58	S23707.58	4/28/2021	2nd Floor Fountain near Rm 215	Fountain	Initial	<0.001	5/11/2021	N/A	
59	S23707.59	4/28/2021	3rd Floor Boys Bathroom Faucet Gym	Faucet	Initial	<0.001	5/11/2021	N/A	
60	S23707.60	4/28/2021	3rd Floor Girls Bathroom Faucet Gym	Faucet	Initial	0.010	5/11/2021	N/A	
61	S23707.61	4/28/2021	3rd Floor Fountain near Rm 303	Fountain	Initial	0.054	5/11/2021	TURND OFF	
62	S23707.62	4/28/2021	3rd Floor Fountain near Room 303	Fountain	Initial	0.011	5/11/2021	N/A	
63	S23707.63	4/28/2021	3rd Floor Girls Bathroom Faucet	Faucet	Initial	<0.001	5/11/2021	N/A	
64	S23707.64	4/28/2021	3rd Floor Girls Bathroom Faucet	Faucet	Initial	0.001	5/11/2021	N/A	
65	S23707.65	4/28/2021	3rd Floor Girls Bathroom Faucet	Faucet	Initial	0.004	5/11/2021	N/A	
66	S23707.66	4/28/2021	Room 307A Faucet	Faucet	Initial	0.005	5/11/2021	N/A	
67	S23707.67	4/28/2021	Room 308 Faucet	Faucet	Initial	0.003	5/11/2021	N/A	
68	S23707.68	4/28/2021	Room 308 Faucet	Faucet	Initial	0.002	5/11/2021	N/A	
69	S23707.69	4/28/2021	3rd Floor Womens Bathroom Faucet	Faucet	Initial	<0.001	5/11/2021	N/A	
70	S23707.70	4/28/2021	3rd Floor Mens Bathroom Faucet	Faucet	Initial	<0.001	5/11/2021	N/A	
71	S23707.71	4/28/2021	3rd Floor Boys Bathroom Faucet	Faucet	Initial	<0.001	5/11/2021	N/A	
72	S23707.72	4/28/2021	3rd Floor Boys Bathroom Faucet	Faucet	Initial	<0.001	5/11/2021	N/A	

SCHOOL NAME: School #18 750 West Avenue**75 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
73	S23707.73	4/28/2021	3rd Floor Fountain by 313	Fountain	Initial	0.013	5/11/2021	N/A
74	S23707.74	4/28/2021	3rd Floor Bottle Filler	Bottle Filler	Initial	0.001	5/11/2021	N/A
75	S23707.75	4/28/2021	Room 314 Faucet	Faucet	Initial	0.007	5/11/2021	N/A