

**SCHOOL NAME: School #19 97 W Delevan****33 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
1	21P006831	6/12/2021	Basement Water Fountain Hallway Near #016	Fountain	Initial	0.0024	7/12/2021	N/A
2	21P006832	6/12/2021	Kitchen Faucet #1 Rm #015	Faucet	Initial	<0.0010	7/12/2021	N/A
3	21p006833	6/12/2021	Kitchen Faucet #2 Rm #015	Faucet	Initial	0.0036	7/12/2021	N/A
4	21P006834	6/12/2021	Kitchen Faucet #3 Rm #015	Faucet	Initial	0.001	7/12/2021	N/A
5	21P006835	6/12/2021	Kitchen Faucet #4 Rm #015	Faucet	Initial	<0.0010	7/12/2021	N/A
6	21P006836	6/12/2021	Water Fountain Rm #011 Basement	Fountain	Initial	<0.0010	7/12/2021	N/A
7	21P006837	6/12/2021	Sink Rm #011 Basement	Faucet	Initial	<0.0010	7/12/2021	N/A
8	21P006838	6/12/2021	Water Fountain Basement Outside #011	Fountain	Initial	<0.0010	7/12/2021	N/A
9	21P006839	6/12/2021	Boys Bathroom Basement Sink	Faucet	Initial	<0.0010	7/12/2021	N/A
10	21P006840	6/12/2021	Girls Bathroom Sink #1	Faucet	Initial	<0.0010	7/12/2021	N/A
11	21P006841	6/12/2021	Girls Bathroom Sink #2 Basement	Faucet	Initial	0.0012	7/12/2021	N/A
12	21P006842	6/12/2021	Café Kitchen Faucet #1 Room #004	Faucet	Initial	0.0011	7/12/2021	N/A
13	21P006843	6/12/2021	Café Kitchen Faucet #2 Room #004	Faucet	Initial	<0.0010	7/12/2021	N/A
14	21P006844	6/12/2021	Café Kitchen Faucet #3 Rm #004	Faucet	Initial	<0.0010	7/12/2021	N/A
15	21P006845	6/12/2021	Café Kitchen Faucet #4 Room #004	Faucet	Initial	<0.0010	7/12/2021	N/A
16	21P006846	6/12/2021	Café Kitchen Faucet #5 Room #004	Faucet	Initial	<0.0010	7/12/2021	N/A
17	21P006847	6/12/2021	Water Fountain 1st FI Hallway Outside Rm #117	Fountain	Initial	0.0016	7/12/2021	N/A
18	21P006848	6/12/2021	Boys Bathroom Sink 1st Floor Hallway	Faucet	Initial	<0.0010	7/12/2021	N/A
19	21P006849	6/12/2021	Girls Bathroom Sink 1 Floor Hallway	Faucet	Initial	<0.0010	7/12/2021	N/A
20	21P006850	6/12/2021	Rm 103 Sink	Faucet	Initial	<0.0010	7/12/2021	N/A
21	21P006851	6/12/2021	Water Fountain Outside Rm 103	Fountain	Initial	<0.0010	7/12/2021	N/A
22	21P006852	6/12/2021	Sink Room #102	Faucet	Initial	0.001	7/12/2021	N/A
23	21P006853	6/12/2021	Rm 104 Sink	Faucet	Initial	<0.0010	7/12/2021	N/A
24	21P006854	6/12/2021	Water Fountain Outside Room 203	Fountain	Initial	0.0011	7/12/2021	N/A
25	21P006855	6/12/2021	Girls Bathroom Sink #1 2nd Floor	Faucet	Initial	<0.0010	7/12/2021	N/A
26	21P006856	6/12/2021	Girls Bathroom Sink #2	Faucet	Initial	<0.0010	7/12/2021	N/A

**SCHOOL NAME: School #19 97 W Delevan****33 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
27	21P006857	6/12/2021	Boys Bathroom Sink #1 2nd Floor	Faucet	Initial	0.0014	7/12/2021	N/A
28	21P006858	6/12/2021	Bathroom Sink (Boys) 2 Floor Hallway	Faucet	Initial	<0.0010	7/12/2021	N/A
29	21P006859	6/12/2021	Water Fountain Outside Rm 216	Fountain	Initial	0.0037	7/12/2021	N/A
30	21P006860	6/12/2021	Girls Bathroom Sink #1 3rd Floor	Faucet	Initial	0.0011	7/12/2021	N/A
31	21P006861	6/12/2021	Girls Bathroom Sink #2 3rd Floor	Faucet	Initial	0.0024	7/12/2021	N/A
32	21P006862	6/12/2021	Boys Bathroom Sink #1 3rd Floor	Faucet	Initial	0.0018	7/12/2021	N/A
33	21P006863	6/12/2021	Boys Bathroom Sink #2	Faucet	Initial	0.0024	7/12/2021	N/A