

**SCHOOL NAME:****School #27 Hillery Park Elementary 73 Pawnee Parkway****88 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
1	S24537.01	5/18/2021	Boiler Room	Faucet	Initial	0.004	7/7/2021	N/A
2	S24537.02	5/18/2021	Electrical Room	Faucet	Initial	0.002	7/7/2021	N/A
3	S24537.03	5/18/2021	Room 141 - Faucet	Faucet	Initial	0.001	7/7/2021	N/A
4	S24537.04	5/18/2021	Stage - Faucet	Faucet	Initial	0.013	7/7/2021	N/A
5	S24537.05	5/18/2021	Girls Bathroom near Room 146 - Faucet C1	Faucet	Initial	0.002	7/7/2021	N/A
6	S24537.06	5/18/2021	Girls Bathroom near Room 146 - Faucet C2	Faucet	Initial	0.002	7/7/2021	N/A
7	S24537.07	5/18/2021	Boys Bathroom near Room 146 - Faucet C1	Faucet	Initial	0.001	7/7/2021	N/A
8	S24537.08	5/18/2021	Boys Bathroom near Room 146 - Faucet C2	Faucet	Initial	<0.001	7/7/2021	N/A
9	S24537.09	5/18/2021	Room 145 - Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
10	S24537.10	5/18/2021	Room 147 - Faucet	Faucet	Initial	0.002	7/7/2021	N/A
11	S24537.11	5/18/2021	Room 149 - Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
12	S24537.12	5/18/2021	Clinic - Faucet 150A	Faucet	Initial	0.006	7/7/2021	N/A
13	S24537.13	5/18/2021	Clinic - Faucet 150B	Faucet	Initial	0.009	7/7/2021	N/A
14	S24537.14	5/18/2021	Clinic - Faucet	Faucet	Initial	0.002	7/7/2021	N/A
15	S24537.15	5/18/2021	Clinic - Faucet Restroom	Faucet	Initial	<0.001	7/7/2021	N/A
16	S24537.16	5/18/2021	Main Office - Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
17	S24537.17	5/18/2021	Principal's Office Bathroom - Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
18	S24537.18	5/18/2021	Room 104 - Faucet	Faucet	Initial	0.005	7/7/2021	N/A
19	S24537.19	5/18/2021	Room 105 - Faucet	Faucet	Initial	0.003	7/7/2021	N/A
20	S24537.20	5/18/2021	Room 107 - Faucet	Faucet	Initial	0.004	7/7/2021	N/A
21	S24537.21	5/18/2021	Room 109 - Faucet	Faucet	Initial	0.003	7/7/2021	N/A
22	S24537.22	5/18/2021	Room 112 - Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
23	S24537.23	5/18/2021	Boys Bathroom near Room 110 - Faucet D1	Faucet	Initial	0.004	7/7/2021	N/A
24	S24537.24	5/18/2021	Boys Bathroom near Room 110 - Faucet D2	Faucet	Initial	0.001	7/7/2021	N/A
25	S24537.25	5/18/2021	Boys Bathroom near Room 110 - Faucet D3	Faucet	Initial	0.001	7/7/2021	N/A
26	S24537.26	5/18/2021	Girls Bathroom near Room 110 - Faucet C1	Faucet	Initial	<0.001	7/7/2021	N/A

**SCHOOL NAME:****School #27 Hillery Park Elementary 73 Pawnee Parkway****88 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
27	S24537.27	5/18/2021	Girls Bathroom near Room 110 - Faucet C2	Faucet	Initial	<0.001	7/7/2021	N/A
28	S24537.28	5/18/2021	Girls Bathroom near Room 110 - Faucet C3	Faucet	Initial	<0.001	7/7/2021	N/A
29	S24537.29	5/18/2021	Room 110 - Faucet	Faucet	Initial	0.002	7/7/2021	N/A
30	S24537.30	5/18/2021	Room 117 - Faucet	Faucet	Initial	0.005	7/7/2021	N/A
31	S24537.31	5/18/2021	Room 118 - Faucet	Faucet	Initial	0.002	7/7/2021	N/A
32	S24537.32	5/18/2021	1st FL - Fountain near Elevator	Bottle Filler	Initial	<0.001	7/7/2021	N/A
33	S24537.33	5/18/2021	Room 119 - Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
34	S24537.34	5/18/2021	Room 120 - Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
35	S24537.35	5/18/2021	Room 122 - Faucet	Faucet	Initial	0.003	7/7/2021	N/A
36	S24537.36	5/18/2021	Kitchen Sink - Faucet A	Faucet	Initial	<0.001	7/7/2021	N/A
37	S24537.37	5/18/2021	Kitchen Sink - Faucet D1	Faucet	Initial	0.001	7/7/2021	N/A
38	S24537.38	5/18/2021	Kitchen Sink - Faucet D2	Faucet	Initial	0.010	7/7/2021	N/A
39	S24537.39	5/18/2021	Faculty Bathroom near Cafeteria	Faucet	Initial	<0.001	7/7/2021	N/A
40	S24537.40	5/18/2021	Cafeteria Boys Bathroom - Faucet	Faucet	Initial	0.002	7/7/2021	N/A
41	S24537.41	5/18/2021	Cafeteria Gils Bathroom - Faucet B1	Faucet	Initial	0.007	7/7/2021	N/A
42	S24537.42	5/18/2021	Cafeteria Girls Bathroom - Faucet B2	Faucet	Initial	<0.001	7/7/2021	N/A
43	S24537.43	5/18/2021	Cafeteria Girls Bathroom - Faucet B3	Faucet	Initial	<0.001	7/7/2021	N/A
44	S24537.44	5/18/2021	Room 124 Faculty - Faucet	Faucet	Initial	0.003	7/7/2021	N/A
45	S24537.45	5/18/2021	Room 127 - Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
46	S24537.46	5/18/2021	Room 128 - Faucet	Faucet	Initial	0.002	7/7/2021	N/A
47	S24537.47	5/18/2021	Room 129 - Faucet	Faucet	Initial	0.003	7/7/2021	N/A
48	S24537.48	5/18/2021	Room 130 - Faucet	Faucet	Initial	0.002	7/7/2021	N/A
49	S24537.49	5/18/2021	Room 131 - Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
50	S24537.50	5/18/2021	Room 133 - Faucet	Faucet	Initial	0.003	7/7/2021	N/A
51	S24537.51	5/18/2021	Faculty Bathroom near Gym	Faucet	Initial	<0.001	7/7/2021	N/A
52	S24537.52	5/18/2021	Gym Office	Faucet	Initial	0.003	7/7/2021	N/A

**SCHOOL NAME:****School #27 Hillery Park Elementary 73 Pawnee Parkway****88 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
53	S24537.53	5/18/2021	Room 227 - Faucet	Faucet	Initial	0.004	7/7/2021	N/A
54	S24537.54	5/18/2021	Room 226 - Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
55	S24537.55	5/18/2021	Boys Bathroom near Rm 225 - Faucet C1	Faucet	Initial	0.001	7/7/2021	N/A
56	S24537.56	5/18/2021	Boys Bathroom near Rm 225 - Faucet C2	Faucet	Initial	0.002	7/7/2021	N/A
57	S24537.57	5/18/2021	Boys Bathroom near Rm 225 - #1 Faucet C3	Faucet	Initial	0.006	7/7/2021	N/A
58	S24537.58	5/18/2021	2nd FL - Women's Faculty Room - Faucet D1	Faucet	Initial	0.002	7/7/2021	N/A
59	S24537.59	5/18/2021	2nd FL - Women's Faculty Room - Faucet D2	Faucet	Initial	0.001	7/7/2021	N/A
60	S24537.60	5/18/2021	2nd Fl - Men's Faculty Room - Faucet	Faucet	Initial	0.003	7/7/2021	N/A
61	S24537.61	5/18/2021	Room 224 - Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
62	S24537.62	5/18/2021	Girls Bathroom near Rm 225 #2 - Faucet B1	Faucet	Initial	0.001	7/7/2021	N/A
63	S24537.63	5/18/2021	Girls Bathroom near Rm 225 - Faucet B2	Faucet	Initial	0.002	7/7/2021	N/A
64	S24537.64	5/18/2021	Girls Bathroom near Rm 225 - Faucet B3	Faucet	Initial	0.003	7/7/2021	N/A
65	S24537.65	5/18/2021	Room 222 - Faucet	Faucet	Initial	0.005	7/7/2021	N/A
66	S24537.66	5/18/2021	Room 221 - Faucet	Faucet	Initial	0.003	7/7/2021	N/A
67	S24537.67	5/18/2021	Fountain near Room 220	Fountain	Initial	<0.001	7/7/2021	N/A
68	S24537.68	5/18/2021	Room 220 - Faucet	Faucet	Initial	0.006	7/7/2021	N/A
69	S24537.69	5/18/2021	Room 219 - Faucet	Faucet	Initial	0.003	7/7/2021	N/A
70	S24537.70	5/18/2021	2nd Fl - Room 200	Faucet	Initial	0.004	7/7/2021	N/A
71	S24537.71	5/18/2021	Room 204 - Faucet	Faucet	Initial	0.002	7/7/2021	N/A
72	S24537.72	5/18/2021	Room 203 - Faucet	Faucet	Initial	0.003	7/7/2021	N/A
73	S24537.73	5/18/2021	Room 205 - Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
74	S24537.74	5/18/2021	Room 206 - Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
75	S24537.75	5/18/2021	Room 207 - Faucet	Faucet	Initial	0.001	7/7/2021	N/A
76	S24537.76	5/18/2021	Room 209 - Faucet	Faucet	Initial	0.006	7/7/2021	N/A
77	S24537.77	5/18/2021	Room 211	Faucet	Initial	<0.001	7/7/2021	N/A
78	S24537.78	5/18/2021	Room 214 - Faucet	Faucet	Initial	<0.001	7/7/2021	N/A

**SCHOOL NAME:****School #27 Hillery Park Elementary 73 Pawnee Parkway****88 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
79	S24537.79	5/18/2021	Boys Bathroom near Rm 214 - Faucet D1	Faucet	Initial	0.002	7/7/2021	N/A
80	S24537.80	5/18/2021	Boys Bathroom near Rm 214 - Faucet D2	Faucet	Initial	<0.001	7/7/2021	N/A
81	S24537.81	5/18/2021	Boys Bathroom near Rm 214 - Faucet D3	Faucet	Initial	<0.001	7/7/2021	N/A
82	S24537.82	5/18/2021	Girls Bathroom near Rm 212 - Faucet C1	Faucet	Initial	0.025	7/7/2021	SIGNAGE
83	S24537.83	5/18/2021	Girls Bathroom near Rm 212 - Faucet C2	Faucet	Initial	<0.001	7/7/2021	N/A
84	S24537.84	5/18/2021	Girls Bathroom near Rm 212 - Faucet C3	Faucet	Initial	0.002	7/7/2021	N/A
85	S24537.85	5/18/2021	Room 215 - Faucet C1	Faucet	Initial	0.008	7/7/2021	N/A
86	S24537.86	5/18/2021	Room 215 - Faucet C2	Faucet	Initial	0.010	7/7/2021	N/A
87	S24537.87	5/18/2021	Room 215 - Faucet A1	Faucet	Initial	0.004	7/7/2021	N/A
88	S24537.88	5/18/2021	Room 215 - Faucet A2	Faucet	Initial	0.002	7/7/2021	N/A