

SCHOOL NAME: School #31 Harriet Ross Tubman 212 Stanton Street**50 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
1	S24534.01	5/11/2021	Room 318 - Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
2	S24534.02	5/11/2021	Room 318 - Faucet	Faucet	Initial	0.004	7/7/2021	N/A
3	S24534.03	5/11/2021	Room 115/114 - Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
4	S24534.04	5/11/2021	Room 115/114 - Fountain	Fountain	Initial	<0.001	7/7/2021	N/A
5	S24534.05	5/11/2021	Room 117/119 - Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
6	S24534.06	5/11/2021	Room 117/119 - Fountain	Fountain	Initial	<0.001	7/7/2021	N/A
7	S24534.07	5/11/2021	Room 122-120 - Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
8	S24534.08	5/11/2021	Room 122-/120 - Fountain	Fountain	Initial	<0.001	7/7/2021	N/A
9	S24534.09	5/11/2021	Room 123 - Faucet	Faucet	Initial	0.004	7/7/2021	N/A
10	S24534.10	5/11/2021	Room 123 Bathroom - Faucet	Faucet	Initial	0.002	7/7/2021	N/A
11	S24534.11	5/11/2021	Room 127 - Faucet A	Faucet	Initial	0.005	7/7/2021	N/A
12	S24534.12	5/11/2021	Room 127 - Faucet B	Faucet	Initial	0.005	7/7/2021	N/A
13	S24534.13	5/11/2021	Room 127 - Fountain next to Rm 127	Fountain	Initial	0.005	7/7/2021	N/A
14	S24534.14	5/11/2021	Kitchen - Center Wall Faucet	Faucet	Initial	0.049	7/7/2021	work order to replace
15	S24534.15	5/11/2021	Kitchen - Faucet	Faucet	Initial	0.013	7/7/2021	N/A
16	S24534.16	5/11/2021	Kitchen - Faucet	Faucet	Initial	0.003	7/7/2021	N/A
17	S24534.17	5/11/2021	Kitchen - Faucet	Faucet	Initial	0.007	7/7/2021	N/A
18	S24534.18	5/11/2021	Cafeteria Bathroom - Faucet	Faucet	Initial	0.004	7/7/2021	N/A
19	S24534.19	5/11/2021	Room 103 Bathroom - Faucet	Faucet	Initial	0.004	7/7/2021	N/A
20	S24534.20	5/11/2021	Room 102 - Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
21	S24534.21	5/11/2021	1st FL - Faculty Bathroom near Rm 104 - Faucet	Faucet	Initial	0.009	7/7/2021	N/A
22	S24534.22	5/11/2021	Room 104 - Faucet	Faucet	Initial	0.002	7/7/2021	N/A
23	S24534.23	5/11/2021	1st FL - Boys Bathroom/Storage - Faucet	Faucet	Initial	0.067	7/7/2021	SIGNAGE
24	S24534.24	5/11/2021	Room 106 - Faucet	Faucet	Initial	0.019	7/7/2021	SIGNAGE
25	S24534.25	5/11/2021	Room 107 - Faucet	Faucet	Initial	0.001	7/7/2021	N/A
26	S24534.26	5/11/2021	Room 108 - Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
27	S24534.27	5/11/2021	Room 218 - Faucet	Faucet	Initial	0.001	7/7/2021	N/A

SCHOOL NAME: School #31 Harriet Ross Tubman 212 Stanton Street**50 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
28	S24534.28	5/11/2021	Room 203 - Fountain next to Rm 203	Fountain	Initial	0.005	7/7/2021	N/A
29	S24534.29	5/11/2021	Room 201 - Faucet	Faucet	Initial	0.002	7/7/2021	N/A
30	S24534.30	5/11/2021	Room 204 - Faucet	Faucet	Initial	0.004	7/7/2021	N/A
31	S24534.31	5/11/2021	Room 205 - Faucet	Faucet	Initial	0.002	7/7/2021	N/A
32	S24534.32	5/11/2021	Room 206 - Faucet	Faucet	Initial	0.002	7/7/2021	N/A
33	S24534.33	5/11/2021	Room 207 - Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
34	S24534.34	5/11/2021	Room 209 - Faucet	Faucet	Initial	0.003	7/7/2021	N/A
35	S24534.35	5/11/2021	Room 210 - Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
36	S24534.36	5/11/2021	Room 211 - Faucet	Faucet	Initial	0.002	7/7/2021	N/A
37	S24534.37	5/11/2021	Room 211 - Faucet	Faucet	Initial	0.003	7/7/2021	N/A
38	S24534.38	5/11/2021	Room 212 - Faucet	Faucet	Initial	0.001	7/7/2021	N/A
39	S24534.39	5/11/2021	Room 213 - Faucet	Faucet	Initial	0.005	7/7/2021	N/A
40	S24534.40	5/11/2021	Room 214 - Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
41	S24534.41	5/11/2021	Room 215 - Faucet	Faucet	Initial	0.001	7/7/2021	N/A
42	S24534.42	5/11/2021	Room 216 - Faucet	Faucet	Initial	0.001	7/7/2021	N/A
43	S24534.43	5/11/2021	Room 217 - Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
44	S24534.44	5/11/2021	Room 318 - Faucet A	Faucet	Initial	0.004	7/7/2021	N/A
45	S24534.45	5/11/2021	Room 318 - Faucet A	Faucet	Initial	0.007	7/7/2021	N/A
46	S24534.46	5/11/2021	Room 318 - Faucet B	Faucet	Initial	0.008	7/7/2021	N/A
47	S24534.47	5/11/2021	Room 318 - Faucet B	Faucet	Initial	0.002	7/7/2021	N/A
48	S24534.48	5/11/2021	Room 303 Bathroom - Faucet	Faucet	Initial	0.009	7/7/2021	N/A
49	S24534.49	5/11/2021	Room 302 - Fountain next to Rm 302	Fountain	Initial	0.003	7/7/2021	N/A
50	S24534.50	5/11/2021	Room 318 - Faucet	Faucet	Initial	<0.001	7/7/2021	N/A