

| SCHOOL NAME: | | School #355 75 West Huron Street | | | | | 96 Outlets | | |
|--------------|-----------|----------------------------------|---|--------------------|--------------------------|------------------|-------------------------|--|--|
| Sample ID | Lab ID # | Sample Collection Date | Sample Location | Outlet Description | Initial/Post Remediation | Lead Result mg/L | Lab Report Receipt Date | Action Taken for Outlets Greater than 0.015 mg/L | |
| 1 | 21P004462 | 4/30/2021 | B-18 Utility Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 2 | 21P004463 | 4/30/2021 | Basement Boys Bath Sink Right | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 3 | 21P004464 | 4/30/2021 | Basement Boys Bath Left Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 4 | 21P004471 | 4/30/2021 | Basement Girls Bath Right Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 5 | 21P004465 | 4/30/2021 | Girls Bath Basement Left Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 6 | 21P004466 | 4/30/2021 | Basement Drinking Fountain Left | Fountain | Initial | <0.0010 | 5/20/2021 | N/A | |
| 7 | 21P004467 | 4/30/2021 | Basement Drinking Fountain Right | Fountain | Initial | <0.0010 | 5/20/2021 | N/A | |
| 8 | 21P004468 | 4/30/2021 | Basement Bottle Filler | Bottle Filler | Initial | <0.0010 | 5/20/2021 | N/A | |
| 9 | 21P004469 | 4/30/2021 | B-15 Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 10 | 21P004470 | 5/1/2021 | Restaurant Sink Front Wall | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 11 | 21P004472 | 5/1/2021 | Restaurant Sink Side | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 12 | 21P004473 | 5/1/2021 | Restaurant Boys Bath Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 13 | 21P004474 | 5/1/2021 | Restaurant Girls Bath Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 14 | 21P004475 | 5/1/2021 | Restaurant Fountain Left | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 15 | 21P004476 | 5/1/2021 | Restaurant Fountain Right | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 16 | 21P004477 | 5/1/2021 | Restaurant Bottle Filler | Bottle Filler | Initial | <0.0010 | 5/20/2021 | N/A | |
| 17 | 21P004478 | 5/1/2021 | Ice Maker 1st Floor | Ice Maker | Initial | <0.0010 | 5/20/2021 | N/A | |
| 18 | 21P004479 | 5/1/2021 | Sink Next to Steam Table in Kitchen | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 19 | 21P004480 | 5/1/2021 | Rm 103 1st Floor Kitchen 3 Bay Sink Left | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 20 | 21P004481 | 5/1/2021 | Rm 103 1st Floor 3 Bay Sink Right Faucet | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 21 | 21P004482 | 5/1/2021 | 1st Floor Faucet Rm 103 Mop Filling Station | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 22 | 21P004483 | 5/1/2021 | 1st Floor Rm 103 Kettle Filler | Kettle | Initial | <0.0010 | 5/20/2021 | N/A | |
| 23 | 21P004484 | 5/1/2021 | Rm 103 Tilt Skillet | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 24 | 21P004485 | 5/1/2021 | Rm 105 3 Bay Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |

| SCHOOL NAME: School #355 75 West Huron Street | | | | | | | | 96 Outlets | |
|---|-----------|------------------------|---------------------------------|--------------------|--------------------------|------------------|-------------------------|--|--|
| Sample ID | Lab ID # | Sample Collection Date | Sample Location | Outlet Description | Initial/Post Remediation | Lead Result mg/L | Lab Report Receipt Date | Action Taken for Outlets Greater than 0.015 mg/L | |
| 25 | 21P004486 | 5/1/2021 | Rm 105 Dishwasher Faucet | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 26 | 21P004487 | 5/1/2021 | 107 Pot Filler | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 27 | 21P004488 | 5/1/2021 | 107 3 Bay Sink Right Faucet | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 28 | 21P004489 | 5/1/2021 | 107 3 Bay Sink Left | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 29 | 21P004490 | 5/1/2021 | 107 Dishwasher Faucet | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 30 | 21P004491 | 5/1/2021 | 1st Floor Girls Rm Left Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 31 | 21P004492 | 5/1/2021 | 1st Floor Girls Rm Right Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 32 | 21P004493 | 5/1/2021 | 1st Floor Boys Room Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 33 | 21P004494 | 5/1/2021 | 1st Floor Fountain Left | Fountain | Initial | <0.0010 | 5/20/2021 | N/A | |
| 34 | 21P004495 | 5/1/2021 | 1st Floor Fountain Right | Fountain | Initial | <0.0010 | 5/20/2021 | N/A | |
| 35 | 21P004496 | 5/1/2021 | Bottle Filler 1st Floor | Bottle Filler | Initial | <0.0010 | 5/20/2021 | N/A | |
| 36 | 21P004497 | 5/1/2021 | 1st Floor Boys Room Right Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 37 | 21P004558 | 5/1/2021 | Gym Office Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 38 | 21P004559 | 5/1/2021 | 2nd Floor Womens Room Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 39 | 21P004560 | 5/1/2021 | 2nd Floor Mens Room Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 40 | 21P004561 | 5/1/2021 | Gym Fountain Right | Fountain | Initial | <0.0010 | 5/20/2021 | N/A | |
| 41 | 21P004562 | 5/1/2021 | Gym Fountain Left | Fountain | Initial | <0.0010 | 5/20/2021 | N/A | |
| 42 | 21P004563 | 5/1/2021 | Gym Bottle Filler | Bottle Filler | Initial | <0.0010 | 5/20/2021 | N/A | |
| 43 | 21P004564 | 5/1/2021 | 2nd Floor Boys Locker Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 44 | 21P004565 | 5/1/2021 | 2nd Floor Locker Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 45 | 21P004566 | 5/1/2021 | 2nd Floor Girls Bath Sink Right | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 46 | 21P004567 | 5/1/2021 | 2nd Floor Girls Bath Sink Left | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 47 | 21P004568 | 5/1/2021 | 2nd Floor Boys Bath Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 48 | 21P004569 | 5/1/2021 | Cafeteria Fountain Right | Fountain | Initial | <0.0010 | 5/20/2021 | N/A | |

| SCHOOL NAME: | | School #355 75 West Huron Street | | | | | 96 Outlets | | |
|--------------|-----------|----------------------------------|-----------------------------|--------------------|--------------------------|------------------|-------------------------|--|--|
| Sample ID | Lab ID # | Sample Collection Date | Sample Location | Outlet Description | Initial/Post Remediation | Lead Result mg/L | Lab Report Receipt Date | Action Taken for Outlets Greater than 0.015 mg/L | |
| 49 | 21P004570 | 5/1/2021 | Caf Fountain Left | Fountain | Initial | <0.0010 | 5/20/2021 | N/A | |
| 50 | 21P004571 | 5/1/2021 | Caf Bottle Filler | Bottle Filler | Initial | <0.0010 | 5/20/2021 | N/A | |
| 51 | 21P004572 | 5/1/2021 | 213 Tilt Skillet | Faucet | Initial | 0.0043 | 5/20/2021 | N/A | |
| 52 | 21P004573 | 5/1/2021 | 213 Cauldron Filler | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 53 | 21P004574 | 5/1/2021 | 213 3 Bay Sink Window | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 54 | 21P004575 | 5/1/2021 | 213 3 Bay Sink Wall | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 55 | 21P004576 | 5/1/2021 | Mop Station 213 | Faucet | Initial | 0.0045 | 5/20/2021 | N/A | |
| 57 | 21P004577 | 5/1/2021 | 207 2 Bay Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 58 | 21P004578 | 5/1/2021 | 3 Boys Bath Sink Right | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 59 | 21P004579 | 5/1/2021 | 3 Boys Bath Sink Left | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 60 | 21P004580 | 5/1/2021 | 3 Girls Bathroom Sink Left | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 61 | 21P004581 | 5/1/2021 | 3 Girls Bathroom Sink Right | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 62 | 21P004582 | 5/1/2021 | 3 Fountain Right | Fountain | Initial | <0.0010 | 5/20/2021 | N/A | |
| 63 | 21P004583 | 5/1/2021 | 3 Fountain Left | Fountain | Initial | <0.0010 | 5/20/2021 | N/A | |
| 64 | 21P004584 | 5/1/2021 | 3 Bottle Filler | Bottle Filler | Initial | <0.0010 | 5/20/2021 | N/A | |
| 65 | 21P004585 | 5/1/2021 | 3 303 Mens Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 66 | 21P004586 | 5/1/2021 | 3 303 Womens Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 67 | 21P004587 | 5/1/2021 | 3 Staff Room Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 68 | 21P004588 | 5/1/2021 | 3 303 A Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 69 | 21P004589 | 5/1/2021 | 3 301 H Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 70 | 21P004590 | 5/1/2021 | 3 301 Sink Bathroom | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 71 | 21P004591 | 5/1/2021 | 3 301 B Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 72 | 21P004592 | 5/1/2021 | 4 Boys Bath Sink Right | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |
| 73 | 21P004593 | 5/1/2021 | 4 Boys Bath Sink Left | Faucet | Initial | <0.0010 | 5/20/2021 | N/A | |

| SCHOOL NAME: School #355 75 West Huron Street | | | | | | | | 96 Outlets |
|---|-----------|------------------------|-------------------------|--------------------|--------------------------|------------------|-------------------------|--|
| Sample ID | Lab ID # | Sample Collection Date | Sample Location | Outlet Description | Initial/Post Remediation | Lead Result mg/L | Lab Report Receipt Date | Action Taken for Outlets Greater than 0.015 mg/L |
| 74 | 21P004594 | 5/1/2021 | 4 Girls Bath Sink Left | Faucet | Initial | <0.0010 | 5/20/2021 | N/A |
| 75 | 21P004595 | 5/1/2021 | 4 Girls Bath Sink Right | Faucet | Initial | <0.0010 | 5/20/2021 | N/A |
| 76 | 21P004596 | 5/1/2021 | 4 Fountain Right | Fountain | Initial | <0.0010 | 5/20/2021 | N/A |
| 77 | 21P004597 | 5/1/2021 | 4 Fountain Left | Fountain | Initial | <0.0010 | 5/20/2021 | N/A |
| 78 | 21P004598 | 5/1/2021 | 4 Bottle Filler | Bottle Filler | Initial | <0.0010 | 5/20/2021 | N/A |
| 79 | 21P004599 | 5/1/2021 | 5 Nurse Bath Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A |
| 80 | 21P004600 | 5/1/2021 | 5 Nurse Office Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A |
| 81 | 21P004601 | 5/1/2021 | 5 Left Staff Bath Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A |
| 82 | 21P004602 | 5/1/2021 | 5 Right Staff Bath Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A |
| 83 | 21P004603 | 5/1/2021 | 5 Boys Bath Sink Right | Faucet | Initial | <0.0010 | 5/20/2021 | N/A |
| 84 | 21P004604 | 5/1/2021 | 5 Boys Bath Sink Left | Faucet | Initial | <0.0010 | 5/20/2021 | N/A |
| 85 | 21P004605 | 5/1/2021 | 5 Girls Sink Left | Faucet | Initial | <0.0010 | 5/20/2021 | N/A |
| 86 | 21P004606 | 5/1/2021 | 5 Girls Sink Right | Faucet | Initial | <0.0010 | 5/20/2021 | N/A |
| 87 | 21P004607 | 5/1/2021 | 5 Fountain Right | Fountain | Initial | <0.0010 | 5/20/2021 | N/A |
| 88 | 21P004617 | 5/1/2021 | 5 Fountain Left | Fountain | Initial | <0.0010 | 5/20/2021 | N/A |
| 89 | 21P004608 | 5/1/2021 | 5 Bottle Filler | Bottle Filler | Initial | <0.0010 | 5/20/2021 | N/A |
| 90 | 21P004609 | 5/1/2021 | 6 Sink Boys | Faucet | Initial | <0.0010 | 5/20/2021 | N/A |
| 91 | 21P004610 | 5/1/2021 | 6 Girls Bath Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A |
| 92 | 21P004611 | 5/1/2021 | 6 Right Staff Bath Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A |
| 93 | 21P004612 | 5/1/2021 | 6 Left Staff Bath Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A |
| 94 | 21P004613 | 5/1/2021 | 6 Right Fountain | Fountain | Initial | <0.0010 | 5/20/2021 | N/A |
| 95 | 21P004614 | 5/1/2021 | 6 Left Fountain | Fountain | Initial | <0.0010 | 5/20/2021 | N/A |
| 96 | 21P004615 | 5/1/2021 | 6 Bottle Filler | Bottle Filler | Initial | <0.0010 | 5/20/2021 | N/A |
| 97 | 21P004616 | 5/1/2021 | 6 Library Sink | Faucet | Initial | <0.0010 | 5/20/2021 | N/A |