

SCHOOL NAME: School #50 North Park Community School at Bldg 66 780 Parkside Ave**39 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
1	S24742.01	5/25/2021	Boiler Room - Bathroom	Faucet	Initial	0.008	7/20/2021	N/A
2	S24742.02	5/25/2021	Boiler Room - Faucet	Faucet	Initial	0.001	7/20/2021	N/A
3	S24742.03	5/25/2021	Girls Locker Rm - Fountain	Fountain	Initial	<0.001	7/20/2021	N/A
4	S24742.04	5/25/2021	Boys Locker Rm - Fountain	Fountain	Initial	<0.001	7/20/2021	N/A
5	S24742.05	5/25/2021	1st Fl Boys Bathroom - Faucet	Faucet	Initial	0.002	7/20/2021	N/A
6	S24742.06	5/25/2021	1st Fl Boys Bathroom - Faucet	Faucet	Initial	0.001	7/20/2021	N/A
7	S24742.07	5/25/2021	1st Fl Girls Bathroom C Side - Faucet	Faucet	Initial	<0.001	7/20/2021	N/A
8	S24742.08	5/25/2021	1st Fl Girls Bathroom C Side - Faucet	Faucet	Initial	0.001	7/20/2021	N/A
9	S24742.09	5/25/2021	1st Fl Hallway C - Fountain	Fountain	Initial	<0.001	7/20/2021	N/A
10	S24742.10	5/25/2021	Rm 108 Principals Bathroom - Faucet	Faucet	Initial	0.001	7/20/2021	N/A
11	S24742.11	5/25/2021	Rm 106 Ladies Rm - Faucet	Faucet	Initial	0.002	7/20/2021	N/A
12	S24742.12	5/25/2021	Rm 106 Men's Rm - Faucet	Faucet	Initial	0.009	7/20/2021	N/A
13	S24742.13	5/25/2021	Rm 106 Faculty Lounge - Faucet	Faucet	Initial	<0.001	7/20/2021	N/A
14	S24742.14	5/25/2021	2nd FL Boys Bathroom Faucet next to 209	Faucet	Initial	0.002	7/20/2021	N/A
15	S24742.15	5/25/2021	2nd FL Boys Bathroom Faucet next to 209	Faucet	Initial	<0.001	7/20/2021	N/A
16	S24742.16	5/25/2021	2nd Fl Girls Bathroom - Faucet	Faucet	Initial	0.001	7/20/2021	N/A
17	S24742.17	5/25/2021	2nd FL Girls Bathroom - Faucet	Faucet	Initial	0.001	7/20/2021	N/A
18	S24742.18	5/25/2021	Rm 209 Home & Careers - Faucet	Faucet	Initial	0.015	7/20/2021	N/A
19	S24742.19	5/25/2021	Rm 209 Home & Careers - Faucet	Faucet	Initial	0.013	7/20/2021	N/A
20	S24742.20	5/25/2021	2nd FL Boys Bathroom C Side - Faucet	Faucet	Initial	0.003	7/20/2021	N/A
21	S24742.21	5/25/2021	2nd FL Boys Bathroom C Side - Faucet	Faucet	Initial	0.002	7/20/2021	N/A
22	S24742.22	5/25/2021	2nd FL Girls Bathroom C Side - Faucet	Faucet	Initial	0.002	7/20/2021	N/A
23	S24742.23	5/25/2021	2nd FL Girls Bathroom C Side - Faucet	Faucet	Initial	0.010	7/20/2021	N/A

SCHOOL NAME: School #50 North Park Community School at Bldg 66 780 Parkside Ave**39 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
24	S24742.24	5/25/2021	2nd FL Hallway C Side - Fountain	Fountain	Initial	<0.001	7/20/2021	N/A
25	S24742.25	5/25/2021	3rd FL Boys Bathroom B Side - Faucet	Faucet	Initial	0.004	7/20/2021	N/A
26	S24742.26	5/25/2021	3rd FL Boys Bathroom B Side - Faucet	Faucet	Initial	<0.001	7/20/2021	N/A
27	S24742.27	5/25/2021	3rd FL Girls Bathroom B Side - Faucet	Faucet	Initial	<0.001	7/20/2021	N/A
28	S24742.28	5/25/2021	3rd FL Girls Bathroom B Side - Faucet	Faucet	Initial	0.002	7/20/2021	N/A
29	S24742.29	5/25/2021	3rd FL Hallway - Fountain	Fountain	Initial	<0.001	7/20/2021	N/A
30	S24742.30	5/25/2021	Rm 308 Faculty Men's - Faucet	Faucet	Initial	0.003	7/20/2021	N/A
31	S24742.31	5/25/2021	Rm 308 Faculty Ladies - Faucet	Faucet	Initial	0.007	7/20/2021	N/A
32	S24742.32	5/25/2021	3rd Fl Boys Bathroom C Side - Faucet	Faucet	Initial	<0.001	7/20/2021	N/A
33	S24742.33	5/25/2021	3rd Fl Boys Bathroom C Side - Faucet	Faucet	Initial	0.001	7/20/2021	N/A
34	S24742.34	5/25/2021	3rd FL Girls Bathroom C Side - Faucet	Faucet	Initial	0.001	7/20/2021	N/A
35	S24742.35	5/25/2021	3rd FL Girls Bathroom C Side - Faucet	Faucet	Initial	0.001	7/20/2021	N/A
36	S24742.36	5/25/2021	3rd Fl Hallway C Side - Fountain	Fountain	Initial	<.001	7/20/2021	N/A
37	S24742.37	5/25/2021	4th FL Kitchen Dish - Faucet	Faucet	Initial	0.005	7/20/2021	N/A
38	S24742.38	5/25/2021	4th Fl Kitchen Dish - Faucet	Faucet	Initial	0.010	7/20/2021	N/A
39	S24742.39	5/25/2021	4TH Fl Kitchen Prep Sink - Faucet	Faucet	Initial	0.003	7/20/2021	N/A