

SCHOOL NAME: School #59A at Building 90 50 A Street**83 Outlets**

| Sample ID | Lab ID # | Sample Collection Date | Sample Location | Outlet Description | Initial/Post Remediation | Lead Result mg/L | Lab Report Receipt Date | Action Taken for Outlets Greater than 0.015 mg/L |
|-----------|-----------|------------------------|--|--------------------|--------------------------|------------------|-------------------------|--|
| 1 | S24985.01 | 6/3/2021 | Rm 120 - Faucet | Faucet | Initial | 0.002 | 7/22/2021 | N/A |
| 2 | S24985.02 | 6/3/2021 | Rm 120 - Fountain | Fountain | Initial | <0.001 | 7/22/2021 | N/A |
| 3 | S24985.03 | 6/3/2021 | Rm 121 - Faucet | Faucet | Initial | 0.002 | 7/22/2021 | N/A |
| 4 | S24985.04 | 6/3/2021 | Rm 121 - Fountain | Fountain | Initial | <0.001 | 7/22/2021 | N/A |
| 5 | S24985.05 | 6/3/2021 | Rm 122 - Faucet | Faucet | Initial | 0.001 | 7/22/2021 | N/A |
| 6 | S24985.06 | 6/3/2021 | Rm 122 - Fountain | Fountain | Initial | <0.001 | 7/22/2021 | N/A |
| 7 | S24985.07 | 6/3/2021 | Rm 123 - Faucet | Faucet | Initial | 0.002 | 7/22/2021 | N/A |
| 8 | S24985.08 | 6/3/2021 | Rm 124 - Faucet | Faucet | Initial | 0.002 | 7/22/2021 | N/A |
| 9 | S24985.09 | 6/3/2021 | Rm 124 - Fountain | Fountain | Initial | 0.001 | 7/22/2021 | N/A |
| 10 | S24985.10 | 6/3/2021 | Rm 125 - Faucet | Faucet | Initial | 0.001 | 7/22/2021 | N/A |
| 11 | S24985.11 | 6/3/2021 | Rm 125 - Fountain | Fountain | Initial | <0.001 | 7/22/2021 | N/A |
| 12 | S24985.12 | 6/3/2021 | Rm 126 - Faucet | Faucet | Initial | 0.002 | 7/22/2021 | N/A |
| 13 | S24985.13 | 6/3/2021 | Rm 126 - Fountain | Fountain | Initial | <0.001 | 7/22/2021 | N/A |
| 14 | S24985.14 | 6/3/2021 | Rm 127 - Faucet | Faucet | Initial | 0.001 | 7/22/2021 | N/A |
| 15 | S24985.15 | 6/3/2021 | Rm 127 - Fountain | Fountain | Initial | <0.001 | 7/22/2021 | N/A |
| 16 | S24985.16 | 6/3/2021 | Rm 129 - Faucet | Faucet | Initial | 0.002 | 7/22/2021 | N/A |
| 17 | S24985.17 | 6/3/2021 | Rm 129 - Fountain | Fountain | Initial | <0.001 | 7/22/2021 | N/A |
| 18 | S24985.18 | 6/3/2021 | Rm 131 - Faucet | Faucet | Initial | 0.002 | 7/22/2021 | N/A |
| 19 | S24985.19 | 6/3/2021 | Rm 131 - Fountain | Fountain | Initial | <0.001 | 7/22/2021 | N/A |
| 20 | S24985.20 | 6/3/2021 | Rm 132 - Faucet | Faucet | Initial | 0.001 | 7/22/2021 | N/A |
| 21 | S24985.21 | 6/3/2021 | Rm 132 - Fountain | Fountain | Initial | <0.001 | 7/22/2021 | N/A |
| 22 | S24985.22 | 6/3/2021 | 1st Fl - Girls Bath near Rm 135 - Faucet | Faucet | Initial | 0.021 | 7/22/2021 | SIGNAGE |
| 23 | S24985.23 | 6/3/2021 | 1st Fl - Girls Bath near Rm 135 - Faucet | Faucet | Initial | 0.025 | 7/22/2021 | SIGNAGE |
| 24 | S24985.24 | 6/3/2021 | 1st Fl - Girls Bath near Rm 135 - Faucet | Faucet | Initial | 0.157 | 7/22/2021 | SIGNAGE |
| 25 | S24985.25 | 6/3/2021 | 1st FL - Boys Bath near Rm 135 - Faucet | Faucet | Initial | 0.040 | 7/22/2021 | SIGNAGE |

SCHOOL NAME: School #59A at Building 90 50 A Street**83 Outlets**

| Sample ID | Lab ID # | Sample Collection Date | Sample Location | Outlet Description | Initial/Post Remediation | Lead Result mg/L | Lab Report Receipt Date | Action Taken for Outlets Greater than 0.015 mg/L |
|-----------|-----------|------------------------|---|--------------------|--------------------------|------------------|-------------------------|--|
| 26 | S24985.26 | 6/3/2021 | 1st FL - Boys Bath near Rm 135 - Faucet | Faucet | Initial | 0.022 | 7/22/2021 | SIGNAGE |
| 27 | S24985.27 | 6/3/2021 | 1st FL - Boys Bath near Rm 135 - Faucet | Faucet | Initial | 0.030 | 7/22/2021 | SIGNAGE |
| 28 | S24985.28 | 6/3/2021 | Rm 137 - Faucet | Faucet | Initial | 0.016 | 7/22/2021 | SIGNAGE |
| 29 | S24985.29 | 6/3/2021 | Rm 137 - Fountain | Fountain | Initial | 0.004 | 7/22/2021 | N/A |
| 30 | S24985.30 | 6/3/2021 | Rm 139 - Faucet | Faucet | Initial | 0.004 | 7/22/2021 | N/A |
| 31 | S24985.31 | 6/3/2021 | Rm 139 - Fountain | Fountain | Initial | 0.004 | 7/22/2021 | N/A |
| 32 | S24985.32 | 6/3/2021 | Rm 142 - Faucet | Faucet | Initial | 0.007 | 7/22/2021 | N/A |
| 33 | S24985.33 | 6/3/2021 | Rm 142 - Fountain | Fountain | Initial | 0.008 | 7/22/2021 | N/A |
| 34 | S24985.34 | 6/3/2021 | Rm 142 Bath - Faucet | Faucet | Initial | 0.014 | 7/22/2021 | N/A |
| 35 | S24985.35 | 6/3/2021 | Rm 143 - Faucet | Faucet | Initial | 0.001 | 7/22/2021 | N/A |
| 36 | S24985.36 | 6/3/2021 | Rm 143 - Fountain | Fountain | Initial | <0.001 | 7/22/2021 | N/A |
| 37 | S24985.37 | 6/3/2021 | Rm 143 Bath - Faucet | Faucet | Initial | 0.005 | 7/22/2021 | N/A |
| 38 | S24985.38 | 6/3/2021 | Rm 148 - Faucet | Faucet | Initial | 0.004 | 7/22/2021 | N/A |
| 39 | S24985.39 | 6/3/2021 | Rm 144 - Faucet | Faucet | Initial | 0.001 | 7/22/2021 | N/A |
| 40 | S24985.40 | 6/3/2021 | Rm 144 Bath - Faucet | Faucet | Initial | 0.004 | 7/22/2021 | N/A |
| 41 | S24985.41 | 6/3/2021 | Rm 145 Faculty Faucet | Faucet | Initial | <0.001 | 7/22/2021 | N/A |
| 42 | S24985.42 | 6/3/2021 | Rm 145 Faculty Fountain | Fountain | Initial | <0.001 | 7/22/2021 | N/A |
| 43 | S24985.43 | 6/3/2021 | Rm 145 Faculty Bath - Faucet | Faucet | Initial | 0.007 | 7/22/2021 | N/A |
| 44 | S24985.44 | 6/3/2021 | Rm 146 - Faucet | Faucet | Initial | 0.002 | 7/22/2021 | N/A |
| 45 | S24985.45 | 6/3/2021 | Rm 146 - Fountain | Fountain | Initial | <0.001 | 7/22/2021 | N/A |
| 46 | S24985.46 | 6/3/2021 | Rm 146 Bath - Faucet | Faucet | Initial | 0.006 | 7/22/2021 | N/A |
| 47 | S24985.47 | 6/3/2021 | Rm 149 - Faucet | Faucet | Initial | 0.002 | 7/22/2021 | N/A |
| 48 | S24985.48 | 6/3/2021 | Rm 149 - Fountain | Fountain | Initial | <0.001 | 7/22/2021 | N/A |
| 49 | S24985.49 | 6/3/2021 | Rm 149 Bath - Faucet | Faucet | Initial | 0.004 | 7/22/2021 | N/A |
| 50 | S24985.50 | 6/3/2021 | Rm 150 - Faucet | Faucet | Initial | 0.006 | 7/22/2021 | N/A |

SCHOOL NAME: School #59A at Building 90 50 A Street**83 Outlets**

| Sample ID | Lab ID # | Sample Collection Date | Sample Location | Outlet Description | Initial/Post Remediation | Lead Result mg/L | Lab Report Receipt Date | Action Taken for Outlets Greater than 0.015 mg/L |
|-----------|-----------|------------------------|--|--------------------|--------------------------|------------------|-------------------------|--|
| 51 | S24985.51 | 6/3/2021 | Rm 150 Bath - Faucet | Faucet | Initial | 0.004 | 7/22/2021 | N/A |
| 52 | S24985.52 | 6/3/2021 | Rm 151 - Faucet | Faucet | Initial | 0.002 | 7/22/2021 | N/A |
| 53 | S24985.53 | 6/3/2021 | Rm 151 - Fountain | Fountain | Initial | <0.001 | 7/22/2021 | N/A |
| 54 | S24985.54 | 6/3/2021 | Rm 151 Bath - Faucet | Faucet | Initial | 0.004 | 7/22/2021 | N/A |
| 55 | S24985.55 | 6/3/2021 | Rm 152 - Faucet | Faucet | Initial | 0.002 | 7/22/2021 | N/A |
| 56 | S24985.56 | 6/3/2021 | Rm 154 - Faucet | Faucet | Initial | 0.002 | 7/22/2021 | N/A |
| 57 | S24985.57 | 6/3/2021 | Rm 154 Bath - Faucet | Faucet | Initial | 0.005 | 7/22/2021 | N/A |
| 58 | S24985.58 | 6/3/2021 | Rm 153 - Faucet | Faucet | Initial | <0.001 | 7/22/2021 | N/A |
| 59 | S24985.59 | 6/3/2021 | Rm 153 - Fountain | Fountain | Initial | <0.001 | 7/22/2021 | N/A |
| 60 | S24985.60 | 6/3/2021 | Rm 153 Bath - Faucet | Faucet | Initial | 0.004 | 7/22/2021 | N/A |
| 61 | S24985.61 | 6/3/2021 | Rm 155 - Faucet | Faucet | Initial | 0.002 | 7/22/2021 | N/A |
| 62 | S24985.62 | 6/3/2021 | Rm 155 Bath - Faucet | Faucet | Initial | 0.005 | 7/22/2021 | N/A |
| 63 | S24985.63 | 6/3/2021 | Rm 156 - Faucet | Faucet | Initial | 0.002 | 7/22/2021 | N/A |
| 64 | S24985.64 | 6/3/2021 | Rm 156 - Fountain | Fountain | Initial | <0.001 | 7/22/2021 | N/A |
| 65 | S24985.65 | 6/3/2021 | Rm 156 Bath - Faucet | Faucet | Initial | 0.003 | 7/22/2021 | N/A |
| 66 | S24985.66 | 6/3/2021 | Cafeteria - Women's Faculty Faucet | Faucet | Initial | 0.005 | 7/22/2021 | N/A |
| 67 | S24985.67 | 6/3/2021 | Cafeteria - Men's Faculty Faucet | Faucet | Initial | 0.007 | 7/22/2021 | N/A |
| 68 | S24985.68 | 6/3/2021 | Cafeteria Dish Sink - Faucet | Faucet | Initial | 0.013 | 7/22/2021 | N/A |
| 69 | S24985.69 | 6/3/2021 | Cafeteria Dish Sink - Faucet | Faucet | Initial | 0.009 | 7/22/2021 | N/A |
| 70 | S24985.70 | 6/3/2021 | Cafeteria Hand Sink - Faucet | Faucet | Initial | 0.018 | 7/22/2021 | SIGNAGE |
| 71 | S24985.71 | 6/3/2021 | Fountain Near Rm 101 | Fountain | Initial | 0.001 | 7/22/2021 | N/A |
| 72 | S24985.72 | 6/3/2021 | Rm 101 Asst. Principal's Office - Faucet | Faucet | Initial | 0.005 | 7/22/2021 | N/A |
| 73 | S24985.73 | 6/3/2021 | Rm 101 Asst. Principal's Bath - Faucet | Faucet | Initial | <0.001 | 7/22/2021 | N/A |
| 74 | S24985.74 | 6/3/2021 | 1st FL Womens Faculty Bath Faucet | Faucet | Initial | 0.005 | 7/22/2021 | N/A |
| 75 | S24985.75 | 6/3/2021 | 1st FL Mens Faculty Bath Faucet | Faucet | Initial | 0.003 | 7/22/2021 | N/A |

SCHOOL NAME: School #59A at Building 90 50 A Street**83 Outlets**

| Sample ID | Lab ID # | Sample Collection Date | Sample Location | Outlet Description | Initial/Post Remediation | Lead Result mg/L | Lab Report Receipt Date | Action Taken for Outlets Greater than 0.015 mg/L |
|-----------|-----------|------------------------|--|--------------------|--------------------------|------------------|-------------------------|--|
| 76 | S24985.76 | 6/3/2021 | Rm 102 SST Office - Faucet | Faucet | Initial | 0.006 | 7/22/2021 | N/A |
| 77 | S24985.77 | 6/3/2021 | Rm 107 Nurses Office - Faucet | Faucet | Initial | <0.001 | 7/22/2021 | N/A |
| 78 | S24985.78 | 6/3/2021 | Rm 107 Nurses Office Bath Faucet | Faucet | Initial | 0.004 | 7/22/2021 | N/A |
| 79 | S24985.79 | 6/3/2021 | Girls Bath near Engineer Office Faucet | Faucet | Initial | 0.001 | 7/22/2021 | N/A |
| 80 | S24985.80 | 6/3/2021 | Girls Bath near Engineer Office Faucet | Faucet | Initial | 0.004 | 7/22/2021 | N/A |
| 81 | S24985.81 | 6/3/2021 | Boys Bath near Engineer Office Faucet | Faucet | Initial | 0.003 | 7/22/2021 | N/A |
| 82 | S24985.82 | 6/3/2021 | Boys Bath near Engineer Office Faucet | Faucet | Initial | 0.002 | 7/22/2021 | N/A |
| 83 | S24985.83 | 6/3/2021 | Maintenance Garage Bath - Faucet | Faucet | Initial | <0.001 | 7/22/2021 | N/A |