

**SCHOOL NAME: School #99 Stanley Makowski Early Childhood 1095 Jefferson Ave****143 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
1	S24530.01	5/17/2021	Lower BOAT Mens Bathroom Faucet	Faucet	Initial	0.004	7/7/2021	N/A
2	S24530.02	5/17/2021	Rm 039 BOAT Faucet	Faucet	Initial	0.002	7/7/2021	N/A
3	S24530.03	5/17/2021	Rm 037 BOAT Faucet	Faucet	Initial	0.001	7/7/2021	N/A
4	S24530.04	5/17/2021	Rm 036 BOAT Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
5	S24530.05	5/17/2021	Rm 034 BOAT Faucet	Faucet	Initial	0.002	7/7/2021	N/A
6	S24530.06	5/17/2021	Rm 033 Faucet	Faucet	Initial	0.002	7/7/2021	N/A
7	S24530.07	5/17/2021	Rm 031 BOAT Faucet	Faucet	Initial	0.006	7/7/2021	N/A
8	S24530.08	5/17/2021	Rm 030 Faucet	Faucet	Initial	0.001	7/7/2021	N/A
9	S24530.09	5/17/2021	Lower BOAT Womens Bathroom faucet by Delaware Park	Faucet	Initial	<0.001	7/7/2021	N/A
10	S24530.10	5/17/2021	Rm 028 Faucet	Faucet	Initial	0.002	7/7/2021	N/A
11	S24530.11	5/17/2021	Rm 026 Faucet	Faucet	Initial	0.003	7/7/2021	N/A
12	S24530.12	5/17/2021	Lower BOAT Boys Changing Rm Faucet	Faucet	Initial	0.002	7/7/2021	N/A
13	S24530.13	5/17/2021	Lower BOAT Girls Changing Rm Faucet	Faucet	Initial	0.001	7/7/2021	N/A
14	S24530.14	5/17/2021	Rm 139 BOAT Faucet	Faucet	Initial	0.002	7/7/2021	N/A
15	S24530.15	5/17/2021	Rm 137 BOAT Faucet	Faucet	Initial	0.002	7/7/2021	N/A
16	S24530.16	5/17/2021	Rm 136 BOAT Faucet	Faucet	Initial	0.002	7/7/2021	N/A
17	S24530.17	5/17/2021	Rm 134 BOAT Faucet	Faucet	Initial	0.002	7/7/2021	N/A
18	S24530.18	5/17/2021	Rm 133 BOAT Faucet	Faucet	Initial	0.003	7/7/2021	N/A
19	S24530.19	5/17/2021	Rm 131 BOAT Faucet	Faucet	Initial	0.013	7/7/2021	N/A
20	S24530.20	5/17/2021	Rm 130 BOAT Faucet	Faucet	Initial	0.002	7/7/2021	N/A
21	S24530.21	5/17/2021	BOAT Café Faucet	Faucet	Initial	0.013	7/7/2021	N/A
22	S24530.22	5/17/2021	BOAT - Handwash Station	Faucet	Initial	0.003	7/7/2021	N/A
23	S24530.23	5/17/2021	Rm 127 BOAT Teacher Café Faucet	Faucet	Initial	0.006	7/7/2021	N/A
24	S24530.24	5/17/2021	BOAT Hallway Womens faucet	Faucet	Initial	0.010	7/7/2021	N/A
25	S24530.25	5/17/2021	BOAT Hallway Girls Faucet	Faucet	Initial	0.012	7/7/2021	N/A
26	S24530.26	5/17/2021	BOAT Hallway Boys Faucet	Faucet	Initial	0.003	7/7/2021	N/A
27	S24530.27	5/17/2021	RM 159 TRAIN Faucet	Faucet	Initial	0.009	7/7/2021	N/A
28	S24530.28	5/17/2021	TRAIN Hallway Mens Bathroom Faucet	Faucet	Initial	0.003	7/7/2021	N/A
29	S24530.29	5/17/2021	TRAIN Hallway Womens Bathroom Faucet	Faucet	Initial	<0.001	7/7/2021	N/A

**SCHOOL NAME:** School #99 Stanley Makowski Early Childhood 1095 Jefferson Ave **143 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
30	S24530.30	5/17/2021	TRAIN Hallway Fountain by Changing Room	Fountain	Initial	<0.001	7/7/2021	N/A
31	S24530.31	5/17/2021	Rm 123B BOAT Faucet	Faucet	Initial	0.018	7/7/2021	SIGNAGE
32	S24530.32	5/17/2021	Rm 122 BOAT Faucet	Faucet	Initial	0.003	7/7/2021	N/A
33	S24530.33	5/17/2021	Rm 161 TRAIN Café Handwash Station	Faucet	Initial	0.005	7/7/2021	N/A
34	S24530.34	5/17/2021	Rm 161 TRAIN Café Faucet B1	Faucet	Initial	0.001	7/7/2021	N/A
35	S24530.35	5/17/2021	Rm 161 TRAIN Café Faucet A1	Faucet	Initial	0.005	7/7/2021	N/A
36	S24530.36	5/17/2021	Rm 161 TRAIN Café Faucet A1	Faucet	Initial	0.005	7/7/2021	N/A
37	S24530.37	5/17/2021	Rm 155 TRAIN Teacher Lounge Faucet	Faucet	Initial	0.003	7/7/2021	N/A
38	S24530.38	5/17/2021	Rm 151 TRAIN Faucet	Faucet	Initial	0.003	7/7/2021	N/A
39	S24530.39	5/17/2021	Rm 150 TRAIN	Faucet	Initial	0.002	7/7/2021	N/A
40	S24530.40	5/17/2021	Rm 148 TRAIN	Faucet	Initial	0.006	7/7/2021	N/A
41	S24530.41	5/17/2021	Rm 147 TRAIN	Faucet	Initial	0.003	7/7/2021	N/A
42	S24530.42	5/17/2021	RM 145 TRAIN	Faucet	Initial	0.006	7/7/2021	N/A
43	S24530.43	5/17/2021	Rm 144 TRAIN	Faucet	Initial	0.005	7/7/2021	N/A
44	S24530.44	5/17/2021	Rm 142 TRAIN	Faucet	Initial	0.006	7/7/2021	N/A
45	S24530.45	5/17/2021	Rm 162 TRAIN Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
46	S24530.46	5/17/2021	Rm 164 TRAIN Faucet	Faucet	Initial	0.002	7/7/2021	N/A
47	S24530.47	5/17/2021	Rm 165 TRAIN Faucet	Faucet	Initial	0.005	7/7/2021	N/A
48	S24530.48	5/17/2021	Rm 168 TRAIN Faucet	Faucet	Initial	0.002	7/7/2021	N/A
49	S24530.49	5/17/2021	Rm 169 Faucet	Faucet	Initial	0.007	7/7/2021	N/A
50	S24530.50	5/17/2021	Rm 171 Faucet	Faucet	Initial	0.005	7/7/2021	N/A
51	S24530.51	5/17/2021	Rm 172 PLANE CAFÉ Faucet C1	Faucet	Initial	0.016	7/7/2021	work order to replace
52	S24530.52	5/17/2021	Rm 172 PLANE CAFÉ Faucet C2	Faucet	Initial	0.016	7/7/2021	work order to replace
53	S24530.53	5/17/2021	Rm 172 PLANE Behind Counter Faucet	Faucet	Initial	0.010	7/7/2021	N/A
54	S24530.54	5/17/2021	Rm 172 PLANE Wash Station Behind Serving Counter	Faucet	Initial	0.008	7/7/2021	N/A
55	S24530.55	5/17/2021	Rm 178 PLANE Faucet	Faucet	Initial	0.005	7/7/2021	N/A
56	S24530.56	5/17/2021	Rm 177 PLANE Faucet	Faucet	Initial	0.004	7/7/2021	N/A
57	S24530.57	5/17/2021	Hallway PLANE Womens Bathroom Faucet	Faucet	Initial	0.003	7/7/2021	N/A
58	S24530.58	5/17/2021	Hallway PLANE Mens Bathroom Faucet	Faucet	Initial	0.007	7/7/2021	N/A

**SCHOOL NAME:** School #99 Stanley Makowski Early Childhood 1095 Jefferson Ave **143 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
59	S24530.59	5/17/2021	Rm 174 PLANE Faucet	Faucet	Initial	0.003	7/7/2021	N/A
60	S24530.60	5/17/2021	Rm 175 B PLANE Back Office Bathroom Faucet	Faucet	Initial	0.008	7/7/2021	N/A
61	S24530.61	5/17/2021	PLANE Girls Changing Room	Faucet	Initial	0.011	7/7/2021	N/A
62	S24530.62	5/17/2021	PLANE Boys Changing Room	Faucet	Initial	0.029	7/7/2021	SIGNAGE
63	S24530.63	5/17/2021	Rm 181 PLANE Faucet	Faucet	Initial	0.008	7/7/2021	N/A
64	S24530.64	5/17/2021	Rm 182 PLANE Faucet	Faucet	Initial	0.002	7/7/2021	N/A
65	S24530.65	5/17/2021	Rm 184 PLANE Faucet	Faucet	Initial	0.002	7/7/2021	N/A
66	S24530.66	5/17/2021	Rm 185 PLANE Faucet	Faucet	Initial	0.004	7/7/2021	N/A
67	S24530.67	5/17/2021	Rm 187 PLANE Faucet	Faucet	Initial	0.002	7/7/2021	N/A
68	S24530.68	5/17/2021	Rm 188 Faucet	Faucet	Initial	0.005	7/7/2021	N/A
69	S24530.69	5/17/2021	Rm 190 Faucet	Faucet	Initial	0.003	7/7/2021	N/A
70	S24530.70	5/17/2021	Rm 100D Conference Rm Faucet	Faucet	Initial	0.005	7/7/2021	N/A
71	S24530.71	5/17/2021	Rm 100B Principles Office Faucet	Faucet	Initial	0.008	7/7/2021	N/A
72	S24530.72	5/17/2021	Main Hallway Boy's Bathroom Faucet	Faucet	Initial	0.008	7/7/2021	N/A
73	S24530.73	5/17/2021	Main Hallway Girl's Bathroom Faucet	Faucet	Initial	0.006	7/7/2021	N/A
74	S24530.74	5/17/2021	Main Hallway Family Bathroom Faucet	Faucet	Initial	0.004	7/7/2021	N/A
75	S24530.75	5/17/2021	Main Hallway Women's Staff Bathroom	Faucet	Initial	0.024	7/7/2021	SIGNAGE
76	S24530.76	5/17/2021	Main Hallway Men's Bathroom Faucet B1	Faucet	Initial	0.008	7/7/2021	N/A
77	S24530.77	5/17/2021	Main Hallway Men's Bathroom Faucet B2	Faucet	Initial	0.009	7/7/2021	N/A
78	S24530.78	5/17/2021	Main Hallway Women's Bathroom Faucet C1	Faucet	Initial	0.005	7/7/2021	N/A
79	S24530.79	5/17/2021	Main Hallway Women's Bathroom Faucet C2	Faucet	Initial	0.005	7/7/2021	N/A
80	S24530.80	5/17/2021	Rm 193 IC Faucet	Faucet	Initial	0.012	7/7/2021	N/A
81	S24530.81	5/17/2021	Rm 104 Kitchen	Faucet	Initial	0.001	7/7/2021	N/A
82	S24530.82	5/17/2021	Rm 104 Girls Bathroom	Faucet	Initial	0.001	7/7/2021	N/A
83	S24530.83	5/17/2021	Rm 104 Boys Bathroom	Faucet	Initial	<0.001	7/7/2021	N/A
84	S24530.84	5/17/2021	Rm 106E Bathroom Faucet	Faucet	Initial	0.004	7/7/2021	N/A
85	S24530.85	5/17/2021	Rm 109 Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
86	S24530.86	5/17/2021	Rm 111 Faucet	Faucet	Initial	0.011	7/7/2021	N/A
87	S24530.87	5/17/2021	Rm 112M Clinic Faucet	Faucet	Initial	<0.001	7/7/2021	N/A

**SCHOOL NAME:** School #99 Stanley Makowski Early Childhood 1095 Jefferson Ave **143 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
88	S24530.88	5/17/2021	Rm 112C Clinic Faucet	Faucet	Initial	0.007	7/7/2021	N/A
89	S24530.89	5/17/2021	Rm 112D Clinic Faucet	Faucet	Initial	0.011	7/7/2021	N/A
90	S24530.90	5/17/2021	Rm 112F Clinic Faucet	Faucet	Initial	0.016	7/7/2021	work order to replace
91	S24530.91	5/17/2021	Rm 112G Clinic Faucet	Faucet	Initial	0.005	7/7/2021	N/A
92	S24530.92	5/17/2021	Rm 112K Clinic Faucet	Faucet	Initial	0.003	7/7/2021	N/A
93	S24530.93	5/17/2021	Rm 112 Clinic Bathroom Next to 112L	Faucet	Initial	<0.001	7/7/2021	N/A
94	S24530.94	5/17/2021	Rm 112 Clinic Bathroom Next to 112	Faucet	Initial	0.001	7/7/2021	N/A
95	S24530.95	5/17/2021	Rm 113E FALK Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
96	S24530.96	5/17/2021	Rm 113E Bathroom Faucet	Faucet	Initial	0.004	7/7/2021	N/A
97	S24531.01	5/17/2021	Rm 113R Faucet	Faucet	Initial	0.006	7/7/2021	N/A
98	S24531.02	5/17/2021	Rm 113P FALK Bathroom Faucet	Faucet	Initial	0.004	7/7/2021	N/A
99	S24531.03	5/17/2021	Rm 113P FALK Faucet	Faucet	Initial	0.002	7/7/2021	N/A
100	S24531.04	5/17/2021	Rm 113L FALK Faucet	Faucet	Initial	0.006	7/7/2021	N/A
101	S24531.05	5/17/2021	Rm 113M FALK Bathroom Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
102	S24531.06	5/17/2021	Rm 113M FALK Faucet	Faucet	Initial	0.006	7/7/2021	N/A
103	S24531.07	5/17/2021	Rm 113M FALK Faucet	Faucet	Initial	0.003	7/7/2021	N/A
104	S24531.08	5/17/2021	Rm 113H FALK Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
105	S24531.09	5/17/2021	Rm 113H FALK Bathroom Faucet	Faucet	Initial	0.002	7/7/2021	N/A
106	S24531.10	5/17/2021	Rm 199 Faucet	Faucet	Initial	0.008	7/7/2021	N/A
107	S24531.11	5/17/2021	Rm 197 Faucet	Faucet	Initial	0.004	7/7/2021	N/A
108	S24531.12	5/17/2021	Rm 195 Library Faculty Faucet C	Faucet	Initial	0.007	7/7/2021	N/A
109	S24531.13	5/17/2021	Rm 195 Library Faculty Faucet A	Faucet	Initial	0.011	7/7/2021	N/A
110	S24531.14	5/17/2021	Rm 195G Library Faucet	Faucet	Initial	0.006	7/7/2021	N/A
111	S24531.15	5/17/2021	Rm 195A Faucet	Faucet	Initial	0.007	7/7/2021	N/A
112	S24531.16	5/17/2021	Rm 115	Faucet	Initial	0.003	7/7/2021	N/A
113	S24531.17	5/17/2021	Rm 115 Bathroom	Faucet	Initial	0.002	7/7/2021	N/A
114	S24531.18	5/17/2021	Kitchen Faucet B1	Faucet	Initial	0.005	7/7/2021	N/A
115	S24531.19	5/17/2021	Kitchen Hand Wash	Faucet	Initial	<0.001	7/7/2021	N/A
116	S24531.20	5/17/2021	Kitchen Faucet B2	Faucet	Initial	0.001	7/7/2021	N/A

**SCHOOL NAME:** School #99 Stanley Makowski Early Childhood 1095 Jefferson Ave **143 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
117	S24531.21	5/17/2021	Kitchen Faucet B3	Faucet	Initial	<0.001	7/7/2021	N/A
118	S24531.22	5/17/2021	Kitchen Faucet B4	Faucet	Initial	<0.001	7/7/2021	N/A
119	S24531.23	5/17/2021	Kitchen Faucet B5	Faucet	Initial	<0.001	7/7/2021	N/A
120	S24531.24	5/17/2021	Kitchen Faucet Center of Room C	Faucet	Initial	0.001	7/7/2021	N/A
121	S24531.25	5/17/2021	Kitchen Faucet Center of Room A	Faucet	Initial	0.001	7/7/2021	N/A
122	S24531.26	5/17/2021	Kitchen Pot Filler C1	Faucet	Initial	0.006	7/7/2021	N/A
123	S24531.27	5/17/2021	Kitchen Pot Filler C2	Faucet	Initial	<0.001	7/7/2021	N/A
124	S24531.28	5/17/2021	Chief Engineer Men's Bathroom	Faucet	Initial	0.004	7/7/2021	N/A
125	S24531.29	5/17/2021	Rm 289 UPPER PLANE Faucet	Faucet	Initial	0.002	7/7/2021	N/A
126	S24531.30	5/17/2021	Rm 287 UPPER PLANE Faucet	Faucet	Initial	0.004	7/7/2021	N/A
127	S24531.31	5/17/2021	Rm 286 UPPER PLANE Faucet	Faucet	Initial	0.002	7/7/2021	N/A
128	S24531.32	5/17/2021	Rm 285 UPPER PLANE Faucet	Faucet	Initial	0.004	7/7/2021	N/A
129	S24531.33	5/17/2021	Rm 284 UPPER PLANE Faucet	Faucet	Initial	0.003	7/7/2021	N/A
130	S24531.34	5/17/2021	Rm 283 UPPER PLANE Faucet	Faucet	Initial	0.002	7/7/2021	N/A
131	S24531.35	5/17/2021	Rm 281 UPPER PLANE Faucet	Faucet	Initial	0.002	7/7/2021	N/A
132	S24531.36	5/17/2021	Rm 280 UPPER PLANE Faucet	Faucet	Initial	0.006	7/7/2021	N/A
133	S24531.37	5/17/2021	Womens UPPER PLANE Bathroom Faucet	Faucet	Initial	0.001	7/7/2021	N/A
134	S24531.38	5/17/2021	Mens UPPER PLANE Bathroom Faucet	Faucet	Initial	0.002	7/7/2021	N/A
135	S24531.39	5/17/2021	UPPER TRAIN Rm 242 Faucet	Faucet	Initial	0.002	7/7/2021	N/A
136	S24531.40	5/17/2021	UPPER TRAIN Rm 244 Faucet	Faucet	Initial	0.002	7/7/2021	N/A
137	S24531.41	5/17/2021	UPPER TRAIN Rm 245 Faucet	Faucet	Initial	0.003	7/7/2021	N/A
138	S24531.42	5/17/2021	UPPER TRAIN Rm 247 Faucet	Faucet	Initial	0.004	7/7/2021	N/A
139	S24531.43	5/17/2021	UPPER TRAIN Rm 248 Faucet	Faucet	Initial	0.004	7/7/2021	N/A
140	S24531.44	5/17/2021	UPPER TRAIN Rm 250 Faucet	Faucet	Initial	0.002	7/7/2021	N/A
141	S24531.45	5/17/2021	UPPER TRAIN Rm 251 Faucet	Faucet	Initial	<0.001	7/7/2021	N/A
142	S24531.46	5/17/2021	UPPER TRAIN Mens Bathroom	Faucet	Initial	0.004	7/7/2021	N/A
143	S24531.47	5/17/2021	UPPER TRAIN Womens Bathroom	Faucet	Initial	0.006	7/7/2021	N/A