

SCHOOL NAME: School #156 319 Suffolk Street							70 Outlets	
Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
1	21P006403	5/22/2021	Rm 404	Faucet	Initial	0.0019	7/7/2021	N/A
2	21P006404	5/22/2021	Room 412	Faucet	Initial	<0.0010	7/7/2021	N/A
3	21P006405	5/22/2021	Room 300	Faucet	Initial	0.0135	7/7/2021	N/A
4	21P006406	5/22/2021	Room 312	Faucet	Initial	<0.0010	7/7/2021	N/A
5	21P006407	5/22/2021	Room 314	Faucet	Initial	<0.0010	7/7/2021	N/A
6	21P006408	5/22/2021	Room 325	Faucet	Initial	0.0055	7/7/2021	N/A
7	21P006409	5/22/2021	Room 200	Faucet	Initial	<0.0010	7/7/2021	N/A
8	21P006410	5/22/2021	Room 215	Faucet	Initial	<0.0010	7/7/2021	N/A
9	21P006411	5/22/2021	Room 227	Faucet	Initial	<0.0010	7/7/2021	N/A
10	21P006412	5/22/2021	Rm 230 NE Sink	Faucet	Initial	0.001	7/7/2021	N/A
11	21P006413	5/22/2021	Rm 230 SE Sink	Faucet	Initial	<0.0010	7/7/2021	N/A
12	21P006414	5/22/2021	Rm 230 NW Sink	Faucet	Initial	<0.0010	7/7/2021	N/A
13	21P006415	5/22/2021	Rm 230 SW Sink	Faucet	Initial	<0.0010	7/7/2021	N/A
14	21P006416	5/22/2021	Room 127	Faucet	Initial	<0.0010	7/7/2021	N/A
15	21P006417	5/22/2021	Rm Clinic North	Faucet	Initial	0.0269	7/7/2021	SIGNAGE
16	21P006418	5/22/2021	Rm 128 Clinic South	Faucet	Initial	0.0013	7/7/2021	N/A
17	21P006419	5/22/2021	Kitchen N	Faucet	Initial	<0.0010	7/7/2021	N/A
18	21P006420	5/22/2021	Kitchen Center	Faucet	Initial	<0.0010	7/7/2021	N/A
19	21P006421	5/22/2021	Kitchen S	Faucet	Initial	<0.0010	7/7/2021	N/A
20	21P006422	5/22/2021	Rm 133 Custodian	Faucet	Initial	<0.0010	7/7/2021	N/A
1	21P006346	5/29/2021	Boys Lav 4th Floor	Faucet	Initial	<0.0010	7/7/2021	N/A

**SCHOOL NAME: School #156 319 Suffolk Street** **70 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
2	21P006347	5/29/2021	Boys Lav 4th Floor	Faucet	Initial	<0.0010	7/7/2021	N/A
3	21P006348	5/29/2021	Boys Lav 4th Floor	Faucet	Initial	<0.0010	7/7/2021	N/A
4	21P006349	5/29/2021	Boys Lav 4th Floor	Faucet	Initial	0.0011	7/7/2021	N/A
5	21P006350	5/29/2021	Boys Lav 4th Floor	Faucet	Initial	<0.0010	7/7/2021	N/A
6	21P006351	5/29/2021	Rm 424	Faucet	Initial	<0.0010	7/7/2021	N/A
7	21P006352	5/29/2021	Girls Lav 4th Floor	Faucet	Initial	<0.0010	7/7/2021	N/A
8	21P006353	5/29/2021	Girls Lav 4th Floor	Faucet	Initial	0.0013	7/7/2021	N/A
9	21P006354	5/29/2021	Girls Lav 4th Floor	Faucet	Initial	<0.0010	7/7/2021	N/A
10	21P006355	5/29/2021	Girls Lav 4th Floor	Faucet	Initial	0.0033	7/7/2021	N/A
11	21P006356	5/29/2021	Girls Lav 4th Floor	Faucet	Initial	0.0034	7/7/2021	N/A
12	21P006357	5/29/2021	Boys Lav 3rd Floor	Faucet	Initial	<0.0010	7/7/2021	N/A
13	21P006358	5/29/2021	Boys Lav 3rd Floor	Faucet	Initial	<0.0010	7/7/2021	N/A
14	21P006359	5/29/2021	Boys Lav 3rd Floor	Faucet	Initial	0.0052	7/7/2021	N/A
15	21P006360	5/29/2021	Boys Lav 3rd Floor	Faucet	Initial	<0.0010	7/7/2021	N/A
16	21P006361	5/29/2021	Boys Lav 3rd Floor	Faucet	Initial	<0.0010	7/7/2021	N/A
17	21P006362	5/29/2021	Room 327	Faucet	Initial	0.0024	7/7/2021	N/A
18	21P006363	5/29/2021	Girls Lav 3rd Floor	Faucet	Initial	0.0017	7/7/2021	N/A
19	21P006364	5/29/2021	Girls Lav 3rd Floor	Faucet	Initial	<0.0010	7/7/2021	N/A
20	21P006365	5/29/2021	Girls Lav 3rd Floor	Faucet	Initial	0.0015	7/7/2021	N/A
21	21P006366	5/29/2021	Girls Lav 3rd Floor	Faucet	Initial	<0.0010	7/7/2021	N/A
22	21P006367	5/29/2021	Girls Lav 3rd Floor	Faucet	Initial	<0.0010	7/7/2021	N/A

**SCHOOL NAME: School #156 319 Suffolk Street** **70 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
23	21P006368	5/29/2021	Room 212	Faucet	Initial	<0.0010	7/7/2021	N/A
24	21P006369	5/29/2021	Boys Lav 2nd Floor	Faucet	Initial	<0.0010	7/7/2021	N/A
25	21P006370	5/29/2021	Boys Lav 2nd Floor	Faucet	Initial	0.001	7/7/2021	N/A
26	21P006371	5/29/2021	Boys Lav 2nd Floor	Faucet	Initial	<0.0010	7/7/2021	N/A
27	21P006372	5/29/2021	Boy Lav 2nd Floor	Faucet	Initial	<0.0010	7/7/2021	N/A
28	21P006380	5/29/2021	Boys Lav 2nd Floor	Faucet	Initial	<0.0010	7/7/2021	N/A
29	21P006381	5/29/2021	Girls Lav 2nd Floor	Faucet	Initial	0.0026	7/7/2021	N/A
30	21P006382	5/29/2021	Girls Lav 2nd Floor	Faucet	Initial	0.0361	7/7/2021	SIGNAGE
31	21P006383	5/29/2021	Girls Lav 2nd Floor	Faucet	Initial	0.0411	7/7/2021	SIGNAGE
32	21P006384	5/29/2021	Girls Lav 2nd Floor	Faucet	Initial	0.2425	7/7/2021	SIGNAGE
33	21P006385	5/29/2021	Girls Lav 2nd Floor	Faucet	Initial	<0.0010	7/7/2021	N/A
34	21P006386	5/29/2021	Room 229	Faucet	Initial	0.0113	7/7/2021	N/A
35	21P006387	5/29/2021	Room 229	Faucet	Initial	0.0103	7/7/2021	N/A
36	21P006388	5/29/2021	Room 229	Faucet	Initial	0.0021	7/7/2021	N/A
37	21P006389	5/29/2021	Room 229	Faucet	Initial	0.0011	7/7/2021	N/A
38	21P006390	5/29/2021	Main Office Lav	Faucet	Initial	<0.0010	7/7/2021	N/A
39	21P006391	5/29/2021	Principal Office	Faucet	Initial	<0.0010	7/7/2021	N/A
40	21P006392	5/29/2021	Room 111 by 109 Lav	Faucet	Initial	<0.0010	7/7/2021	N/A
41	21P006393	5/29/2021	Girls Lav 1st Floor	Faucet	Initial	0.0013	7/7/2021	N/A
42	21P006394	5/29/2021	Girls Lav 1st floor	Faucet	Initial	0.0018	7/7/2021	N/A
43	21P006395	5/29/2021	Girls Lav 1st Floor	Faucet	Initial	0.0213	7/7/2021	SIGNAGE

**SCHOOL NAME: School #156 319 Suffolk Street** **70 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
44	21P006396	5/29/2021	Girls Lav 1st Floor	Faucet	Initial	<0.0010	7/7/2021	N/A
45	21P006397	5/29/2021	Girls Lav 1st Floor	Faucet	Initial	0.1506	7/7/2021	SIGNAGE
46	21P006398	5/29/2021	Boys Lav 1st Floor	Faucet	Initial	<0.0010	7/7/2021	N/A
47	21P006399	5/29/2021	Boys Lav 1st Floor	Faucet	Initial	0.0013	7/7/2021	N/A
48	21P006400	5/29/2021	Boys Lav 1st Floor	Faucet	Initial	0.0013	7/7/2021	N/A
49	21P006401	5/29/2021	Boys Lav 1st Floor	Faucet	Initial	0.0887	7/7/2021	SIGNAGE
50	21P006402	5/29/2021	Boys Lav 1st Floor	Faucet	Initial	<0.0010	7/7/2021	N/A