

**SCHOOL NAME: School #208 @ Building 205 51 Ontario Street**
**75 Outlets**

| Sample ID | Lab ID #  | Sample Collection Date | Sample Location                            | Outlet Description | Initial/Post Remediation | Lead Result mg/L | Lab Report Receipt Date | Action Taken for Outlets Greater than 0.015 mg/L |
|-----------|-----------|------------------------|--|--------------------|--------------------------|------------------|-------------------------|--|
| 1         | 21P006509 | 6/5/2021               | 3rd Floor Girls Lav                        | Faucet             | Initial                  | 0.0012           | 7/13/2021               | N/A  |
| 2         | 21P006510 | 6/5/2021               | Drinking Fountain 3rd Floor Girls Lav      | Fountain           | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 3         | 21P006511 | 6/5/2021               | Drinking Fountain Girls Lav 3rd Floor      | Fountain           | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 4         | 21P006512 | 6/5/2021               | Teacher Faculty 3rd Floor Rm #313          | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 5         | 21P006513 | 6/5/2021               | 3rd Floor Boy Lav                          |                    | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 6         | 21P006514 | 6/5/2021               | 3rd Floor Drinking Fountains Boys Lav      | Fountain           | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 7         | 21P006515 | 6/5/2021               | 3rd Floor Drinking Fountains Boys Lav      | Fountain           | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 8         | 21P006516 | 6/5/2021               | 2nd Floor Drinking Fountains Girls Lav     | Fountain           | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 9         | 21P006517 | 6/5/2021               | 2nd Floor Girls Lav Drinking Fountains     | Fountain           | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 10        | 21P006522 | 6/5/2021               | 2nd Floor Girls Lav                        | Faucet             | Initial                  | 0.0014           | 7/13/2021               | N/A  |
| 11        | 21P006523 | 6/5/2021               | 2nd Floor Faculty Lav                      | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 12        | 21P006524 | 6/5/2021               | 2nd Floor Drinking Fountain boys Lav       | Fountain           | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 13        | 21P006525 | 6/5/2021               | Library Sink                               | Faucet             | Initial                  | 0.0152           | 7/13/2021               | SIGNAGE  |
| 14        | 21P006526 | 6/5/2021               | 1st Floor Drinking Fountain Girls Lav      | Fountain           | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 15        | 21P006529 | 6/5/2021               | 1st Floor Drinking Fountain Girls Lav      | Fountain           | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 16        | 21P006530 | 6/5/2021               | 1st Floor Girls Lav                        | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 17        | 21P006531 | 6/5/2021               | 1st Floor Teachers Faculty                 | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 18        | 21P006532 | 6/5/2021               | Drinking Fountain Weight Room              | Fountain           | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 19        | 21P006533 | 6/5/2021               | Drinking Fountain Weight Room              | Fountain           | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 20        | 21P006534 | 6/5/2021               | Boys Lav Pavillion                         | Faucet             | Initial                  | 0.0046           | 7/13/2021               | N/A  |
| 21        | 21P006535 | 6/5/2021               | Girls Lav Pavillion                        | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 22        | 21P006536 | 6/5/2021               | Drinking Fountain Pavillion 1st Floor Hall | Fountain           | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 23        | 21P006537 | 6/5/2021               | Drinking Fountain 1st Floor Pavillion Hall | Fountain           | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 24        | 21P006538 | 6/5/2021               | Girls Gym Locker Room                      | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 25        | 21P006539 | 6/5/2021               | 121A Gym                                   | Faucet             | Initial                  | 0.0032           | 7/13/2021               | N/A  |
| 26        | 21P006540 | 6/5/2021               | 121B Gym                                   | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 27        | 21P006541 | 6/5/2021               | Boys Locker Room Gym                       | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 28        | 21P006542 | 6/5/2021               | 1st Floor Boys Lav                         | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |

**SCHOOL NAME: School #208 @ Building 205 51 Ontario Street**
**75 Outlets**

| Sample ID | Lab ID #  | Sample Collection Date | Sample Location                              | Outlet Description | Initial/Post Remediation | Lead Result mg/L | Lab Report Receipt Date | Action Taken for Outlets Greater than 0.015 mg/L |
|-----------|-----------|------------------------|--|--------------------|--------------------------|------------------|-------------------------|--|
| 29        | 21P006543 | 6/5/2021               | Drinking Fountain Boys Lav                   | Fountain           | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 30        | 21P006544 | 6/5/2021               | 131 Clinic Sink                              | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 31        | 21P006545 | 6/5/2021               | 131 Clinic Bathroom Sink                     | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 32        | 21P006546 | 6/5/2021               | 131C Sink                                    | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 33        | 21P006547 | 6/5/2021               | 131E Sink                                    | Faucet             | Initial                  | 0.0024           | 7/13/2021               | N/A  |
| 34        | 21P006580 | 6/5/2021               | 131F Sink                                    | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 35        | 21P006581 | 6/5/2021               | Rm 100 Main Office Lav                       | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 36        | 21P006582 | 6/5/2021               | Rm 100 Principals Office                     | Faucet             | Initial                  | 0.0021           | 7/13/2021               | N/A  |
| 37        | 21P006583 | 6/5/2021               | Rm 111 Sink 1                                | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 38        | 21P006584 | 6/5/2021               | Rm 111 Sink 2                                | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 39        | 21P006585 | 6/5/2021               | Rm 024 Faculty Sink                          | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 40        | 21P006586 | 6/5/2021               | Rm 024 Faculty Lav                           | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 41        | 21P006587 | 6/5/2021               | Basement Boys Lav                            | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 42        | 21P006588 | 6/5/2021               | Basement Girls Lav                           | Faucet             | Initial                  | 0.0022           | 7/13/2021               | N/A  |
| 43        | 21P006589 | 6/5/2021               | Café Water Fountain                          | Fountain           | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 44        | 21P006590 | 6/5/2021               | Café Water Fountain                          | Fountain           | Initial                  | 0.002            | 7/13/2021               | N/A  |
| 45        | 21P006591 | 6/5/2021               | Rm 013 Sink                                  | Faucet             | Initial                  | 0.0156           | 7/13/2021               | SIGNAGE  |
| 46        | 21P006592 | 6/5/2021               | Hand Sink Behind Serving Line                | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 47        | 21P006593 | 6/5/2021               | Kitchen Hand Sink #2                         | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 48        | 21P006594 | 6/5/2021               | Kitchen Hand Sink #1                         | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 49        | 21P006595 | 6/5/2021               | Kitchen Vegetable Sink                       | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 50        | 21P006596 | 6/5/2021               | Kitchen 3 Base Sink #1                       | Faucet             | Initial                  | 0.0016           | 7/13/2021               | N/A  |
| 51        | 21P006597 | 6/5/2021               | Kitchen 3 Base Sink #2                       | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 52        | 21P006598 | 6/5/2021               | Mezz Girls Lav                               | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 53        | 21P006599 | 6/5/2021               | Mezz Boys Lav                                | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 54        | 21P006600 | 6/5/2021               | Lower Pavillion Boys Lav Outside             | Faucet             | Initial                  | 0.0073           | 7/13/2021               | N/A  |
| 55        | 21P006601 | 6/5/2021               | Outside Pavillion Boys Lav Water Fountain    | Fountain           | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 56        | 21P006602 | 6/5/2021               | Outside Pavillion Boys Lav Drinking Fountain | Fountain           | Initial                  | <0.0010          | 7/13/2021               | N/A  |

**SCHOOL NAME: School #208 @ Building 205 51 Ontario Street****75 Outlets**

| Sample ID | Lab ID #  | Sample Collection Date | Sample Location                               | Outlet Description | Initial/Post Remediation | Lead Result mg/L | Lab Report Receipt Date | Action Taken for Outlets Greater than 0.015 mg/L |
|-----------|-----------|------------------------|---|--------------------|--------------------------|------------------|-------------------------|--|
| 57        | 21P006603 | 6/5/2021               | Outside Pavillion Girls Lav Drinking Fountain | Fountain           | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 58        | 21P006604 | 6/5/2021               | Outside Pavillion Girls Lav Drinking Fountain | Fountain           | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 59        | 21P006605 | 6/5/2021               | Outside Pavillion Girls Lav Sink              | Faucet             | Initial                  | 0.005            | 7/13/2021               | N/A  |
| 60        | 21P006606 | 6/5/2021               | Outside Pavillion Girls Lav Sink              | Faucet             | Initial                  | 0.0025           | 7/13/2021               | N/A  |
| 61        | 21P006607 | 6/5/2021               | Baby Changing Room                            | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 62        | 21P006608 | 6/5/2021               | Rm 040A Sink                                  | Faucet             | Initial                  | 0.0014           | 7/13/2021               | N/A  |
| 63        | 21P006609 | 6/5/2021               | JV & Varsity Drinking Fountain                | Fountain           | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 64        | 21P006610 | 6/5/2021               | JV & Varsity Drinking Fountain                | Fountain           | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 65        | 21P006611 | 6/5/2021               | Rm 046A                                       | Faucet             | Initial                  | 0.0248           | 7/13/2021               | SIGNAGE  |
| 66        | 21P006612 | 6/5/2021               | Referee's Changing Room Sink                  | Faucet             | Initial                  | 0.022            | 7/13/2021               | SIGNAGE  |
| 67        | 21P006613 | 6/5/2021               | Referee's Room Water Fountain                 | Fountain           | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 68        | 21P006614 | 6/5/2021               | Referee's Room Drinking Fountain              | Fountain           | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 69        | 21P006615 | 6/5/2021               | Rm 044 Sink                                   | Faucet             | Initial                  | 0.0022           | 7/13/2021               | N/A  |
| 70        | 21P006616 | 6/5/2021               | 048A Sink                                     | Faucet             | Initial                  | 0.0046           | 7/13/2021               | N/A  |
| 71        | 21P006617 | 6/5/2021               | Visitors Locker Room Water Fountain           | Fountain           | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 72        | 21P006618 | 6/5/2021               | Visitors Locker Room Water Fountain           | Fountain           | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 73        | 21P006619 | 6/5/2021               | Visitors Locker Room Sink                     | Faucet             | Initial                  | 0.0344           | 7/13/2021               | SIGNAGE  |
| 74        | 21P006620 | 6/5/2021               | Girls Pool Locker Room Sink                   | Faucet             | Initial                  | <0.0010          | 7/13/2021               | N/A  |
| 75        | 21P006621 | 6/5/2021               | Boys Pool Locker Room                         | Faucet             | Initial                  | 0.0013           | 7/13/2021               | N/A  |