

SCHOOL NAME: School #92 at Building 91 340 Fougeron Street**56 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
1	S24739.01	5/26/2021	Boiler Rm - Faucet	Faucet	Initial	0.003	7/16/2021	N/A
2	S24739.02	5/26/2021	Engineer Office Bathroom - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
3	S24739.03	5/26/2021	Boys Gym Locker Rm - Faucet B1	Faucet	Initial	0.004	7/16/2021	N/A
4	S24739.04	5/26/2021	Boys Gym Locker Rm - Faucet B2	Faucet	Initial	0.018	7/16/2021	SIGNAGE
5	S24739.05	5/26/2021	Gym Office - Faucet	Faucet	Initial	0.015	7/16/2021	N/A
6	S24739.06	5/26/2021	Girls Gym Locker Rm - Faucet D1	Faucet	Initial	0.012	7/16/2021	N/A
7	S24739.07	5/26/2021	Girls Gym Locker Rm - Faucet D2	Faucet	Initial	<0.001	7/16/2021	N/A
8	S24739.08	5/26/2021	Fountain next to Rm 132	Fountain	Initial	0.001	7/16/2021	N/A
9	S24739.09	5/26/2021	Rm 111 - Fountain	Fountain	Initial	<0.001	7/16/2021	N/A
10	S24739.10	5/26/2021	Rm 111 - Faucet	Faucet	Initial	0.002	7/16/2021	N/A
11	S24739.11	5/26/2021	Rm 112 - Faucet D1	Faucet	Initial	0.003	7/16/2021	N/A
12	S24739.12	5/26/2021	Rm 112 - Faucet D2	Faucet	Initial	0.001	7/16/2021	N/A
13	S24739.13	5/26/2021	Rm 113 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
14	S24739.14	5/26/2021	Rm 113 - Fountain	Fountain	Initial	<0.001	7/16/2021	N/A
15	S24739.15	5/26/2021	Rm 114 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
16	S24739.16	5/26/2021	Rm 114 - Fountain	Fountain	Initial	<0.001	7/16/2021	N/A
17	S24739.17	5/26/2021	Rm 115 - Fountain	Fountain	Initial	0.001	7/16/2021	N/A
18	S24739.18	5/26/2021	Rm 115 - Faucet	Faucet	Initial	0.002	7/16/2021	N/A
19	S24739.19	5/26/2021	Rm 117 - Faucet	Faucet	Initial	0.001	7/16/2021	N/A
20	S24739.20	5/26/2021	Rm 117 - Fountain	Fountain	Initial	<0.001	7/16/2021	N/A
21	S24739.21	5/26/2021	Faculty Bathroom - Faucet near cafeteria to the right	Faucet	Initial	0.003	7/16/2021	N/A
22	S24739.22	5/26/2021	Faculty Lounge - Faucet 119	Faucet	Initial	0.002	7/16/2021	N/A
23	S24739.23	5/26/2021	Main Office Con 101F - Faucet	Faucet	Initial	0.008	7/16/2021	N/A
24	S24739.24	5/26/2021	Main Office Break Area - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
25	S24739.25	5/26/2021	Main Office Bathroom - Faucet C	Faucet	Initial	0.002	7/16/2021	N/A
26	S24739.26	5/26/2021	Main Office Bathroom - Faucet B	Faucet	Initial	0.002	7/16/2021	N/A

SCHOOL NAME: School #92 at Building 91 340 Fougeron Street**56 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
27	S24739.27	5/26/2021	Rm 149 - Faucet A1	Faucet	Initial	<0.001	7/16/2021	N/A
28	S24739.28	5/26/2021	Rm 149 - Faucet A2	Faucet	Initial	0.005	7/16/2021	N/A
29	S24739.29	5/26/2021	Rm 149 - Faucet C1	Faucet	Initial	0.004	7/16/2021	N/A
30	S24739.30	5/26/2021	Rm 149 - Faucet C2	Faucet	Initial	0.002	7/16/2021	N/A
31	S24739.31	5/26/2021	Kitchen Faucet - Hand Wash D1	Faucet	Initial	0.015	7/16/2021	N/A
32	S24739.32	5/26/2021	Kitchen - Faucet D2	Faucet	Initial	0.002	7/16/2021	N/A
33	S24739.33	5/26/2021	Kitchen - Faucet 3	Faucet	Initial	0.003	7/16/2021	N/A
34	S24739.34	5/26/2021	Kitchen - Faucet B	Faucet	Initial	0.007	7/16/2021	N/A
35	S24739.35	5/26/2021	Kitchen - Faucet D1	Faucet	Initial	0.003	7/16/2021	N/A
36	S24739.36	5/26/2021	Kitchen - Faucet D2	Faucet	Initial	0.037	7/16/2021	W/O TO REPLACE
37	S24739.37	5/26/2021	Cafeteria Faculty - Bathroom	Faucet	Initial	0.003	7/16/2021	N/A
38	S24739.38	5/26/2021	Bottle Filler by Room 234	Bottle Filler	Initial	0.001	7/16/2021	N/A
39	S24739.39	5/26/2021	Faculty Bathroom near Rm 200 - Faucet	Faucet	Initial	0.006	7/16/2021	N/A
40	S24739.40	5/26/2021	Faculty Lounge - Faucet Room 203	Faucet	Initial	<0.001	7/16/2021	N/A
41	S24739.41	5/26/2021	Faculty Bathroom - Faucet Room 203	Faucet	Initial	<0.001	7/16/2021	N/A
42	S24739.42	5/26/2021	Rm 209 Bathroom - Faucet	Faucet	Initial	0.005	7/16/2021	N/A
43	S24739.43	5/26/2021	Faculty Bathroom near Rm 229 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
44	S24739.44	5/26/2021	Library Office - Faucet	Faucet	Initial	0.002	7/16/2021	N/A
45	S24739.45	5/26/2021	Library Bathroom - Faucet	Faucet	Initial	0.001	7/16/2021	N/A
46	S24739.46	5/26/2021	Clinic Rm 108 - Faucet	Faucet	Initial	0.002	7/16/2021	N/A
47	S24739.47	5/26/2021	Clinic Rm 108I - Faucet	Faucet	Initial	0.003	7/16/2021	N/A
48	S24739.48	5/26/2021	Clinic Rm 108G - Faucet	Faucet	Initial	0.025	7/16/2021	W/O TO REPLACE
49	S24739.49	5/26/2021	Clinic Bathroom - Faucet D	Faucet	Initial	<0.001	7/16/2021	N/A
50	S24739.50	5/26/2021	Clinic Bathroom - Faucet B	Faucet	Initial	0.002	7/16/2021	N/A
51	S24739.51	5/26/2021	Boys Pool Locker Rm - Faucet	Faucet	Initial	0.102	7/16/2021	SIGNAGE
52	S24739.52	5/26/2021	Girls Pool Locker Rm - Faucet A1	Faucet	Initial	0.024	7/16/2021	SIGNAGE

SCHOOL NAME: School #92 at Building 91 340 Fougeron Street**56 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
53	S24739.53	5/26/2021	Girls Pool Locker Rm - Faucet A2	Faucet	Initial	0.023	7/16/2021	SIGNAGE
54	S24739.54	5/26/2021	Handicap Bathroom across from Pool	Faucet	Initial	0.003	7/16/2021	N/A
55	S24739.55	5/26/2021	Faculty Bathroom to the right	Faucet	Initial	0.010	7/16/2021	N/A
56	S24739.56	5/26/2021	Faculty Bathroom to the left	Faucet	Initial	0.003	7/16/2021	N/A