

**SCHOOL NAME: School #76 315 Carolina Street****55 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
1	S24779.01	5/27/2021	Principals Bathroom - Faucet	Faucet	Initial	0.011	7/20/2021	N/A
2	S24779.02	5/27/2021	Office Work Rm - Faucet	Faucet	Initial	0.001	7/20/2021	N/A
3	S24779.03	5/27/2021	Office Bathroom - Facuet	Faucet	Initial	0.001	7/20/2021	N/A
4	S24779.04	5/27/2021	Clinic Bathroom - Faucet	Faucet	Initial	0.002	7/20/2021	N/A
5	S24779.05	5/27/2021	Clinic Exam Rm 1 - Faucet 101C	Faucet	Initial	<0.001	7/20/2021	N/A
6	S24779.06	5/27/2021	Rm 105 - Faucet	Faucet	Initial	<0.001	7/20/2021	N/A
7	S24779.07	5/27/2021	Rm 105 Bathroom - Faucet	Faucet	Initial	<0.001	7/20/2021	N/A
8	S24779.08	5/27/2021	Rm 107 - Faucet	Faucet	Initial	<0.001	7/20/2021	N/A
9	S24779.09	5/27/2021	Rm 107 - Bathroom Faucet	Faucet	Initial	<0.001	7/20/2021	N/A
10	S24779.10	5/27/2021	Rm 108 - Faucet	Faucet	Initial	0.002	7/20/2021	N/A
11	S24779.11	5/27/2021	Rm 108 Bathroom - Faucet	Faucet	Initial	0.002	7/20/2021	N/A
12	S24779.12	5/27/2021	Rm 109 - Faucet	Faucet	Initial	<0.001	7/20/2021	N/A
13	S24779.13	5/27/2021	Rm 109 Bathroom - Faucet	Faucet	Initial	<0.001	7/20/2021	N/A
14	S24779.14	5/27/2021	Rm 110 - Faucet	Faucet	Initial	<0.001	7/20/2021	N/A
15	S24779.15	5/27/2021	Rm 110 Bathroom - Faucet	Faucet	Initial	0.003	7/20/2021	N/A
16	S24779.16	5/27/2021	Rm 111 - Faucet	Faucet	Initial	0.001	7/20/2021	N/A
17	S24779.17	5/27/2021	Rm 112 - Faucet	Faucet	Initial	0.001	7/20/2021	N/A
18	S24779.18	5/27/2021	Rm 112 Bathroom - Faucet	Faucet	Initial	0.003	7/20/2021	N/A
19	S24779.19	5/27/2021	Rm 113 - Faucet	Faucet	Initial	<0.001	7/20/2021	N/A
20	S24779.20	5/27/2021	Rm 113 - Bathroom Faucet	Faucet	Initial	0.001	7/20/2021	N/A
21	S24779.21	5/27/2021	1st Fl Boys Bathroom - Faucet	Faucet	Initial	0.003	7/20/2021	N/A
22	S24779.22	5/27/2021	1st Fl Boys Bathroom - Faucet	Faucet	Initial	0.001	7/20/2021	N/A
23	S24779.23	5/27/2021	1st Fl boys Bathroom - Faucet	Faucet	Initial	0.003	7/20/2021	N/A
24	S24779.24	5/27/2021	1st Fl Girls Bathroom - Faucet	Faucet	Initial	<0.001	7/20/2021	N/A
25	S24779.25	5/27/2021	1st Fl Girls Bathroom - Faucet	Faucet	Initial	<0.001	7/20/2021	N/A

**SCHOOL NAME: School #76 315 Carolina Street****55 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
26	S24779.26	5/27/2021	1st Fl Girls Bathroom - Faucet	Faucet	Initial	0.001	7/20/2021	N/A
27	S24779.27	5/27/2021	Rm 120 Red Kitchen - Faucet	Faucet	Initial	0.003	7/20/2021	N/A
28	S24779.28	5/27/2021	Rm 120 Green Kitchen - Faucet	Faucet	Initial	<0.001	7/20/2021	N/A
29	S24779.29	5/27/2021	Rm 120 Blue Kitchen - Faucet	Faucet	Initial	0.001	7/20/2021	N/A
30	S24779.30	5/27/2021	Rm 118 - Faucet	Faucet	Initial	0.004	7/20/2021	N/A
31	S24779.31	5/27/2021	Boiler Rm Bathroom - Faucet	Faucet	Initial	0.001	7/20/2021	N/A
32	S24779.32	5/27/2021	1st Fl faculty Bathroom - Faucet	Faucet	Initial	<0.001	7/20/2021	N/A
33	S24779.33	5/27/2021	Kitchen Bathroom Faucet	Faucet	Initial	0.012	7/20/2021	N/A
34	S24779.34	5/27/2021	Rm 201 Kitchen Hand Sink - Faucet	Faucet	Initial	0.002	7/20/2021	N/A
35	S24779.35	5/27/2021	Rm 201 Kitchen 3 Comp Sink - Faucet	Faucet	Initial	0.002	7/20/2021	N/A
36	S24779.36	5/27/2021	Rm 201 Kitchen 3 Comp Sink - Faucet	Faucet	Initial	0.002	7/20/2021	N/A
37	S24779.37	5/27/2021	Rm 201 Kitchen Center Sink	Faucet	Initial	0.002	7/20/2021	N/A
38	S24779.38	5/27/2021	Rm 200 Café Hand Sink	Faucet	Initial	0.011	7/20/2021	N/A
39	S24779.39	5/27/2021	Rm 209 Faculty Rm - Faucet	Faucet	Initial	<0.001	7/20/2021	N/A
40	S24779.40	5/27/2021	Rm 209 Women's - Faucet	Faucet	Initial	<0.001	7/20/2021	N/A
41	S24779.41	5/27/2021	Rm 209 Men's - Faucet	Faucet	Initial	0.001	7/20/2021	N/A
42	S24779.42	5/27/2021	2nd Fl Boys Bathroom - Faucet	Faucet	Initial	0.002	7/20/2021	N/A
43	S24779.43	5/27/2021	2nd Fl Boys Bathroom - Faucet	Faucet	Initial	0.001	7/20/2021	N/A
44	S24779.44	5/27/2021	2nd Fl Boys Bathroom - Faucet	Faucet	Initial	0.002	7/20/2021	N/A
45	S24779.45	5/27/2021	2nd Fl Girls Bathroom - Faucet	Faucet	Initial	0.004	7/20/2021	N/A
46	S24779.46	5/27/2021	2nd Fl Girls Bathroom - Faucet	Faucet	Initial	0.003	7/20/2021	N/A
47	S24779.47	5/27/2021	2nd Fl Girls Bathroom - Faucet	Faucet	Initial	0.002	7/20/2021	N/A
48	S24779.48	5/27/2021	Rm 300 - Faucet	Faucet	Initial	0.002	7/20/2021	N/A
49	S24779.49	5/27/2021	3rd Fl Boys Bathroom - Faucet	Faucet	Initial	0.003	7/20/2021	N/A
50	S24779.50	5/27/2021	3rd Fl Boys Bathroom - Faucet	Faucet	Initial	<0.001	7/20/2021	N/A

**SCHOOL NAME: School #76 315 Carolina Street****55 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
51	S24779.51	5/27/2021	3rd FI Boys Bathroom - Faucet	Faucet	Initial	0.001	7/20/2021	N/A
52	S24779.52	5/27/2021	3rd FI Girls Bathroom - Faucet	Faucet	Initial	0.002	7/20/2021	N/A
53	S24779.53	5/27/2021	3rd FI Girls Bathroom - Faucet	Faucet	Initial	0.001	7/20/2021	N/A
54	S24779.54	5/27/2021	3rd FI Girls Bathroom - Faucet	Faucet	Initial	0.002	7/20/2021	N/A
55	S24779.55	5/27/2021	3rd FI Faculty Bathroom - Faucet	Faucet	Initial	0.001	7/20/2021	N/A

**SCHOOL NAME: School #76 315 Carolina Street**

**55 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
-----------	----------	------------------------	-----------------	--------------------	--------------------------	------------------	-------------------------	--

**SCHOOL NAME: School #76 315 Carolina Street**

**55 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
-----------	----------	------------------------	-----------------	--------------------	--------------------------	------------------	-------------------------	--

**SCHOOL NAME: School #76 315 Carolina Street**

**55 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
-----------	----------	------------------------	-----------------	--------------------	--------------------------	------------------	-------------------------	--

--