

SCHOOL NAME: School #212 320 Porter Ave
29 Outlets

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L (ppb)	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.15 mg/L
1	S25480.01	6/16/2021	Lower-Level Faculty Bath Faucet Men's	Faucet	Initial	0.014	8/9/2021	N/A
2	S25480.02	6/16/2021	Lower-Level Faculty Bath Faucet Women's	Faucet	Initial	0.006	8/9/2021	N/A
3	S25480.03	6/16/2021	Kitchen Dish Sprayer	Faucet	Initial	0.005	8/9/2021	N/A
4	S25480.04	6/16/2021	Kitchen 2 Bay B2	Faucet	Initial	0.069	8/9/2021	work order to replace
5	S25480.05	6/16/2021	Kitchen 2 Bay B3	Faucet	Initial	0.006	8/9/2021	N/A
6	S25480.06	6/16/2021	Kitchen Hand Wash - Faucet B4	Faucet	Initial	0.007	8/9/2021	N/A
7	S25480.07	6/16/2021	Kitchen Center Sink C	Faucet	Initial	0.007	8/9/2021	N/A
8	S25480.08	6/16/2021	Kitchen Kettle	Kettle	Initial	0.035	8/9/2021	work order to replace
9	S25480.09	6/16/2021	Kitchen Center Sink A	Faucet	Initial	0.108	8/9/2021	work order to replace
10	S25480.10	6/16/2021	Kitchen Hand Wash - Faucet A	Faucet	Initial	<0.001	8/9/2021	N/A
11	S25480.11	6/16/2021	Lower-Level Women's Faucet G	Faucet	Initial	0.001	8/9/2021	N/A
12	S25480.12	6/16/2021	Lower-Level Women's Faucet B1	Faucet	Initial	0.001	8/9/2021	N/A
13	S25480.13	6/16/2021	Lower-Level Fountain	Bottle Filler	Initial	0.001	8/9/2021	N/A
14	S25480.14	6/16/2021	Lower-Level Men's Faucet	Faucet	Initial	0.002	8/9/2021	N/A
15	S25480.15	6/16/2021	Women's Bath - Faucet Nr 102 C1	Faucet	Initial	0.015	8/9/2021	N/A
16	S25480.16	6/16/2021	Women's Bath - Faucet Nr 102 C2	Faucet	Initial	0.008	8/9/2021	N/A
17	S25480.17	6/16/2021	Men's Bath - Faucet Nr 102 A	Faucet	Initial	0.008	8/9/2021	N/A
18	S25480.18	6/16/2021	Principal's Office - Faucet	Faucet	Initial	0.001	8/9/2021	N/A
19	S25480.19	6/16/2021	Fountain Near 2nd FL Men's Bathroom	Bottle Filler	Initial	<0.001	8/9/2021	N/A
20	S25480.20	6/16/2021	Nurse's Office - Faucet	Faucet	Initial	0.002	8/9/2021	N/A
21	S25480.21	6/16/2021	Nurse's Office Bath - Faucet	Faucet	Initial	0.006	8/9/2021	N/A
22	S25480.22	6/16/2021	Fountain Near Gym D1	Bottle Filler	Initial	<0.001	8/9/2021	N/A
23	S25480.23	6/16/2021	Fountain Near Gym D2	Fountain	Initial	<0.001	8/9/2021	N/A
24	S25480.24	6/16/2021	Fountain Near Gym D3	Fountain	Initial	<0.001	8/9/2021	N/A
25	S25480.25	6/16/2021	Women's Locker Rm - Faucet A1	Faucet	Initial	0.164	8/9/2021	SIGNAGE
26	S25480.26	6/16/2021	Women's Locker Rm - Faucet A2	Faucet	Initial	0.011	8/9/2021	N/A
27	S25480.26	6/16/2021	Women's Locker Rm - Faucet A3	Faucet	Initial	0.103	8/9/2021	SIGNAGE
28	S25480.28	6/16/2021	Men's Locker Rm - Faucet B1	Faucet	Initial	0.005	8/9/2021	N/A
29	S25480.29	6/16/2021	Men's Locker Rm - Faucet B2	Faucet	Initial	0.003	8/9/2021	N/A