

SCHOOL NAME:**School #6 414 Division Street****50 Samples**

Sample ID	Lab ID #	Sample collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
1	21P005822	5/22/2021	1st Floor Girls Bathroom 1	Faucet	Initial	<0.0010	7/7/2021	N/A
2	21P005823	5/22/2021	1st Floor Girls Bathroom 2	Faucet	Initial	<0.0010	7/7/2021	N/A
3	21P005824	5/22/2021	1st Floor Girls Bathroom Sink 3	Faucet	Initial	<0.0010	7/7/2021	N/A
4	21P005825	5/22/2021	1st Floor Girls Bathroom Sink 4	Faucet	Initial	<0.0010	7/7/2021	N/A
5	21P005826	5/22/2021	1st Floor New Boys Bathroom Sink 1	Faucet	Initial	<0.0010	7/7/2021	N/A
6	21P005827	5/22/2021	1st Floor New Boys Bathroom Sink 2	Faucet	Initial	<0.0010	7/7/2021	N/A
7	21P005828	5/22/2021	1st Floor New Boys Bathroom Sink 3	Faucet	Initial	<0.0010	7/7/2021	N/A
8	21P005829	5/22/2021	1st Floor Girls Bathroom New Sink 1	Faucet	Initial	<0.0010	7/7/2021	N/A
9	21P005830	5/22/2021	1st Floor Girls Bathroom New Sink 2	Faucet	Initial	<0.0010	7/7/2021	N/A
10	21P005831	5/22/2021	1st Floor Girls Bathroom New Sink 3	Faucet	Initial	<0.0010	7/7/2021	N/A
11	21P005832	5/22/2021	Old Room 113A Boys Bathroom Sink 1	Faucet	Initial	<0.0010	7/7/2021	N/A
12	21P005833	5/22/2021	Old Room 113A Boys Bathroom Sink 2	Faucet	Initial	<0.0010	7/7/2021	N/A
13	21P005834	5/22/2021	Old Room 113A Boys Bathroom Sink 3	Faucet	Initial	<0.0010	7/7/2021	N/A
14	21P005835	5/22/2021	Old Room 113A Boys Bathroom Sink 4	Faucet	Initial	<0.0010	7/7/2021	N/A
15	21P005836	5/22/2021	Old Room 113A Boys Bathroom Sink 5	Faucet	Initial	<0.0010	7/7/2021	N/A
16	21P005837	5/22/2021	102B Faculty Lunch Faucet	Faucet	Initial	<0.0010	7/7/2021	N/A
17	21P005838	5/22/2021	121 Conference Room New Building	Faucet	Initial	<0.0010	7/7/2021	N/A
18	21P005839	5/22/2021	Clinic	Faucet	Initial	<0.0010	7/7/2021	N/A
19	21P005840	5/22/2021	2nd Floor Girls Bathroom Faucet	Faucet	Initial	<0.0010	7/7/2021	N/A
20	21P005841	5/22/2021	New 2nd Floor Boys Bathroom Sink 1	Faucet	Initial	<0.0010	7/7/2021	N/A
21	21P005842	5/22/2021	New 2nd Floor Boys Bathroom Sink 2	Faucet	Initial	<0.0010	7/7/2021	N/A
22	21P005843	5/22/2021	New 2nd Floor Boys Bathroom Sink 3	Faucet	Initial	<0.0010	7/7/2021	N/A
23	21P005844	5/22/2021	Boys Bathroom Faucet Old Sink 1	Faucet	Initial	<0.0010	7/7/2021	N/A
24	21P005845	5/22/2021	Boys Bathroom Faucet Sink 2	Faucet	Initial	<0.0010	7/7/2021	N/A
25	21P005846	5/22/2021	Old Boys Bathroom Faucet Sink 3	Faucet	Initial	<0.0010	7/7/2021	N/A
26	21P005847	5/22/2021	Old Boys Bathroom Faucet Sink 4	Faucet	Initial	<0.0010	7/7/2021	N/A
27	21P005848	5/22/2021	Old Girls Bathroom Faucet Sink 1	Faucet	Initial	<0.0010	7/7/2021	N/A
28	21P005849	5/22/2021	Old Girls Bathroom Faucet Sink 2	Faucet	Initial	<0.0010	7/7/2021	N/A
29	21P005850	5/22/2021	Old Girls Bathroom Faucet Sink 3	Faucet	Initial	<0.0010	7/7/2021	N/A

SCHOOL NAME:**School #6 414 Division Street****50 Samples**

Sample ID	Lab ID #	Sample collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
30	21P005851	5/22/2021	Girls Bathroom Faucet Old Sink 4	Faucet	Initial	<0.0010	7/7/2021	N/A
31	21P005852	5/22/2021	Rm 226 2nd Floor Faculty Faucet	Faucet	Initial	<0.0010	7/7/2021	N/A
32	21P005853	5/22/2021	Rm 229 Faucet	Faucet	Initial	<0.0010	7/7/2021	N/A
33	21P005854	5/22/2021	Room 233 Faucet	Faucet	Initial	<0.0010	7/7/2021	N/A
34	21P005855	5/22/2021	Room 236 Faucet	Faucet	Initial	<0.0010	7/7/2021	N/A
35	21P005856	5/22/2021	Room 237 Faucet	Faucet	Initial	<0.0010	7/7/2021	N/A
36	21P005857	5/22/2021	Old 3rd Floor Boys Bathroom Sink 1	Faucet	Initial	<0.0010	7/7/2021	N/A
37	21P005858	5/22/2021	Old 3rd Floor Boys Bathroom Sink 2	Faucet	Initial	<0.0010	7/7/2021	N/A
38	21P005859	5/22/2021	Old 3rd Floor Boys Bathroom Sink 3	Faucet	Initial	<0.0010	7/7/2021	N/A
39	21P005860	5/22/2021	Old 3rd Floor Boys Bathroom Sink 4	Faucet	Initial	<0.0010	7/7/2021	N/A
40	21P005861	5/22/2021	Old 3rd Floor Boys Bathroom Sink 5	Faucet	Initial	<0.0010	7/7/2021	N/A
41	21P005862	5/22/2021	Old Girls Bathroom 3rd Floor Faucet Sink 1	Faucet	Initial	<0.0010	7/7/2021	N/A
42	21P005863	5/22/2021	Old Girls Bathroom 3rd Floor Faucet Sink 2	Faucet	Initial	<0.0010	7/7/2021	N/A
43	21P005864	5/22/2021	Old Girls Bathroom 3rd Floor Faucet Sink 3	Faucet	Initial	<0.0010	7/7/2021	N/A
44	21P005865	5/22/2021	Old Girls Bathroom 3rd Floor Faucet Sink 4	Faucet	Initial	<0.0010	7/7/2021	N/A
45	21P005866	5/22/2021	Room 308 Faucet	Faucet	Initial	<0.0010	7/7/2021	N/A
46	21P005867	5/22/2021	Custodial Break Room Faucet	Faucet	Initial	<0.0010	7/7/2021	N/A
47	21P005868	5/22/2021	Kitchen Dishwasher Sink Right	Faucet	Initial	<0.0010	7/7/2021	N/A
48	21P005869	5/22/2021	Kitchen Dishwasher Sink Left	Faucet	Initial	<0.0010	7/7/2021	N/A
49	21P005870	5/22/2021	Kitchen Veggie Washing Sink 1	Faucet	Initial	<0.0010	7/7/2021	N/A
50	21P005871	5/22/2021	Kitchen Veggie Washing Sink 2	Faucet	Initial	<0.0010	7/7/2021	N/A