

SCHOOL NAME: School #17 1045 W. Delavan 63 Outlets

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
1	21P004997	5/13/2021	Café Sink #1	Faucet	Initial	0.0181	6/11/2021	SIGNAGE
2	21P004998	5/13/2021	Kitchen Hand Sink #1	Faucet	Initial	0.0022	6/11/2021	N/A
3	21P004999	5/13/2021	Kitchen Hand Sink #2	Faucet	Initial	<0.0010	6/11/2021	N/A
4	21P005000	5/13/2021	Kitchen Wash Sink #2	Faucet	Initial	<0.0010	6/11/2021	N/A
5	21P005001	5/13/2021	Kitchen Hand Sink #3	Faucet	Initial	0.0016	6/11/2021	N/A
6	21P005002	5/13/2021	Kitchen Wash Sink #1	Faucet	Initial	<0.0010	6/11/2021	N/A
7	21P005003	5/13/2021	Kitchen Wash Sink #3	Faucet	Initial	<0.0010	6/11/2021	N/A
8	21P005004	5/13/2021	Fountain in Café	Fountain	Initial	<0.0010	6/11/2021	N/A
9	21P005005	5/13/2021	240 Sink	Faucet	Initial	<0.0010	6/11/2021	N/A
10	21P005006	5/13/2021	241 Sink	Faucet	Initial	<0.0010	6/11/2021	N/A
11	21P005007	5/13/2021	242 Sink	Faucet	Initial	0.0025	6/11/2021	N/A
12	21P005008	5/13/2021	244 Sink	Faucet	Initial	<0.0010	6/11/2021	N/A
13	21P005009	5/13/2021	2R Boys Bathroom Sink #2	Faucet	Initial	0.0024	6/11/2021	N/A
14	21P005010	5/13/2021	2nd Floor Boys Sink #1	Faucet	Initial	<0.0010	6/11/2021	N/A
15	21P005011	5/13/2021	2nd Floor Boys Sink #2	Faucet	Initial	<0.0010	6/11/2021	N/A
16	21P005012	5/13/2021	2nd Floor Girls Sink #1	Faucet	Initial	<0.0010	6/11/2021	N/A
17	21P005013	5/13/2021	223 Sink	Faucet	Initial	0.0114	6/11/2021	N/A
18	21P005014	5/13/2021	225 Sink	Faucet	Initial	0.0033	6/11/2021	N/A
19	21P005015	5/13/2021	226 Mens B-Room Sink	Faucet	Initial	<0.0010	6/11/2021	N/A
20	21P005016	5/13/2021	226 Sink	Faucet	Initial	0.0074	6/11/2021	N/A
21	21P005017	5/13/2021	227 Sink	Faucet	Initial	0.0034	6/11/2021	N/A

SCHOOL NAME: School #17 1045 W. Delavan 63 Outlets

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
22	21P005018	5/13/2021	Fountain Outside 229	Fountain	Initial	<0.0010	6/11/2021	N/A
23	21P005019	5/13/2021	229 Sink	Faucet	Initial	0.0062	6/11/2021	N/A
24	21P005020	5/13/2021	228 Sink	Faucet	Initial	0.005	6/11/2021	N/A
25	21P005021	5/13/2021	231 Sink	Faucet	Initial	0.0028	6/11/2021	N/A
26	21P005022	5/13/2021	1R Boys Sink #1	Faucet	Initial	0.0015	6/11/2021	N/A
27	21P005023	5/13/2021	1R Girls Sink #1	Faucet	Initial	<0.0010	6/11/2021	N/A
28	21P005024	5/13/2021	1R Girls Sink #4	Faucet	Initial	<0.0010	6/11/2021	N/A
29	21P005025	5/13/2021	226 Womens B-Rooms	Faucet	Initial	0.0021	6/11/2021	N/A
30	21P005026	5/13/2021	128 Sink	Faucet	Initial	0.001	6/11/2021	N/A
31	21P005027	5/13/2021	128 Fountain	Fountain	Initial	0.002	6/11/2021	N/A
32	21P005028	5/13/2021	126 Sink	Faucet	Initial	0.0023	6/11/2021	N/A
33	21P005029	5/13/2021	126 Fountain	Fountain	Initial	0.0024	6/11/2021	N/A
34	21P005030	5/13/2021	124 Sink	Faucet	Initial	0.0017	6/11/2021	N/A
35	21P005031	5/13/2021	124 Fountain	Fountain	Initial	0.0029	6/11/2021	N/A
36	21P005032	5/13/2021	122 Sink	Faucet	Initial	0.0024	6/11/2021	N/A
37	21P005033	5/13/2021	122 Fountain	Fountain	Initial	0.0011	6/11/2021	N/A
38	21P005034	5/13/2021	121 Sink	Faucet	Initial	0.0025	6/11/2021	N/A
39	21P005035	5/13/2021	121 Fountain	Fountain	Initial	0.0015	6/11/2021	N/A
40	21P005036	5/13/2021	120	Faucet	Initial	0.0021	6/11/2021	N/A
41	21P005037	5/13/2021	120 Fountain	Fountain	Initial	<0.0010	6/11/2021	N/A
42	21P005038	5/13/2021	135 Sink	Faucet	Initial	0.0031	6/11/2021	N/A

SCHOOL NAME: School #17 1045 W. Delavan 63 Outlets

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
43	21P005039	5/13/2021	135 Fountain	Fountain	Initial	0.0022	6/11/2021	N/A
44	21P005040	5/13/2021	134 Sink	Faucet	Initial	0.0027	6/11/2021	N/A
45	21P005041	5/13/2021	132 Sink	Faucet	Initial	0.0039	6/11/2021	N/A
46	21P005042	5/13/2021	130 Sink	Faucet	Initial	0.0251	6/11/2021	SIGNAGE
47	21P005043	5/13/2021	130 Mens B-Room Sink	Faucet	Initial	<0.0010	6/11/2021	N/A
48	21P005044	5/13/2021	130 Womens B-Room Sink	Faucet	Initial	<0.0010	6/11/2021	N/A
49	21P005045	5/13/2021	136 Sink	Faucet	Initial	0.0019	6/11/2021	N/A
50	21P005046	5/13/2021	131 Sink	Faucet	Initial	0.0071	6/11/2021	N/A
51	21P005047	5/13/2021	103 Sink	Faucet	Initial	<0.0010	6/11/2021	N/A
52	21P005048	5/13/2021	103 Womens B-Room Sink	Faucet	Initial	<0.0010	6/11/2021	N/A
53	21P005049	5/13/2021	103 Mens B-Room Sink	Faucet	Initial	0.0044	6/11/2021	N/A
54	21P005050	5/13/2021	1st Floor Girls Sink #1	Faucet	Initial	0.0028	6/11/2021	N/A
55	21P005051	5/13/2021	1st Floor Boys Sink	Faucet	Initial	0.0011	6/11/2021	N/A
56	21P005052	5/13/2021	Main Office Bathroom 100	Faucet	Initial	<0.0010	6/11/2021	N/A
57	21P005053	5/13/2021	Principal B-Room Sink 100	Faucet	Initial	<0.0010	6/11/2021	N/A
58	21P005054	5/13/2021	100 I Sink	Faucet	Initial	<0.0010	6/11/2021	N/A
59	21P005055	5/13/2021	123 Fountain	Fountain	Initial	0.0017	6/11/2021	N/A
60	21P005056	5/13/2021	126 Sink (123)	Faucet	Initial	0.0018	6/11/2021	N/A
61	21P005057	5/13/2021	100 I Restroom	Faucet	Initial	<0.0010	6/11/2021	N/A
62	21P005058	5/13/2021	Boiler Room Breakroom	Faucet	Initial	0.002	6/11/2021	N/A
63	21P005059	5/13/2021	Boiler Room Bathroom	Faucet	Initial	<0.0010	6/11/2021	N/A