

SCHOOL NAME: School 33 Bilingual Center 157 Elk Street 52 outlets

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
1	S23751.01	4/29/2021	Boiler Rm	Faucet	Initial	0.019	5/13/2021	SIGNAGE
2	S23751.02	4/29/2021	Faculty Lavatory at Rm 138	Faucet	Initial	<0.001	5/13/2021	N/A
3	S23751.03	4/29/2021	Kitchen by Warmer	Faucet	Initial	0.002	5/13/2021	N/A
4	S23751.04	4/29/2021	Kitchen by Warmer	Faucet	Initial	0.002	5/13/2021	N/A
5	S23751.05	4/29/2021	Kitchen Southeast Wall	Faucet	Initial	<0.001	5/13/2021	N/A
6	S23751.06	4/29/2021	Kitchen Southeast Wall	Faucet	Initial	0.002	5/13/2021	N/A
7	S23751.07	4/29/2021	Kitchen Lavatory	Faucet	Initial	<0.001	5/13/2021	N/A
8	S23751.08	4/29/2021	Kitchen Center	Faucet	Initial	0.003	5/13/2021	N/A
9	S23751.09	4/29/2021	Kitchen	Faucet	Initial	0.003	5/13/2021	N/A
10	S23751.10	4/29/2021	Bottle Filler next to Rm 102	Bottle Filler	Initial	<0.001	5/13/2021	N/A
11	S23751.11	4/29/2021	Rm 102	Faucet	Initial	<0.001	5/13/2021	N/A
12	S23751.12	4/29/2021	Rm 101	Faucet	Initial	<0.001	5/13/2021	N/A
13	S23751.13	4/29/2021	Rm 101 Bubbler	Fountain	Initial	<0.001	5/13/2021	N/A
14	S23751.14	4/29/2021	Rm 103 Bottle Filler	Bottle Filler	Initial	<0.001	5/13/2021	N/A
15	S23751.15	4/29/2021	Rm 103	Faucet	Initial	<0.001	5/13/2021	N/A
16	S23751.16	4/29/2021	Rm 104 Bottle Filler	Bottle Filler	Initial	<0.001	5/13/2021	N/A
17	S23751.17	4/29/2021	Rm 104 Faucet	Faucet	Initial	0.001	5/13/2021	N/A
18	S23751.18	4/29/2021	Rm 106 Bottle Filler	Bottle Filler	Initial	<0.001	5/13/2021	N/A
19	S23751.19	4/29/2021	Rm 106 Faucet	Faucet	Initial	<0.001	5/13/2021	N/A
20	S23751.20	4/29/2021	Rm 105C Principal	Faucet	Initial	0.002	5/13/2021	N/A
21	S23751.21	4/29/2021	Rm 105C Principals Hallway	Bottle Filler	Initial	<0.001	5/13/2021	N/A
22	S23751.22	4/29/2021	Rm 105C Principals Hallway	Faucet	Initial	<0.001	5/13/2021	N/A

SCHOOL NAME: School 33 Bilingual Center 157 Elk Street 52 outlets

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
23	S23751.23	4/29/2021	Rm 105 C Faculty Bathroom	Faucet	Initial	<0.001	5/13/2021	N/A
24	S23751.24	4/29/2021	Rm 108 Bottle Filler	Bottle Filler	Initial	<0.001	5/13/2021	N/A
25	S23751.25	4/29/2021	Rm 108 Faucet	Faucet	Initial	<0.001	5/13/2021	N/A
26	S23751.26	4/29/2021	Rm 114 B	Fountain	Initial	<0.001	5/13/2021	N/A
27	S23751.27	4/29/2021	Rm 114 B	Faucet	Initial	0.002	5/13/2021	N/A
28	S23751.28	4/29/2021	Rm 114 B Lavatory	Faucet	Initial	<0.001	5/13/2021	N/A
29	S23751.29	4/29/2021	Rm 112 Faucet	Faucet	Initial	<0.001	5/13/2021	N/A
30	S23751.30	4/29/2021	Rm 107	Faucet	Initial	<0.001	5/13/2021	N/A
31	S23751.31	4/29/2021	Rm 122	Faucet	Initial	<0.001	5/13/2021	N/A
32	S23751.32	4/29/2021	Rm 122	Faucet	Initial	<0.001	5/13/2021	N/A
33	S23751.33	4/29/2021	Rm 122	Faucet	Initial	<0.001	5/13/2021	N/A
34	S23751.34	4/29/2021	Rm 124	Faucet	Initial	0.004	5/13/2021	N/A
35	S23751.35	4/29/2021	Rm 124	Faucet	Initial	<0.001	5/13/2021	N/A
36	S23751.36	4/29/2021	Rm 124	Faucet	Initial	<0.001	5/13/2021	N/A
37	S23751.37	4/29/2021	Rm 124	Faucet	Initial	0.001	5/13/2021	N/A
38	S23751.38	4/29/2021	Rm 126	Faucet	Initial	<0.001	5/13/2021	N/A
39	S23751.39	4/29/2021	Rm 126	Faucet	Initial	<0.001	5/13/2021	N/A
40	S23751.40	4/29/2021	Rm 109 Office Lavatory	Faucet	Initial	0.002	5/13/2021	N/A
41	S23751.41	4/29/2021	Womens Faculty	Faucet	Initial	<0.001	5/13/2021	N/A
42	S23751.42	4/29/2021	Rm 205	Faucet	Initial	<0.001	5/13/2021	N/A
43	S23751.43	4/29/2021	Rm 205 Fountain	Fountain	Initial	<0.001	5/13/2021	N/A
44	S23751.44	4/29/2021	Faculty Bathroom 2 next 213	Faucet	Initial	<0.001	5/13/2021	N/A

SCHOOL NAME: School 33 Bilingual Center 157 Elk Street **52 outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
45	S23751.45	4/29/2021	Faculty Bathroom 2 next 211	Faucet	Initial	<0.001	5/13/2021	N/A
46	S23751.46	4/29/2021	215	Faucet	Initial	<0.001	5/13/2021	N/A
47	S23751.47	4/29/2021	232 Teacher Office	Faucet	Initial	0.002	5/13/2021	N/A
48	S23751.48	4/29/2021	Drinking Fountain next to 232	Fountain	Initial	<0.001	5/13/2021	N/A
49	S23751.49	4/29/2021	238	Faucet	Initial	<0.001	5/13/2021	N/A
50	S23751.50	4/29/2021	238 Lavatory	Faucet	Initial	<0.001	5/13/2021	N/A
51	S23751.51	4/29/2021	3rd FI Restroom	Faucet	Initial	<0.001	5/13/2021	N/A
52	S23751.52	4/29/2021	Library Lavatory	Faucet	Initial	<0.001	5/13/2021	N/A