

SCHOOL NAME: School #37 295 Carlton Street**68 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
1	S23935.01	5/5/2021	Fountain Across from B16	Fountain	Initial	<0.001	5/28/2021	N/A
2	S23935.02	5/5/2021	Room B19 - Fountain	Fountain	Initial	0.001	5/28/2021	N/A
3	S23935.03	5/5/2021	Room B19 - Faucet	Faucet	Initial	0.027	5/28/2021	SIGNAGE
4	S23935.04	5/5/2021	Room B20 - Faucet	Faucet	Initial	0.015	5/28/2021	N/A
5	S23935.05	5/5/2021	Room B20 - Faucet	Faucet	Initial	0.018	5/28/2021	SIGNAGE
6	S23935.06	5/5/2021	Room B20 - Faucet	Faucet	Initial	0.013	5/28/2021	N/A
7	S23935.07	5/5/2021	Room B20 - Faucet	Faucet	Initial	0.010	5/28/2021	N/A
8	S23935.08	5/5/2021	Room B20 - Faucet	Faucet	Initial	0.017	5/28/2021	SIGNAGE
9	S23935.09	5/5/2021	Room B20 - Faucet	Faucet	Initial	0.011	5/28/2021	N/A
10	S23935.10	5/5/2021	Room B15 - Faucet	Faucet	Initial	<0.001	5/28/2021	N/A
11	S23935.11	5/5/2021	Room B11 - Kitchen Faucet	Faucet	Initial	0.002	5/28/2021	N/A
12	S23935.12	5/5/2021	Room B11 - Kitchen Faucet	Faucet	Initial	0.002	5/28/2021	N/A
13	S23935.13	5/5/2021	Room B11 - Kitchen Faucet	Faucet	Initial	0.009	5/28/2021	N/A
14	S23935.14	5/5/2021	Room B11 - Kitchen Faucet	Faucet	Initial	<0.001	5/28/2021	N/A
15	S23935.15	5/5/2021	Room B11 - Kitchen Faucet	Faucet	Initial	0.001	5/28/2021	N/A
16	S23935.16	5/5/2021	Room B11 - Kitchen Faucet	Faucet	Initial	<0.001	5/28/2021	N/A
17	S23935.17	5/5/2021	Café B Fountain	Fountain	Initial	0.002	5/28/2021	N/A
18	S23935.18	5/5/2021	Room B02	Faucet	Initial	<0.001	5/28/2021	N/A
19	S23935.19	5/5/2021	Basement - Faculty Basement Faucet	Faucet	Initial	0.003	5/28/2021	N/A
20	S23935.20	5/5/2021	Room B28 - Faucet	Faucet	Initial	0.003	5/28/2021	N/A
21	S23935.21	5/5/2021	Room B28 - Fountain	Fountain	Initial	<0.001	5/28/2021	N/A
22	S23935.22	5/5/2021	Room B28 - Faucet	Faucet	Initial	0.003	5/28/2021	N/A
23	S23935.23	5/5/2021	Room 104 - Drinking Fountain	Fountain	Initial	<0.001	5/28/2021	N/A

SCHOOL NAME: School #37 295 Carlton Street**68 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
24	S23935.24	5/5/2021	Room 104 - Faucet	Faucet	Initial	<0.001	5/28/2021	N/A
25	S23935.25	5/5/2021	Room 104 Bathroom - Faucet	Faucet	Initial	<0.001	5/28/2021	N/A
26	S23935.26	5/5/2021	Across from Room 104	Faucet	Initial	<0.001	5/28/2021	N/A
27	S23935.27	5/5/2021	Room 109 - Faucet	Faucet	Initial	<0.001	5/28/2021	N/A
28	S23935.28	5/5/2021	Room 109 - Fountain	Fountain	Initial	<0.001	5/28/2021	N/A
29	S23935.29	5/5/2021	Room 111 - Faucet	Faucet	Initial	0.001	5/28/2021	N/A
30	S23935.30	5/5/2021	Room 111 - Fountain	Fountain	Initial	<0.001	5/28/2021	N/A
31	S23935.31	5/5/2021	Room 111 - Faucet - Bathroom	Faucet	Initial	0.007	5/28/2021	N/A
32	S23935.32	5/5/2021	Room 108 - Faucet	Faucet	Initial	<0.001	5/28/2021	N/A
33	S23935.33	5/5/2021	Room 108 - Fountain	Fountain	Initial	<0.001	5/28/2021	N/A
34	S23935.34	5/5/2021	Room 108 - Bathroom Faucet	Faucet	Initial	<0.001	5/28/2021	N/A
35	S23935.35	5/5/2021	Room 110 - Faucet	Faucet	Initial	<0.001	5/28/2021	N/A
36	S23935.36	5/5/2021	Room 110 - Fountain	Fountain	Initial	<0.001	5/28/2021	N/A
37	S23935.37	5/5/2021	Room 116 - Faucet	Faucet	Initial	<0.001	5/28/2021	N/A
38	S23935.38	5/5/2021	Room 116 - Fountain	Fountain	Initial	<0.001	5/28/2021	N/A
39	S23935.39	5/5/2021	Room 116 - Bathroom Faucet	Faucet	Initial	0.010	5/28/2021	N/A
40	S23935.40	5/5/2021	Room 117 - Faucet	Faucet	Initial	<0.001	5/28/2021	N/A
41	S23935.41	5/5/2021	Room 117 - Fountain	Fountain	Initial	<0.001	5/28/2021	N/A
42	S23935.42	5/5/2021	Room 118 - Faucet	Faucet	Initial	<0.001	5/28/2021	N/A
43	S23935.43	5/5/2021	Room 118 - Fountain	Fountain	Initial	<0.001	5/28/2021	N/A
44	S23935.44	5/5/2021	Across from Room 121	Faucet	Initial	<0.001	5/28/2021	N/A
45	S23935.45	5/5/2021	Main Office Bathroom - Faucet	Faucet	Initial	<0.001	5/28/2021	N/A
46	S23935.46	5/5/2021	Nurse Office Bathroom - Faucet	Faucet	Initial	0.001	5/28/2021	N/A

