

SCHOOL NAME: School #43 161 Benzinger St.**75 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
1	21P004906	5/10/2021	Rm 320 1	Faucet	Initial	0.0012	6/11/2021	N/A
2	21P004907	5/10/2021	Rm 320 2	Faucet	Initial	0.0052	6/11/2021	N/A
3	21P004908	5/10/2021	Rm 320 3	Faucet	Initial	0.0021	6/11/2021	N/A
4	21P004909	5/10/2021	Water Fountain by 301 1	Fountain	Initial	<0.0010	6/11/2021	N/A
5	21P004910	5/10/2021	Water Fountain by 301 2	Fountain	Initial	<0.0010	6/11/2021	N/A
6	21P004911	5/10/2021	Water Fountain by 312	Faucet	Initial	<0.0010	6/11/2021	N/A
7	21P004912	5/10/2021	Rm 314 1	Faucet	Initial	<0.0010	6/11/2021	N/A
8	21P004913	5/10/2021	Rm 314 2	Faucet	Initial	<0.0010	6/11/2021	N/A
9	21P004914	5/10/2021	Rm 314 3	Faucet	Initial	0.003	6/11/2021	N/A
10	21P004915	5/10/2021	Rm 314 4	Faucet	Initial	0.0019	6/11/2021	N/A
11	21P004916	5/10/2021	Rm 314 6	Faucet	Initial	<0.0010	6/11/2021	N/A
12	21P004917	5/10/2021	Rm 326 1	Faucet	Initial	<0.0010	6/11/2021	N/A
13	21P004918	5/10/2021	Rm 326 2	Faucet	Initial	0.0011	6/11/2021	N/A
14	21P004919	5/10/2021	Rm 326 3	Faucet	Initial	<0.0010	6/11/2021	N/A
15	21P004920	5/10/2021	Rm 326 4	Faucet	Initial	0.001	6/11/2021	N/A
16	21P004921	5/10/2021	Rm 326 5	Faucet	Initial	0.0012	6/11/2021	N/A
17	21P004922	5/10/2021	Rm 326 6	Faucet	Initial	<0.0010	6/11/2021	N/A
18	21P004923	5/10/2021	Rm 326 Center	Faucet	Initial	0.0114	6/11/2021	N/A
19	21P004924	5/10/2021	Rm 326 Storage	Faucet	Initial	0.0016	6/11/2021	N/A
20	21P004925	5/10/2021	Rm 324	Faucet	Initial	0.0021	6/11/2021	N/A
21	21P004926	5/10/2021	Water Fountain by Rm 321	Fountain	Initial	<0.0010	6/11/2021	N/A
22	21P004927	5/10/2021	Water Fountain by 224	Fountain	Initial	<0.0010	6/11/2021	N/A
23	21P004928	5/10/2021	223 A	Faucet	Initial	<0.0010	6/11/2021	N/A

SCHOOL NAME: School #43 161 Benzinger St.**75 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
24	21P004929	5/10/2021	Water Fountain by 203 1	Fountain	Initial	<0.0010	6/11/2021	N/A
25	21P004930	5/10/2021	Water Fountain by 203 2	Fountain	Initial	<0.0010	6/11/2021	N/A
26	21P004931	5/10/2021	Water Fountain by 312	Fountain	Initial	<0.0010	6/11/2021	N/A
27	21P004932	5/10/2021	Water Fountain by 226	Fountain	Initial	0.0146	6/11/2021	N/A
28	21P004933	5/10/2021	Rm 226	Faucet	Initial	<0.0010	6/11/2021	N/A
29	21P004934	5/10/2021	Rm 123	Faucet	Initial	<0.0010	6/11/2021	N/A
30	21P004935	5/10/2021	Water Fountain by 123 1	Fountain	Initial	<0.0010	6/11/2021	N/A
31	21P004936	5/10/2021	Water Fountain by 123 2	Fountain	Initial	<0.0010	6/11/2021	N/A
32	21P004937	5/10/2021	121 A	Faucet	Initial	0.0012	6/11/2021	N/A
33	21P004938	5/10/2021	121 B	Faucet	Initial	0.0016	6/11/2021	N/A
34	21P004939	5/10/2021	121 C	Faucet	Initial	<0.0010	6/11/2021	N/A
35	21P004940	5/10/2021	Rm 121 Bathroom	Faucet	Initial	<0.0010	6/11/2021	N/A
36	21P004941	5/10/2021	Rm 121 Bathroom	Faucet	Initial	0.0087	6/11/2021	N/A
37	21P004942	5/10/2021	Rm 120	Faucet	Initial	<0.0010	6/11/2021	N/A
38	21P004943	5/10/2021	Water Fountain by 120	Fountain	Initial	<0.0010	6/11/2021	N/A
39	21P004944	5/10/2021	Water Fountain in Café 1	Fountain	Initial	<0.0010	6/11/2021	N/A
40	21P004945	5/10/2021	Water Fountain in Café 2	Fountain	Initial	<0.0010	6/11/2021	N/A
41	21P004946	5/10/2021	Kitchen by Scrumby Line 1	Faucet	Initial	0.0022	6/11/2021	N/A
42	21P004947	5/10/2021	Kitchen Bay Sinks 2	Faucet	Initial	0.0011	6/11/2021	N/A
43	21P004948	5/10/2021	Kitchen Bay Sinks 3	Faucet	Initial	<0.0010	6/11/2021	N/A
44	21P004949	5/10/2021	Kitchen by Circuit Breaker 4	Faucet	Initial	0.0027	6/11/2021	N/A
45	21P004950	5/10/2021	Kitchen by Circuit Breakers 5	Faucet	Initial	0.0018	6/11/2021	N/A
46	21P004951	5/10/2021	Rm 110	Faucet	Initial	0.0025	6/11/2021	N/A

SCHOOL NAME: School #43 161 Benzinger St. 75 Outlets

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
47	21P004952	5/10/2021	Rm 110 Bathroom	Faucet	Initial	0.0031	6/11/2021	N/A
48	21P004953	5/10/2021	Rm 110 Water Fountain	Fountain	Initial	0.0013	6/11/2021	N/A
49	21P004954	5/10/2021	Rm 108	Faucet	Initial	0.001	6/11/2021	N/A
50	21P004955	5/10/2021	Rm 108 Water Fountain	Fountain	Initial	<0.0010	6/11/2021	N/A
51	21P004956	5/10/2021	Rm 108 Bathroom	Faucet	Initial	<0.0010	6/11/2021	N/A
52	21P004957	5/10/2021	Rm 107	Faucet	Initial	0.0018	6/11/2021	N/A
53	21P004958	5/10/2021	Rm 107 Bathroom	Faucet	Initial	<0.0010	6/11/2021	N/A
54	21P004959	5/10/2021	Rm 107 Water Fountain	Fountain	Initial	<0.0010	6/11/2021	N/A
55	21P004960	5/10/2021	Rm 106	Faucet	Initial	0.0017	6/11/2021	N/A
56	21P004961	5/10/2021	Rm 106 Water Fountain	Fountain	Initial	0.0014	6/11/2021	N/A
57	21P004962	5/10/2021	Rm 106 Bathroom	Faucet	Initial	<0.0010	6/11/2021	N/A
58	21P004963	5/10/2021	Rm 105	Faucet	Initial	0.0066	6/11/2021	N/A
59	21P004964	5/10/2021	Rm 105 Bathroom	Faucet	Initial	<0.0010	6/11/2021	N/A
60	21P004965	5/10/2021	Rm 105 Water Fountain	Fountain	Initial	0.0055	6/11/2021	N/A
61	21P004966	5/10/2021	Rm 104	Faucet	Initial	0.0016	6/11/2021	N/A
62	21P004967	5/10/2021	Rm 104 Water Fountain	Fountain	Initial	<0.0010	6/11/2021	N/A
63	21P004968	5/10/2021	Rm 104 Bathroom	Faucet	Initial	<0.0010	6/11/2021	N/A
64	21P004969	5/10/2021	Rm 103	Faucet	Initial	<0.0010	6/11/2021	N/A
65	21P004970	5/10/2021	Rm 103 Water Fountain	Fountain	Initial	<0.0010	6/11/2021	N/A
66	21P004971	5/10/2021	Rm 103 Bathroom	Faucet	Initial	<0.0010	6/11/2021	N/A
67	21P004972	5/10/2021	Rm 102	Faucet	Initial	0.0018	6/11/2021	N/A
68	21P004973	5/10/2021	Rm 102 Water Fountain	Fountain	Initial	0.0014	6/11/2021	N/A
69	21P004974	5/10/2021	Rm 102 Bathroom	Faucet	Initial	<0.0010	6/11/2021	N/A

SCHOOL NAME: School #43 161 Benzinger St. 75 Outlets

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
70	21P004975	5/10/2021	Rm 113 Bathroom	Faucet	Initial	0.0072	6/11/2021	N/A
71	21P004976	5/10/2021	Faculty Bathroom by Rm 113	Faucet	Initial	<0.0010	6/11/2021	N/A
72	21P004977	5/10/2021	Rm 114 Bathroom	Faucet	Initial	<0.0010	6/11/2021	N/A
73	21P004978	5/10/2021	Water Fountain by Rm 114	Fountain	Initial	<0.0010	6/11/2021	N/A
74	21P004979	5/10/2021	Water Fountain by 102 1	Fountain	Initial	<0.0010	6/11/2021	N/A
75	21P004980	5/10/2021	Water Fountain by 102	Fountain	Initial	<0.0010	6/11/2021	N/A