

SCHOOL NAME: School #54 2358 Main St.**70 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
1	21P005107	5/11/2021	Rm 112 Sink Faucet	Faucet	Initial	<0.0010	6/11/2021	N/A
2	21P005108	5/11/2021	Rm 112 Sink Ceramic	Faucet	Initial	0.0011	6/11/2021	N/A
3	21P005109	5/11/2021	Rm 113 Sink Faucet	Faucet	Initial	<0.0010	6/11/2021	N/A
4	21P005110	5/11/2021	Rm 202 #4	Faucet	Initial	<0.0010	6/11/2021	N/A
5	21P005111	5/11/2021	Rm 114 Sink Faucet	Faucet	Initial	0.0018	6/11/2021	N/A
6	21P005112	5/11/2021	1st FI Mens Bath Sink #1	Faucet	Initial	0.0524	6/11/2021	SIGNAGE
7	21P005113	5/11/2021	1st FI Mens Bath Sink #2	Faucet	Initial	0.0016	6/11/2021	N/A
8	21P005114	5/11/2021	1st FI Girls Gang Sink #1	Faucet	Initial	0.0016	6/11/2021	N/A
9	21P005115	5/11/2021	1st FI Girls Gang Sink #2	Faucet	Initial	0.0015	6/11/2021	N/A
10	21P005116	5/11/2021	1st FI Girls Gang Sink #3	Faucet	Initial	0.0041	6/11/2021	N/A
11	21P005117	5/11/2021	1st FI Boys Gang Sink #1	Faucet	Initial	0.0016	6/11/2021	N/A
12	21P005118	5/11/2021	1st FI Boys Gang Sink #2	Faucet	Initial	0.0029	6/11/2021	N/A
13	21P005119	5/11/2021	Rm 116 Sink Faucet	Faucet	Initial	0.0012	6/11/2021	N/A
14	21P005120	5/11/2021	Rm 118 Sink Faucet	Faucet	Initial	0.0018	6/11/2021	N/A
15	21P005121	5/11/2021	Rm 119 Sink Faucet	Faucet	Initial	<0.0010	6/11/2021	N/A
16	21P005122	5/11/2021	Rm 119 Sink White	Faucet	Initial	<0.0010	6/11/2021	N/A
17	21P005123	5/11/2021	Rm 120 Sink Faucet	Faucet	Initial	<0.0010	6/11/2021	N/A
18	21P005124	5/11/2021	Rm 120 Sink White	Faucet	Initial	0.004	6/11/2021	N/A
19	21P005125	5/11/2021	Rm 123 Sink Faucet	Faucet	Initial	<0.0010	6/11/2021	N/A
20	21P005126	5/11/2021	1st FI Bottle Filler	Bottle Filler	Initial	<0.0010	6/11/2021	N/A
21	21P005127	5/11/2021	Rm 102 Sink Faucet	Faucet	Initial	<0.0010	6/11/2021	N/A
22	21P005128	5/11/2021	Rm 101 Sink Faucet	Faucet	Initial	<0.0010	6/11/2021	N/A
23	21P005129	5/11/2021	Principals Office Sink	Faucet	Initial	<0.0010	6/11/2021	N/A
24	21P005130	5/11/2021	Nurse Office Back Rm Sink Faucet	Faucet	Initial	<0.0010	6/11/2021	N/A

SCHOOL NAME: School #54 2358 Main St.**70 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
25	21P005131	5/11/2021	Nurse Office Sink Faucet	Faucet	Initial	<0.0010	6/11/2021	N/A
26	21P005132	5/11/2021	Nurse Office Bath Sink Faucet	Faucet	Initial	<0.0010	6/11/2021	N/A
27	21P005133	5/11/2021	Boy Gang Front Sink #1	Faucet	Initial	0.0011	6/11/2021	N/A
28	21P005134	5/11/2021	Boy Gang Front Sink #2	Faucet	Initial	0.001	6/11/2021	N/A
29	21P005135	5/11/2021	Girls Bath Front Sink #1	Faucet	Initial	<0.0010	6/11/2021	N/A
30	21P005136	5/11/2021	Girls Gang Front Sink #2	Faucet	Initial	<0.0010	6/11/2021	N/A
31	21P005137	5/11/2021	K1	Faucet	Initial	<0.0010	6/11/2021	N/A
32	21P005138	5/11/2021	Kitchen Fountain	Fountain	Initial	<0.0010	6/11/2021	N/A
33	21P005139	5/11/2021	Locker Room Girls Sink #1	Faucet	Initial	0.0015	6/11/2021	N/A
34	21P005140	5/11/2021	Locker Room Girls Sink #2	Faucet	Initial	<0.0010	6/11/2021	N/A
35	21P005141	5/11/2021	Locker Room Boys Sink #1	Faucet	Initial	<0.0010	6/11/2021	N/A
36	21P005142	5/11/2021	Locker Room Boys Sink #2	Faucet	Initial	0.0011	6/11/2021	N/A
37	21P005143	5/11/2021	Gym Water Fountain	Fountain	Initial	<0.0010	6/11/2021	N/A
38	21P005144	5/11/2021	Café Water Fountain	Fountain	Initial	0.0074	6/11/2021	N/A
39	21P005145	5/11/2021	Rm 221 Sink Faucet	Faucet	Initial	<0.0010	6/11/2021	N/A
40	21P005146	5/11/2021	Rm 220 Sink Faucet	Faucet	Initial	<0.0010	6/11/2021	N/A
41	21P005147	5/11/2021	Rm 222 Sink Faucet	Faucet	Initial	0.0021	6/11/2021	N/A
42	21P005148	5/11/2021	Rm 224 Sink Faucet	Faucet	Initial	<0.0010	6/11/2021	N/A
43	21P005149	5/11/2021	Rm 225 Sink Faucet	Faucet	Initial	<0.0010	6/11/2021	N/A
44	21P005150	5/11/2021	Rm 227 Sink Faucet	Faucet	Initial	<0.0010	6/11/2021	N/A
45	21P005151	5/11/2021	Rm 226 Sink Faucet	Faucet	Initial	0.0011	6/11/2021	N/A
46	21P005152	5/11/2021	Rm 226 Sink Faucet	Faucet	Initial	0.0018	6/11/2021	N/A

SCHOOL NAME: School #54 2358 Main St.**70 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
47	21P005153	5/11/2021	Rm 231 Sink Faucet	Faucet	Initial	<0.0010	6/11/2021	N/A
48	21P005154	5/11/2021	2nd Floor Girls Gang Sink 1	Faucet	Initial	0.0018	6/11/2021	N/A
49	21P005155	5/11/2021	2nd Floor Girls Gang Sink 2	Faucet	Initial	<0.0010	6/11/2021	N/A
50	21P005156	5/11/2021	2nd Floor Girls Gang Sink 3	Faucet	Initial	0.0012	6/11/2021	N/A
51	21P005157	5/11/2021	Rm 201 Sink Faucet	Faucet	Initial	<0.0010	6/11/2021	N/A
52	21P005158	5/11/2021	Rm 200 Sink Faucet	Faucet	Initial	<0.0010	6/11/2021	N/A
53	21P005159	5/11/2021	2nd Floor Boys Gang Sink 1	Faucet	Initial	<0.0010	6/11/2021	N/A
54	21P005160	5/11/2021	2nd Floor Boys Gang Sink 2	Faucet	Initial	<0.0010	6/11/2021	N/A
55	21P005161	5/11/2021	Rm 203 Sink Faucet	Faucet	Initial	<0.0010	6/11/2021	N/A
56	21P005162	5/11/2021	2nd Floor Water Fountain	Fountain	Initial	<0.0010	6/11/2021	N/A
57	21P005163	5/11/2021	Rm 208 Sink Faucet	Faucet	Initial	<0.0010	6/11/2021	N/A
58	21P005164	5/11/2021	Rm 209 Sink Faucet	Faucet	Initial	0.001	6/11/2021	N/A
59	21P005165	5/11/2021	Rm 210	Faucet	Initial	0.0014	6/11/2021	N/A
60	21P005166	5/11/2021	Rm 211 Sink Faucet	Faucet	Initial	0.0017	6/11/2021	N/A
61	21P005167	5/11/2021	2nd Floor Men Bath Sink 1	Faucet	Initial	0.0067	6/11/2021	N/A
62	21P005168	5/11/2021	2nd Floor Mens Bath Sink 2	Faucet	Initial	0.025	6/11/2021	SIGNAGE
63	21P005169	5/11/2021	Faculty Bath Womens Sink 1	Faucet	Initial	0.0059	6/11/2021	N/A
64	21P005170	5/11/2021	2nd Floor Bath Womens Sink 2	Faucet	Initial	0.0023	6/11/2021	N/A
65	21P005171	5/11/2021	Music Room Sink Faucet	Faucet	Initial	0.0022	6/11/2021	N/A
66	21P005172	5/11/2021	Rm 214 Sink Faucet	Faucet	Initial	<0.0010	6/11/2021	N/A
67	21P005173	5/11/2021	Rm 114 Sink White	Faucet	Initial	<0.0010	6/11/2021	N/A
68	21P005174	5/11/2021	1st Floor Fac Bath Womens Sink #1	Faucet	Initial	0.0011	6/11/2021	N/A
69	21P005175	5/11/2021	1st Floor Fac Bath Womens Sink #2	Faucet	Initial	0.0011	6/11/2021	N/A
70	21P005176	5/11/2021	2nd Floor Fac Room Sink Faucet	Faucet	Initial	<0.0010	6/11/2021	N/A