

**SCHOOL NAME:**            **School #59 Dr. Charles R. Drew Science**            **1 Martin Luther King Jr. Park**            **58 outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
A1	S23789.43	4/30/2021	Boys Bathroom, 3rd Floor	Faucet	Initial	<0.001	5/13/2021	N/A
A2	S23789.44	4/30/2021	Boys Bathroom, 3rd Floor	Faucet	Initial	<0.001	5/13/2021	N/A
A3	S23789.45	4/30/2021	Girls Bathroom, 3rd Floor	Faucet	Initial	<0.001	5/13/2021	N/A
A4	S23789.46	4/30/2021	Girls Bathroom, 3rd Floor	Faucet	Initial	<0.001	5/13/2021	N/A
A5	S23789.47	4/30/2021	Mens Room, 3rd Floor	Faucet	Initial	<0.001	5/13/2021	N/A
A6	S23789.48	4/30/2021	Womens Room, 3rd Floor	Faucet	Initial	<0.001	5/13/2021	N/A
A7	S23789.49	4/30/2021	Home and Careers, 3rd Floor Room 304	Faucet	Initial	0.001	5/13/2021	N/A
A8	S23789.50	4/30/2021	Home and Careers, 3rd Floor Room 304	Faucet	Initial	0.002	5/13/2021	N/A
A9	S23789.51	4/30/2021	Home and Careers, 3rd Floor Room 304	Faucet	Initial	0.001	5/13/2021	N/A
A10	S23789.52	4/30/2021	Home and Careers, 3rd Floor Room 304	Faucet	Initial	<0.001	5/13/2021	N/A
A12	S23789.56	4/30/2021	Room 307	Faucet	Initial	0.007	5/13/2021	N/A
A13	S23789.55	4/30/2021	Room 309	Faucet	Initial	0.001	5/13/2021	N/A
A14	S23789.53	4/30/2021	Room 315	Faucet	Initial	<0.001	5/13/2021	N/A
A15	S23789.54	4/30/2021	Room 315	Faucet	Initial	<0.001	5/13/2021	N/A
A16	S23789.57	4/30/2021	Room 316	Faucet	Initial	0.001	5/13/2021	N/A
A17	S23789.58	4/30/2021	Room 316	Faucet	Initial	<0.001	5/13/2021	N/A
A20	S23789.33	4/30/2021	Mens Room, 2nd Floor at Room 216	Faucet	Initial	<0.001	5/13/2021	N/A
A21	S23789.32	4/30/2021	Womens Room, 2nd Floor at Room 216	Faucet	Initial	<0.001	5/13/2021	N/A
A44	S23789.34	4/30/2021	GR b, 2nd Fl	Faucet	Initial	<0.001	5/13/2021	N/A
A45	S23789.35	4/30/2021	GR b, 2nd Fl	Faucet	Initial	<0.001	5/13/2021	N/A
A46	S23789.36	4/30/2021	GR b, 2nd Fl	Faucet	Initial	<0.001	5/13/2021	N/A
A47	S23789.37	4/30/2021	GR b, 2nd Fl	Faucet	Initial	<0.001	5/13/2021	N/A
A48	S23789.38	4/30/2021	BR b, 2nd FL	Faucet	Initial	<0.001	5/13/2021	N/A
A49	S23789.39	4/30/2021	BR b, 2nd FL	Faucet	Initial	<0.001	5/13/2021	N/A

**SCHOOL NAME:**                      **School #59 Dr. Charles R. Drew Science**                      **1 Martin Luther King Jr. Park**                      **58 outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
A50	S23789.40	4/30/2021	BR b, 2nd FL	Faucet	Initial	<0.001	5/13/2021	N/A
A51	S23789.41	4/30/2021	BR b, 2nd FL	Faucet	Initial	<0.001	5/13/2021	N/A
A53	S237389.42	4/30/2021	Hallway	Fountain	Initial	0.003	5/13/2021	N/A
A54	S23789.31	4/30/2021	Room 227	Faucet	Initial	<0.001	5/13/2021	N/A
A55	S23789.30	4/30/2021	111 Bathroom Near 111D	Faucet	Initial	<0.001	5/13/2021	N/A
A56	S23789.29	4/30/2021	111 Bathroom Near 111C	Faucet	Initial	<0.001	5/13/2021	N/A
A57	S23789.28	4/30/2021	Room 111C	Faucet	Initial	<0.001	5/13/2021	N/A
A58	S23789.27	4/30/2021	Room 111D	Faucet	Initial	0.003	5/13/2021	N/A
A59	S23789.26	4/30/2021	Room 111	Faucet	Initial	<0.001	5/13/2021	N/A
A60	S23789.24	4/30/2021	101 Mens Restroom	Faucet	Initial	<0.001	5/13/2021	N/A
A61	S23789.23	4/30/2021	101 Mens Restroom	Faucet	Initial	<0.001	5/13/2021	N/A
A62	S23789.22	4/30/2021	101 Womens Restroom	Faucet	Initial	<0.001	5/13/2021	N/A
A63	S23789.21	4/30/2021	101 Womens Restroom	Faucet	Initial	<0.001	5/13/2021	N/A
A65	S23789.25	4/30/2021	Hallway 1st Fl	Bottle Filler	Initial	0.002	5/13/2021	N/A
A68	S23789.20	4/30/2021	Girls Locker Room	Faucet	Initial	0.010	5/13/2021	N/A
A69	S23789.19	4/30/2021	Girls Locker Room	Faucet	Initial	<0.001	5/13/2021	N/A
A70	S23789.18	4/30/2021	Boys Locker Room	Faucet	Initial	<0.001	5/13/2021	N/A
A71	S23789.17	4/30/2021	Boys Locker Room	Faucet	Initial	0.004	5/13/2021	N/A
A73	S23789.16	4/30/2021	Womens Room Basement Near B01	Faucet	Initial	<0.001	5/13/2021	N/A
A74	S23789.15	4/30/2021	Womens Room Basement Near B01	Faucet	Initial	<0.001	5/13/2021	N/A
A75	S23789.14	4/30/2021	Mens Room Basement Near B01	Faucet	Initial	<0.001	5/13/2021	N/A
A76	S23789.13	4/30/2021	Mens Room Basement Near B01	Faucet	Initial	<0.001	5/13/2021	N/A
A77	S23789.12	4/30/2021	Café Boys Restroom	Faucet	Initial	0.001	5/13/2021	N/A
A78	S23789.11	4/30/2021	Café Boys Restroom	Faucet	Initial	<0.001	5/13/2021	N/A

**SCHOOL NAME:**      **School #59 Dr. Charles R. Drew Science**      **1 Martin Luther King Jr. Park**      **58 outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
A79	S23789.10	4/30/2021	Café Girls Restroom	Faucet	Initial	<0.001	5/13/2021	N/A
A80	S23789.09	4/30/2021	Café Girls Restroom	Faucet	Initial	<0.001	5/13/2021	N/A
A81	S23789.08	4/30/2021	Faculty Womens Restroom B01A	Faucet	Initial	<0.001	5/13/2021	N/A
A82	S23789.07	4/30/2021	Faculty Mens Restroom B01A	Faucet	Initial	<0.001	5/13/2021	N/A
A83	S23789.06	4/30/2021	Kitchen Restroom	Faucet	Initial	<0.001	5/13/2021	N/A
A84	S23789.05	4/30/2021	Kitchen Prep	Faucet	Initial	0.002	5/13/2021	N/A
A85	S23789.04	4/30/2021	Kitchen Hand Wash	Faucet	Initial	<0.001	5/13/2021	N/A
A86	S23789.03	4/30/2021	Kitchen Prep	Faucet	Initial	0.002	5/13/2021	N/A
A87	S23789.02	4/30/2021	Kitchen Prep	Faucet	Initial	0.004	5/13/2021	N/A
A88	S23789.01	4/30/2021	Custodian Rm	Faucet	Initial	<0.001	5/13/2021	N/A