

SCHOOL NAME:**School #65 249 Skillen****57 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
#002389	21P006233	6/3/2021	1st Floor Boys Lav Sink 3	Faucet	Initial	<0.0010	7/7/2021	N/A
#002487	21P006234	6/3/2021	1st Floor Boys Lav Sink #4	Faucet	Initial	0.0012	7/7/2021	N/A
#002470	21P006235	6/3/2021	1st Floor Boys Lav Sink #5	Faucet	Initial	0.001	7/7/2021	N/A
#002466	21P006236	6/3/2021	Room #115 Sink	Faucet	Initial	<0.0010	7/7/2021	N/A
#002386	21P006237	6/3/2021	Room #115 Fountain	Fountain	Initial	<0.0010	7/7/2021	N/A
#002424	21P006238	6/3/2021	1st Floor Girls Lav Sink #1	Faucet	Initial	0.0015	7/7/2021	N/A
#002577	21P006239	6/3/2021	1st Floor Girls Lav Sink #2	Faucet	Initial	0.0014	7/7/2021	N/A
#002370	21P006240	6/3/2021	1st Floor Girls Lav Sink #3	Faucet	Initial	<0.0010	7/7/2021	N/A
#002557	21P006241	6/3/2021	1st Floor Girls Lav Sink #4	Faucet	Initial	<0.0010	7/7/2021	N/A
#002467	21P006242	6/3/2021	1st Floor Girls Lav Sink #5	Faucet	Initial	<0.0010	7/7/2021	N/A
#002552	21P006243	6/3/2021	Room #118 Sink	Faucet	Initial	0.075	7/12/2021	SIGNAGE
#002553	21P006244	6/3/2021	Room #118 Fountain	Fountain	Initial	0.0024	7/7/2021	N/A
#002377	21P006245	6/3/2021	Room #121 Sink	Faucet	Initial	0.0113	7/7/2021	N/A
#002468	21P006246	6/3/2021	Room #121 Fountain	Fountain	Initial	0.0014	7/7/2021	N/A
#002421	21P006197	6/3/2021	Room #200 Faucet	Faucet	Initial	0.0017	7/7/2021	N/A
#002518	21P006198	6/3/2021	2 Floor Boys Lav Sink #1	Faucet	Initial	<0.0010	7/7/2021	N/A
#002423	21P006199	6/3/2021	2 Floor Boys Lav Sink #2	Faucet	Initial	0.0019	7/7/2021	N/A
#002403	21P006200	6/3/2021	2 Floor Boys Sink #3	Faucet	Initial	<0.0010	7/7/2021	N/A
#002501	21P006201	6/3/2021	2 Floor Boys Lav Sink #4	Faucet	Initial	<0.0010	7/7/2021	N/A
#002551	21P006202	6/3/2021	Hallway Fountain by Room #204	Fountain	Initial	<0.0010	7/7/2021	N/A
#002412	21P006203	6/3/2021	Hallway Fountain by Rm #210	Fountain	Initial	<0.0010	7/7/2021	N/A
#002367	21P006204	6/3/2021	2 Floor Girls Lav Sink #1	Faucet	Initial	0.0036	7/7/2021	N/A
#002457	21P006205	6/3/2021	2 Floor Girls Lav Sink #2	Faucet	Initial	<0.0010	7/7/2021	N/A
#002477	21P006206	6/3/2021	2 Floor Girls Lav Sink #3	Faucet	Initial	<0.0010	7/7/2021	N/A

SCHOOL NAME:**School #65 249 Skillen****57 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
#002398	21P006207	6/3/2021	2 Floor Girls Lav Sink #4	Faucet	Initial	0.0011	7/7/2021	N/A
#002415	21P006208	6/3/2021	Room #215 Mens Rm Sink	Faucet	Initial	0.0023	7/7/2021	N/A
#002508	21P006209	6/3/2021	Room #215 Ladies Rm Sink	Faucet	Initial	<0.0010	7/7/2021	N/A
#002373	21P006210	6/3/2021	Fountain in Hallway by Rm #217	Faucet	Initial	<0.0010	7/7/2021	N/A
#002463	21P006211	6/3/2021	Room # Mens Rm by #217/219 Sink	Faucet	Initial	0.0012	7/7/2021	N/A
#002521	21P006212	6/3/2021	Room #219 Ladies Rm Sink	Faucet	Initial	0.004	7/7/2021	N/A
#002390	21P006213	6/3/2021	Main Office Sink Rm #100	Faucet	Initial	0.0013	7/7/2021	N/A
#002471	21P006214	6/3/2021	Room #100 A Principal Office Sink	Faucet	Initial	0.001	7/7/2021	N/A
#002490	21P006215	6/3/2021	Room #101 Conference Room Sink	Faucet	Initial	<0.0010	7/7/2021	N/A
#002554	21P006216	6/3/2021	Room #102 Nurse Bathroom Sink	Faucet	Initial	<0.0010	7/7/2021	N/A
#002549	21P006217	6/3/2021	Room #102 Foot Pedal Sink Nurse	Faucet	Initial	0.0015	7/7/2021	N/A
#002407	21P006218	6/3/2021	Room #102A Nurse Exam Room Sink	Faucet	Initial	<0.0010	7/7/2021	N/A
#002591	21P006219	6/3/2021	Room #103 Art Room Sink (West)	Faucet	Initial	<0.0010	7/7/2021	N/A
#002427	21P006220	6/3/2021	Room #103 Art Room Sink (South)	Faucet	Initial	0.0015	7/7/2021	N/A
#002432	21P006221	6/3/2021	Fountain in Hallway by Rm #103	Faucet	Initial	0.0038	7/7/2021	N/A
#002448	21P006222	6/3/2021	Cafeteria Bathroom Sink Room #105	Faucet	Initial	<0.0010	7/7/2021	N/A
#002542	21P006223	6/3/2021	Room #105 Cafeteria Dish Sink	Faucet	Initial	0.0048	7/7/2021	N/A
#002360	21P006224	6/3/2021	Room #105 Upper Fountain	Fountain	Initial	<0.0010	7/7/2021	N/A
#002476	21P006225	6/3/2021	Room #105 Lower Fountain	Fountain	Initial	<0.0010	7/7/2021	N/A
#002388	21P006226	6/3/2021	Room #106 Faculty Bathroom Sink	Faucet	Initial	<0.0010	7/7/2021	N/A
#002392	21P006227	6/3/2021	Room #106 Faculty Kitchen Sink	Faucet	Initial	<0.0010	7/7/2021	N/A
#002505	21P006228	6/3/2021	Fountain in Hallway by Rm #110	Fountain	Initial	0.0106	7/7/2021	N/A
#002498	21P006229	6/3/2021	Room #114 Sink	Faucet	Initial	0.004	7/7/2021	N/A
#002499	21P006230	6/3/2021	Room #114 Fountain	Fountain	Initial	<0.0010	7/7/2021	N/A

SCHOOL NAME:**School #65 249 Skillen****57 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
#002510	21P006231	6/3/2021	1st Floor Boys Lav Sink #1	Faucet	Initial	<0.0010	7/7/2021	N/A
#002369	21P006232	6/3/2021	1st Floor Boys Lav Sink #2	Faucet	Initial	0.0015	7/7/2021	N/A
#003598	21P006317	6/3/2021	Fountain in Hallway by Room #121	Fountain	Initial	<0.0010	7/7/2021	N/A
#002191	21P006318	6/3/2021	Room 122 Sink	Faucet	Initial	0.0558	7/7/2021	SIGNAGE
#003400	21P006319	6/3/2021	122 Fountain	Fountain	Initial	0.0095	7/7/2021	N/A
#000945	21P006321	6/3/2021	124 Fountain	Fountain	Initial	0.0019	7/7/2021	N/A
#002023	21P006320	6/3/2021	124 Sink	Faucet	Initial	0.0276	7/12/2021	SIGNAGE
#000967	21P006322	6/3/2021	124 Mens Room Sink	Faucet	Initial	<0.0010	7/7/2021	N/A
#000954	21P006323	6/3/2021	124 Ladies Room Sink	Faucet	Initial	0.0014	7/7/2021	N/A