

SCHOOL NAME: School #67 911 Abbott Road**41 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
1	21P005551	5/18/2021	Boiler Rm Sink	Faucet	Initial	0.0012	7/8/2021	N/A
2A	21P005552	5/18/2021	Wood Shop Sink	Faucet	Initial	<0.0010	7/8/2021	N/A
2B	21P005553	5/18/2021	Wood Shop Sink	Faucet	Initial	0.0013	7/8/2021	N/A
3A	21P005554	5/18/2021	Cafeteria Handwashing Sink	Faucet	Initial	<0.0010	7/8/2021	N/A
3B	21P005555	5/18/2021	Cafeteria Kitchen Kettle	Kettle	Initial	0.0023	7/8/2021	N/A
3C	21P005556	5/18/2021	Cafeteria Kitchen Sink Left	Faucet	Initial	<0.0010	7/8/2021	N/A
3D	21P005557	5/18/2021	Cafeteria Kitchen Sink Right	Faucet	Initial	<0.0010	7/8/2021	N/A
4A	21P005558	5/18/2021	Boys Bathroom 1st Floor Left	Faucet	Initial	<0.0010	7/8/2021	N/A
4B	21P005559	5/18/2021	Boys Bathroom 1st Floor Right	Faucet	Initial	<0.0010	7/8/2021	N/A
5A	21P005560	5/18/2021	Girls Bathroom 1st Floor Left	Faucet	Initial	<0.0010	7/8/2021	N/A
5B	21P005561	5/18/2021	Girls Bathroom 1st Floor Right	Faucet	Initial	<0.0010	7/8/2021	N/A
6	21P005562	5/18/2021	First Floor Drinking Fountain	Fountain	Initial	<0.0010	7/8/2021	N/A
7	21P005563	5/18/2021	1st Floor Teachers Bathroom by 104	Faucet	Initial	<0.0010	7/8/2021	N/A
8	21P005564	5/18/2021	1st Floor Teachers Bathroom by Clinic	Faucet	Initial	<0.0010	7/8/2021	N/A
9	21P005565	5/18/2021	Rm 101	Faucet	Initial	<0.0010	7/8/2021	N/A
10A	21P005566	5/18/2021	Rm 108 Left	Faucet	Initial	0.0017	7/8/2021	N/A
10B	21P005567	5/18/2021	Rm 108 Right	Faucet	Initial	<0.0010	7/8/2021	N/A
11	21P005568	5/18/2021	Rm 108 Bathroom	Faucet	Initial	<0.0010	7/8/2021	N/A
12A	21P005569	5/18/2021	Rm 111 Left	Faucet	Initial	<0.0010	7/8/2021	N/A
12B	21P005570	5/18/2021	Rm 111 Right	Faucet	Initial	<0.0010	7/8/2021	N/A
13A	21P005571	5/18/2021	Rm 112 Left	Faucet	Initial	0.0044	7/8/2021	N/A
13B	21P005572	5/18/2021	Rm 112 Right	Faucet	Initial	<0.0010	7/8/2021	N/A
14A	21P005573	5/18/2021	Rm 113 Left	Faucet	Initial	<0.0010	7/8/2021	N/A

SCHOOL NAME: School #67 911 Abbott Road**41 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
14B	21P005574	5/18/2021	Rm 113 Right	Faucet	Initial	<0.0010	7/8/2021	N/A
15	21P005575	5/18/2021	Rm 113 Bathroom	Faucet	Initial	<0.0010	7/8/2021	N/A
16	21P005576	5/18/2021	Rm 117 Bathroom	Faucet	Initial	<0.0010	7/8/2021	N/A
17A	21P005577	5/18/2021	Boys Bathroom 2nd Floor Left	Faucet	Initial	<0.0010	7/8/2021	N/A
17B	21P005578	5/18/2021	Boys Bathroom 2nd Floor Right	Faucet	Initial	<0.0010	7/8/2021	N/A
18	21P005579	5/18/2021	Drinking Fountain by 201	Fountain	Initial	<0.0010	7/8/2021	N/A
20	21P005580	5/18/2021	2nd Floor Teachers Lav	Faucet	Initial	<0.0010	7/8/2021	N/A
21A	21P005581	5/18/2021	2nd Floor Girls Bathroom Left	Faucet	Initial	<0.0010	7/8/2021	N/A
21B	21P005582	5/18/2021	2nd Floor Girls Bathroom Right	Faucet	Initial	<0.0010	7/8/2021	N/A
22	21P005583	5/18/2021	Rm 201	Faucet	Initial	<0.0010	7/8/2021	N/A
23	21P005584	5/18/2021	Rm 204 (Rm 203)	Faucet	Initial	<0.0010	7/8/2021	N/A
24	21P005585	5/18/2021	Rm 204	Faucet	Initial	<0.0010	7/8/2021	N/A
25	21P005586	5/18/2021	Rm 216	Faucet	Initial	0.0031	7/8/2021	N/A
26	21P005587	5/18/2021	Rm 217	Faucet	Initial	<0.0010	7/8/2021	N/A
27	21P005588	5/18/2021	Rm 218	Faucet	Initial	<0.0010	7/8/2021	N/A
28	21P005589	5/18/2021	Library	Faucet	Initial	<0.0010	7/8/2021	N/A
29A	21P005590	5/18/2021	Rm 305 Yellow Kitchen Sink	Faucet	Initial	<0.0010	7/8/2021	N/A
29B	21P005591	5/18/2021	Rm 305 Green Kitchen Sink	Faucet	Initial	<0.0010	7/8/2021	N/A
29C	21P005592	5/18/2021	Rm 305 Red Kitchen Sink	Faucet	Initial	<0.0010	7/8/2021	N/A