

<b>SCHOOL NAME:</b>		<b>Building 307 820 Northampton Street</b>			<b>59 Outlets</b>			
<b>Sample ID</b>	<b>Lab ID #</b>	<b>Sample Collection Date</b>	<b>Sample Location</b>	<b>Outlet Description</b>	<b>Initial/Post Remediation</b>	<b>Lead Result mg/L</b>	<b>Lab Report Receipt Date</b>	<b>Action Taken for Outlets Greater than 0.015 mg/L</b>
1	S24740.01	5/26/2021	Cafeteria Serving Area Faucet C1	Faucet	Initial	0.025	7/16/2021	SIGNAGE
2	S24740.02	5/26/2021	Cafeteria Serving Area Faucet C2	Faucet	Initial	0.002	7/16/2021	N/A
3	S24740.03	5/26/2021	Cafeteria Serving Area Faucet C3	Faucet	Initial	0.007	7/16/2021	N/A
4	S24740.04	5/26/2021	Cafeteria Serving Area Faucet C4	Faucet	Initial	0.004	7/16/2021	N/A
5	S24740.05	5/26/2021	Kitchen 023 Faucet A1	Faucet	Initial	<0.001	7/16/2021	N/A
6	S24740.06	5/26/2021	Kitchen 023 Faucet A2	Faucet	Initial	<0.001	7/16/2021	N/A
7	S24740.07	5/26/2021	Kitchen 023 Faucet A3	Faucet	Initial	0.002	7/16/2021	N/A
8	S24740.08	5/26/2021	Kitchen 023 Faucet C	Faucet	Initial	0.109	7/16/2021	SIGNAGE
9	S24740.09	5/26/2021	Kitchen 023 Faucet Center D	Faucet	Initial	0.002	7/16/2021	N/A
10	S24740.10	5/26/2021	Kitchen 023 Faucet Center B	Faucet	Initial	0.003	7/16/2021	N/A
11	S24740.11	5/26/2021	Kitchen 023 Faucet D1	Faucet	Initial	<0.001	7/16/2021	N/A
12	S24740.12	5/26/2021	Kitchen 023 Faucet D2	Faucet	Initial	<0.001	7/16/2021	N/A
13	S24740.13	5/26/2021	Kitchen 023D Bath D	Faucet	Initial	<0.001	7/16/2021	N/A
14	S24740.14	5/26/2021	Basement 018 Faucet	Faucet	Initial	0.055	7/16/2021	SIGNAGE
15	S24740.15	5/26/2021	Cafeteria - Fountain - Bottle Filler	Bottle Filler	Initial	<0.001	7/16/2021	N/A
16	S24740.16	5/26/2021	Basement 007 Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
17	S24740.17	5/26/2021	Basement Girls Handicap Bathroom by Room 004	Faucet	Initial	<0.001	7/16/2021	N/A
18	S24740.18	5/26/2021	Basement Boys Handicap Bathroom by Room 004	Faucet	Initial	<0.001	7/16/2021	N/A
19	S24740.19	5/26/2021	Basement 01B Faucet	Faucet	Initial	0.002	7/16/2021	N/A
20	S24740.20	5/26/2021	Mezz 009 Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
21	S24740.21	5/26/2021	Fountain by 106 D1	Fountain	Initial	<0.001	7/16/2021	N/A
22	S24740.22	5/26/2021	Fountain by 106 D2	Fountain	Initial	<0.001	7/16/2021	N/A
23	S24740.23	5/26/2021	Mezz 013 Faucet	Faucet	Initial	0.001	7/16/2021	N/A
24	S24740.24	5/26/2021	Mezz 014 Faucet	Faucet	Initial	0.010	7/16/2021	N/A
25	S24740.25	5/26/2021	Mezz Girls Locker Fountain	Fountain	Initial	<0.001	7/16/2021	N/A
26	S24740.26	5/26/2021	Rm 029 Bath Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
27	S24740.27	5/26/2021	1st Fl - Boys Locker Room - Fountain	Fountain	Initial	<0.001	7/16/2021	N/A

SCHOOL NAME:			Building 307 820 Northampton Street			59 Outlets		
Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
28	S24740.28	5/26/2021	Rm 108 Faucet B	Faucet	Initial	0.005	7/16/2021	N/A
29	S24740.29	5/26/2021	Rm 108 Faucet D	Faucet	Initial	0.004	7/16/2021	N/A
30	S24740.30	5/26/2021	Rm 112 Storage Faucet	Faucet	Initial	0.001	7/16/2021	N/A
31	S24740.31	5/26/2021	Rm 116 Faucet B	Faucet	Initial	0.002	7/16/2021	N/A
32	S24740.32	5/26/2021	Rm 116 Faucet D1	Faucet	Initial	0.108	7/16/2021	SIGNAGE
33	S24740.33	5/26/2021	Rm 116 Faucet D2	Faucet	Initial	0.010	7/16/2021	N/A
34	S24740.34	5/26/2021	Rm 116 Faucet A	Faucet	Initial	0.091	7/16/2021	SIGNAGE
35	S24740.35	5/26/2021	Rm 118 Bathroom Faucet	Faucet	Initial	0.004	7/16/2021	N/A
36	S24740.36	5/26/2021	Rm 118 Storage	Faucet	Initial	0.003	7/16/2021	N/A
37	S24740.37	5/26/2021	Rm. 119 Womens Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
38	S24740.38	5/26/2021	Rm 119 Mens Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
39	S24740.39	5/26/2021	Rm 121A Faucet	Faucet	Initial	0.005	7/16/2021	N/A
40	S24740.40	5/26/2021	Rm 101 Faucet	Faucet	Initial	0.005	7/16/2021	N/A
41	S24740.41	5/26/2021	Rm 101 - Bathroom Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
42	S24740.42	5/26/2021	Rm 101A Bathroom Faucet	Faucet	Initial	0.002	7/16/2021	N/A
43	S24740.43	5/26/2021	Rm 105 - Bathroom Faucet Left	Faucet	Initial	<0.001	7/16/2021	N/A
44	S24740.44	5/26/2021	Rm 105 - Bathroom Faucet Right	Faucet	Initial	0.002	7/16/2021	N/A
45	S24740.45	5/26/2021	Rm 105A Faucet	Faucet	Initial	0.005	7/16/2021	N/A
46	S24740.46	5/26/2021	Rm 105B Faucet	Faucet	Initial	0.004	7/16/2021	N/A
47	S24740.47	5/26/2021	Rm 105C Faucet	Faucet	Initial	0.004	7/16/2021	N/A
48	S24740.48	5/26/2021	2nd Fl Fountain by 209 - Bottle Filler	Bottle Filler	Initial	<0.001	7/16/2021	N/A
49	S24740.49	5/26/2021	Rm 214 Mens Bathroom Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
50	S24740.50	5/26/2021	Rm 214 Womens Bathroom Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
51	S24740.51	5/26/2021	Rm 221 - Bathroom Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
52	S24740.52	5/26/2021	Rm 225 Faucet	Faucet	Initial	0.004	7/16/2021	N/A
53	S24740.53	5/26/2021	Rm 225 - Storage Faucet	Faucet	Initial	0.022	7/16/2021	SIGNAGE
54	S24740.54	5/26/2021	3rd Floor Hall Outside 310 Fountain	Fountain	Initial	<0.001	7/16/2021	N/A

**SCHOOL NAME: Building 307 820 Northampton Street****59 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
55	S24740.55	5/26/2021	3rd Floor Hall Outside 310 Fountain	Fountain	Initial	0.001	7/16/2021	N/A
56	S24740.56	5/26/2021	Rm 316 Womens Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
57	S24740.57	5/26/2021	Rm 316 Mens Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
58	S24740.58	5/26/2021	Rm 321 - Bathroom Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
59	S24740.59	5/26/2021	Boiler Room Bathroom Faucet	Faucet	Initial	0.002	7/16/2021	N/A