

SCHOOL NAME: School #79 225 Lawn Avenue								77 outlets
Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
1	21P003670	4/14/2021	Café Handsink Managers Office	Faucet	Initial	<.0010	4/20/2021	N/A
2	21P003671	4/14/2021	Café Sink #1	Faucet	Initial	<.0010	4/20/2021	N/A
3	21P003672	4/14/2021	Café Sink #2	Faucet	Initial	<.0010	4/20/2021	N/A
4	21P003673	4/14/2021	Café Sink #3	Faucet	Initial	<.0010	4/20/2021	N/A
5	21P003674	4/14/2021	Café Sink Near Mixer	Faucet	Initial	<.0010	4/20/2021	N/A
6	21P003675	4/14/2021	Café Hand Sink Near Kettles	Faucet	Initial	0.0016	4/20/2021	N/A
7	21P003676	4/14/2021	Kettle Right	Kettle	Initial	<.0010	4/20/2021	N/A
8	21P003677	4/14/2021	Café Kettle Left	Kettle	Initial	<.0010	4/20/2021	N/A
9	21P003678	4/14/2021	Café Hand Sink Rear	Faucet	Initial	<.0010	4/20/2021	N/A
10	21P003679	4/14/2021	Café Hand Sink Breakfast Prep	Faucet	Initial	<.0010	4/20/2021	N/A
11	21P003680	4/14/2021	Café Hand Sink Ovens	Faucet	Initial	<.0010	4/20/2021	N/A
12	21P003681	4/14/2021	Teacher Café	Faucet	Initial	<.0010	4/20/2021	N/A
13	21P003682	4/14/2021	Kitchen Sink A101/103	Faucet	Initial	<.0010	4/20/2021	N/A
14	21P003683	4/14/2021	A101/103 Bubbler	Fountain	Initial	<.0010	4/20/2021	N/A
15	21P003703	4/14/2021	A102 Kitchen Sink	Faucet	Initial	<.0010	4/20/2021	N/A
16	21P003701	4/14/2021	A102 Bubbler	Fountain	Initial	<.0010	4/20/2021	N/A
17	21P003700	4/14/2021	A104 Kitchen Sink	Faucet	Initial	<.0010	4/20/2021	N/A
18	21P003699	4/14/2021	A104 Bubbler	Fountain	Initial	0.0024	4/20/2021	N/A
19	21P003698	4/14/2021	A109 Kitchen Sink	Faucet	Initial	<.0010	4/20/2021	N/A
20	21P003691	4/14/2021	Shop	Faucet	Initial	<.0010	4/20/2021	N/A
21	21P003692	4/14/2021	A106 Kitchen Sink	Faucet	Initial	<.0010	4/20/2021	N/A
22	21P003702	4/14/2021	A106 Bubbler	Fountain	Initial	<.0010	4/20/2021	N/A

SCHOOL NAME: School #79 225 Lawn Avenue								77 outlets
Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
23	21P003689	4/14/2021	A108 Kitchen sink	Faucet	Initial	0.0018	4/20/2021	N/A
24	21P003695	4/14/2021	A108 Bubbler	Fountain	Initial	<.0010	4/20/2021	N/A
25	21P003690	4/14/2021	A105/107 Kitchen Sink	Faucet	Initial	<.0010	4/20/2021	N/A
26	21P003697	4/14/2021	A105/107 Bubbler	Fountain	Initial	0.0072	4/20/2021	N/A
27	21P003694	4/14/2021	Atrium Bottle Filler	Bottle Filler	Initial	<.0010	4/20/2021	N/A
28	21P003696	4/14/2021	Main Office Bottle Filler	Bottle Filler	Initial	<.0010	4/20/2021	N/A
29	21P003693	4/14/2021	Clinic Sink	Faucet	Initial	<.0010	4/20/2021	N/A
30	21P003751	4/14/2021	Main Office Kitchen Sink	Faucet	Initial	0.34	4/20/2021	SIGNAGE
31	21P003750	4/14/2021	B105/107 Kitchen Sink	Faucet	Initial	<.0010	4/20/2021	N/A
32	21P003749	4/14/2021	B105/107 Bubbler	Fountain	Initial	0.002	4/20/2021	N/A
33	21P003748	4/14/2021	B106 Kitchen Sink	Faucet	Initial	<.0010	4/20/2021	N/A
34	21P003747	4/14/2021	B106 Bubbler	Fountain	Initial	<.0010	4/20/2021	N/A
35	21P003746	4/14/2021	B108 Kitchen Sink	Faucet	Initial	<.0010	4/20/2021	N/A
36	21P003745	4/14/2021	B108 Bubbler	Fountain	Initial	<.0010	4/20/2021	N/A
37	21P003744	4/14/2021	B101/103 Kitchen Sink	Faucet	Initial	0.0015	4/20/2021	N/A
38	21P003743	4/14/2021	B101/103 Bubbler	Fountain	Initial	0.18	4/20/2021	TURNED OFF
39	21P003742	4/14/2021	B 104 Kitchen Sink	Faucet	Initial	0.001	4/20/2021	N/A
40	21P003741	4/14/2021	B 104 Bubbler	Fountain	Initial	0.0237	4/20/2021	TURNED OFF
41	21P003740	4/14/2021	B 102 Kitchen Sink	Faucet	Initial	<.0010	4/20/2021	N/A
42	21P003739	4/14/2021	B 102 Bubbler	Fountain	Initial	0.0114	4/20/2021	N/A
43	21P003738	4/14/2021	B 109 Kitchen Sink	Faucet	Initial	<.0010	4/20/2021	N/A
44	21P003737	4/14/2021	A 201/203 Kitchen Sink	Faucet	Initial	<.0010	4/20/2021	N/A

SCHOOL NAME: School #79 225 Lawn Avenue								77 outlets
Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
45	21P003736	4/14/2021	A 201/203 Bubblers	Fountain	Initial	0.0631	4/20/2021	TURNED OFF
46	21P003735	4/14/2021	A 202 Kitchen Sink	Faucet	Initial	<.0010	4/20/2021	N/A
47	21P003734	4/14/2021	A 202 Bubblers	Fountain	Initial	0.0021	4/20/2021	N/A
48	21P003733	4/14/2021	A 209 B Kitchen Sink	Faucet	Initial	<.0010	4/20/2021	N/A
49	21P003732	4/14/2021	A 204 Kitchen Sink	Faucet	Initial	<.0010	4/20/2021	N/A
50	21P003731	4/14/2021	A 204 Bubblers	Fountain	Initial	<.0010	4/20/2021	N/A
51	21P003730	4/14/2021	A209 Right Sink	Faucet	Initial	<.0010	4/20/2021	N/A
52	21P003729	4/14/2021	A209 Left Sink	Faucet	Initial	<.0010	4/20/2021	N/A
53	21P003728	4/14/2021	A206 Kitchen Sink	Faucet	Initial	<.0010	4/20/2021	N/A
54	21P003727	4/14/2021	A206 Bubblers	Fountain	Initial	0.0374	4/20/2021	TURNED OFF
55	21P003726	4/14/2021	A205/207 Kitchen Sink	Faucet	Initial	<.0010	4/20/2021	N/A
56	21P003725	4/14/2021	A205/207 Bubblers	Fountain	Initial	0.0146	4/20/2021	N/A
57	21P003724	4/14/2021	A208 Kitchen Sink	Faucet	Initial	<.0010	4/20/2021	N/A
58	21P003723	4/14/2021	A208 Bubblers	Fountain	Initial	0.0044	4/20/2021	N/A
59	21P003722	4/14/2021	Home EC Sink #1	Faucet	Initial	0.0014	4/20/2021	N/A
60	21P003721	4/14/2021	Home EC Sink #2	Faucet	Initial	<.0010	4/20/2021	N/A
61	21P003720	4/14/2021	Home EC Sink #3	Faucet	Initial	<.0010	4/20/2021	N/A
62	21P003719	4/14/2021	Home EC Sink #4	Faucet	Initial	0.0015	4/20/2021	N/A
63	21P003718	4/14/2021	B205/207 Kitchen Sink	Faucet	Initial	0.0163	4/20/2021	SIGNAGE
64	21P003717	4/14/2021	B205/207 Bubblers	Fountain	Initial	0.0142	4/20/2021	N/A
65	21P003716	4/14/2021	B208 Kitchen Sink	Faucet	Initial	<.0010	4/20/2021	N/A
66	21P003715	4/14/2021	B208 Bubblers	Fountain	Initial	0.103	4/20/2021	TURNED OFF

SCHOOL NAME: School #79 225 Lawn Avenue								77 outlets
Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
67	21P003714	4/14/2021	B209 Right Sink	Faucet	Initial	<.0010	4/20/2021	N/A
68	21P003713	4/14/2021	B209 Left sink	Faucet	Initial	0.0018	4/20/2021	N/A
69	21P003712	4/14/2021	B209 Store Room	Faucet	Initial	<.0010	4/20/2021	N/A
70	21P003711	4/14/2021	B202 Kitchen Sink	Faucet	Initial	<.0010	4/20/2021	N/A
71	21P003710	4/14/2021	B206 Kitchen Sink	Faucet	Initial	0.0171	4/21/2021	SIGNAGE
72	21P003709	4/14/2021	B206 Bubbler	Fountain	Initial	<.0010	4/20/2021	N/A
73	21P003708	4/14/2021	B202 Bubbler	Fountain	Initial	0.104	4/21/2021	TURNED OFF
74	21P003707	4/14/2021	B204 Kitchen Sink	Faucet	Initial	0.0023	4/20/2021	N/A
75	21P003706	4/14/2021	B 204 Bubbler	Fountain	Initial	0.755	4/21/2021	TURNED OFF
76	21P003705	4/14/2021	B201/203 Kitchen Sink	Faucet	Initial	<.0010	4/20/2021	N/A
77	21P003704	4/14/2021	B201/203 Bubbler	Fountain	Initial	0.143	4/20/2021	TURNED OFF