

**SCHOOL NAME: School #81 140 Tacoma Avenue****29 outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
1	S23752.01	4/29/2021	1st Floor Fountain Near Rm 108	Bottle Filler	Initial	<0.001	5/13/2021	N/A
2	S23752.02	4/29/2021	Room 108 Faucet	Faucet	Initial	<0.001	5/13/2021	N/A
3	S23752.03	4/29/2021	Room 110 Faucet	Faucet	Initial	<0.001	5/13/2021	N/A
4	S23752.04	4/29/2021	Room 110 Fountain	Fountain	Initial	<0.001	5/13/2021	N/A
5	S23752.05	4/29/2021	Room 112 Faucet	Faucet	Initial	<0.001	5/13/2021	N/A
6	S23752.06	4/29/2021	Room 112 Fountain	Fountain	Initial	<0.001	5/13/2021	N/A
7	S23752.07	4/29/2021	Room 116 Faucet	Faucet	Initial	0.002	5/13/2021	N/A
8	S23752.08	4/29/2021	Room 122 Fountain	Fountain	Initial	<0.001	5/13/2021	N/A
9	S23752.09	4/29/2021	Room 101 Fountain	Fountain	Initial	0.001	5/13/2021	N/A
10	S23752.10	4/29/2021	Room 101 Faucet	Faucet	Initial	<0.001	5/13/2021	N/A
11	S23752.11	4/29/2021	Room 102 Fountain	Fountain	Initial	0.001	5/13/2021	N/A
12	S23752.12	4/29/2021	Room 102 Faucet	Faucet	Initial	<0.001	5/13/2021	N/A
13	S23752.13	4/29/2021	Room 103 Faucet	Faucet	Initial	0.001	5/13/2021	N/A
14	S23752.14	4/29/2021	Room 103 Fountain	Fountain	Initial	<0.001	5/13/2021	N/A
15	S23752.15	4/29/2021	Room 104 Faucet	Faucet	Initial	0.001	5/13/2021	N/A
16	S23752.16	4/29/2021	Room 104 Fountain	Fountain	Initial	<0.001	5/13/2021	N/A
17	S23752.17	4/29/2021	Cafeteria/Kitchen Sink	Faucet	Initial	0.003	5/13/2021	N/A
18	S23752.18	4/29/2021	Kitchen Sink	Faucet	Initial	0.003	5/13/2021	N/A
19	S23752.19	4/29/2021	Kitchen Sink Center Table	Faucet	Initial	<0.001	5/13/2021	N/A
20	S23752.20	4/29/2021	Kitchen Disk Sink	Faucet	Initial	0.001	5/13/2021	N/A
21	S23752.21	4/29/2021	Kitchen Dish Sink	Faucet	Initial	<0.001	5/13/2021	N/A
22	S23752.22	4/29/2021	Kitchen Dish Sink	Faucet	Initial	<0.001	5/13/2021	N/A
23	S23752.23	4/29/2021	2nd Floor Room 221 Faculty Room Faucet	Faucet	Initial	0.003	5/13/2021	N/A

**SCHOOL NAME: School #81 140 Tacoma Avenue****29 outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
24	S23752.24	4/29/2021	Room 217 Art Room Faucet	Faucet	Initial	0.001	5/13/2021	N/A
25	S23752.25	4/29/2021	Room 217 Art Room Faucet	Faucet	Initial	0.010	5/13/2021	N/A
26	S23752.26	4/29/2021	Room 217 Art Room Faucet	Faucet	Initial	0.002	5/13/2021	N/A
27	S23752.27	4/29/2021	Library Faucet	Faucet	Initial	0.003	5/13/2021	N/A
28	S23752.28	4/29/2021	Room 321	Faucet	Initial	0.002	5/13/2021	N/A
29	S23752.29	4/29/2021	Room 315 Faucet	Faucet	Initial	0.002	5/13/2021	N/A