

SCHOOL NAME: School #82 230 Easton Ave
53 Outlets

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
1	S25510.01	6/18/2021	Boiler Room	Faucet	Initial	0.003	8/24/2021	N/A
2	S25510.02	6/18/2021	120 - Faucet	Faucet	Initial	0.001	8/24/2021	N/A
3	S25510.03	6/18/2021	118 Bathroom	Faucet	Initial	0.003	8/24/2021	N/A
4	S25510.04	6/18/2021	116 - Faucet	Faucet	Initial	<0.001	8/24/2021	N/A
5	S25510.05	6/18/2021	Bathroom 114/116	Faucet	Initial	<0.001	8/24/2021	N/A
6	S25510.06	6/18/2021	114 - Faucet	Faucet	Initial	<0.001	8/24/2021	N/A
7	S25510.07	6/18/2021	Faculty Bathroom across 114	Faucet	Initial	<0.001	8/24/2021	N/A
8	S25510.08	6/18/2021	112 - Faucet	Faucet	Initial	0.001	8/24/2021	N/A
9	S25510.09	6/18/2021	Faculty next 107	Faucet	Initial	<0.001	8/24/2021	N/A
10	S25510.10	6/18/2021	Corridor Fountain next 110A B1	Fountain	Initial	<0.001	8/24/2021	N/A
11	S25510.11	6/18/2021	Corridor Fountain next 110A B2	Fountain	Initial	<0.001	8/24/2021	N/A
12	S25510.12	6/18/2021	Girls Bathroom next 107	Faucet	Initial	<0.001	8/24/2021	N/A
13	S25510.13	6/18/2021	Girls Bathroom next 107	Faucet	Initial	0.002	8/24/2021	N/A
14	S25510.14	6/18/2021	108 - Faucet	Faucet	Initial	0.001	8/24/2021	N/A
15	S25510.15	6/18/2021	108A	Faucet	Initial	0.002	8/24/2021	N/A
16	S25510.16	6/18/2021	Main Office	Faucet	Initial	<0.001	8/24/2021	N/A
17	S25510.17	6/18/2021	Principals	Faucet	Initial	<0.001	8/24/2021	N/A
18	S25510.18	6/18/2021	Fountain Corridor next 122	Fountain	Initial	<0.001	8/24/2021	N/A
19	S25510.19	6/18/2021	Boys Bathroom across 122 B1	Faucet	Initial	0.001	8/24/2021	N/A
20	S25510.20	6/18/2021	Boys Bathroom across 122 B2	Faucet	Initial	0.001	8/24/2021	N/A
21	S25510.21	6/18/2021	Kitchen D1	Faucet	Initial	<0.001	8/24/2021	N/A
22	S25510.22	6/18/2021	Kitchen D2	Faucet	Initial	0.005	8/24/2021	N/A
23	S25510.23	6/18/2021	Kitchen Hand Wash	Faucet	Initial	0.008	8/24/2021	N/A
24	S25510.24	6/18/2021	Kitchen Kettle	Kettle	Initial	0.065	8/24/2021	work order to replace
25	S25510.25	6/18/2021	Cafeteria Bathroom	Faucet	Initial	0.002	8/24/2021	N/A
26	S25510.26	6/18/2021	210 - Bathroom	Faucet	Initial	<0.001	8/24/2021	N/A

SCHOOL NAME: School #82 230 Easton Ave**53 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
27	S25510.27	6/18/2021	Girls Bathroom next 203 B1	Faucet	Initial	<0.001	8/24/2021	N/A
28	S25510.28	6/18/2021	Girls Bathroom next 203 B2	Faucet	Initial	<0.001	8/24/2021	N/A
29	S25510.29	6/18/2021	207 - Faucet	Faucet	Initial	<0.001	8/24/2021	N/A
30	S25510.30	6/18/2021	Bathroom 207	Faucet	Initial	<0.001	8/24/2021	N/A
31	S25510.31	6/18/2021	214 - Faucet	Faucet	Initial	<0.001	8/24/2021	N/A
32	S25510.32	6/18/2021	216 - Faucet	Faucet	Initial	<0.001	8/24/2021	N/A
33	S25510.33	6/18/2021	216/218 Bathroom	Faucet	Initial	<0.001	8/24/2021	N/A
34	S25510.34	6/18/2021	218 - Faucet	Faucet	Initial	<0.001	8/24/2021	N/A
35	S25510.35	6/18/2021	220 - Faucet	Faucet	Initial	0.002	8/24/2021	N/A
36	S25510.36	6/18/2021	220 Bathroom	Faucet	Initial	0.002	8/24/2021	N/A
37	S25510.37	6/18/2021	Faculty Bathroom	Faucet	Initial	<0.001	8/24/2021	N/A
38	S25510.38	6/18/2021	Boys Bathroom next 215 D1	Faucet	Initial	0.001	8/24/2021	N/A
39	S25510.39	6/18/2021	Boys Bathroom next 215 D2	Faucet	Initial	<0.001	8/24/2021	N/A
40	S25510.40	6/18/2021	Boys Bathroom next 215 D3	Faucet	Initial	<0.001	8/24/2021	N/A
41	S25510.41	6/18/2021	200 - Faucet	Faucet	Initial	<0.001	8/24/2021	N/A
42	S25510.42	6/18/2021	Bathroom 200	Faucet	Initial	<0.001	8/24/2021	N/A
43	S25510.43	6/18/2021	Corridor Fountain next to 304	Fountain	Initial	0.002	8/24/2021	N/A
44	S25510.44	6/18/2021	305 Bathroom	Faucet	Initial	0.002	8/24/2021	N/A
45	S25510.45	6/18/2021	309 - Faucet	Faucet	Initial	0.001	8/24/2021	N/A
46	S25510.46	6/18/2021	316 - Faucet	Faucet	Initial	<0.001	8/24/2021	N/A
47	S25510.47	6/18/2021	Fountain Corridor next 320 D1	Fountain	Initial	<0.001	8/24/2021	N/A
48	S25510.48	6/18/2021	Fountain Corridor next 320 D2	Fountain	Initial	<0.001	8/24/2021	N/A
49	S25510.49	6/18/2021	322 - Faucet	Faucet	Initial	<0.001	8/24/2021	N/A
50	S25510.50	6/18/2021	324 - Faucet	Faucet	Initial	<0.001	8/24/2021	N/A
51	S25510.51	6/18/2021	315 - Faucet	Faucet	Initial	<0.001	8/24/2021	N/A
52	S25510.52	6/18/2021	Restroom next to 315	Faucet	Initial	<0.001	8/24/2021	N/A
53	S25510.53	6/18/2021	330 - Faucet	Faucet	Initial	<0.001	8/24/2021	N/A