

SCHOOL NAME:**#94 West Hertel Academy 489 Hertel Avenue****106 outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
1	21P004147	4/24/2021	101C Bathroom	Faucet	Initial	<0.0010	5/5/2021	N/A
2	21P004148	4/24/2021	102A	Faucet	Initial	<0.0010	5/5/2021	N/A
3	21P004149	4/24/2021	102 Faculty Dining Room Fountain	Fountain	Initial	0.0037	5/5/2021	N/A
4	21P004150	4/24/2021	Room 122	Faucet	Initial	<0.0010	5/5/2021	N/A
5	21P004151	4/24/2021	Fountain Near 128 (2)	Fountain	Initial	<0.0010	5/5/2021	N/A
6	21P004152	4/24/2021	Fountain Near 128 (1)	Fountain	Initial	<0.0010	5/5/2021	N/A
7	21P004153	4/24/2021	Room 128	Faucet	Initial	<0.0010	5/5/2021	N/A
8	21P004154	4/24/2021	Room 142	Faucet	Initial	<0.0010	5/5/2021	N/A
9	21P004155	4/24/2021	Room 142 Bubbler	Fountain	Initial	<0.0010	5/5/2021	N/A
10	21P004156	4/24/2021	Girls Bathroom Near 144 (1)	Faucet	Initial	0.0013	5/5/2021	N/A
11	21P004157	4/24/2021	Girls Bathroom Near Room 144 (2)	Faucet	Initial	0.0029	5/5/2021	N/A
12	21P004158	4/24/2021	Girls Bathroom Near Room 144 (3)	Faucet	Initial	0.0083	5/5/2021	N/A
13	21P004159	4/24/2021	Fountain near Room 144 (1)	Fountain	Initial	<0.0010	5/5/2021	N/A
14	21P004160	4/24/2021	Fountain Near 144 (2)	Fountain	Initial	<0.0010	5/5/2021	N/A
15	21P004161	4/24/2021	Room 144	Faucet	Initial	<0.0010	5/5/2021	N/A
16	21P004162	4/24/2021	Boys Bathroom Near Room 146 (1)	Faucet	Initial	0.0027	5/5/2021	N/A
17	21P004163	4/24/2021	Boys Bathroom Near Room 146 (2)	Faucet	Initial	0.0035	5/5/2021	N/A
18	21P004164	4/24/2021	Room 146	Faucet	Initial	<0.0010	5/5/2021	N/A
19	21P004165	4/24/2021	146 Bubbler	Fountain	Initial	<0.0010	5/5/2021	N/A
20	21P004166	4/24/2021	Room 147	Faucet	Initial	<0.0010	5/5/2021	N/A
21	21P004167	4/24/2021	147 Room Bubbler	Fountain	Initial	<0.0010	5/5/2021	N/A
22	21P004168	4/24/2021	Room 148	Faucet	Initial	<0.0010	5/5/2021	N/A
23	21P004169	4/24/2021	Room 148 Bubbler	Fountain	Initial	<0.0010	5/5/2021	N/A
24	21P004170	4/24/2021	Room 149	Faucet	Initial	<0.0010	5/5/2021	N/A
25	21P004171	4/24/2021	Room 149 Bubbler	Fountain	Initial	<0.0010	5/5/2021	N/A

SCHOOL NAME: #94 West Hertel Academy 489 Hertel Avenue**106 outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
26	21P004172	4/24/2021	Room 158	Faucet	Initial	<0.0010	5/5/2021	N/A
27	21P004173	4/24/2021	Room 160 (1)	Faucet	Initial	<0.0010	5/5/2021	N/A
28	21P004174	4/24/2021	Room 160 (2)	Faucet	Initial	0.0013	5/5/2021	N/A
29	21P004175	4/24/2021	Room 160 (3)	Faucet	Initial	<0.0010	5/5/2021	N/A
31	21P004176	4/24/2021	Room 161 Bathroom Pool (1)	Faucet	Initial	0.0021	5/5/2021	N/A
32	21P004177	4/24/2021	Room 161 Bathroom Pool (2)	Faucet	Initial	0.0032	5/5/2021	N/A
33	21P004178	4/24/2021	243 A Fountain Low	Fountain	Initial	<0.0010	5/5/2021	N/A
34	21P004179	4/24/2021	Room 167 E	Faucet	Initial	0.001	5/5/2021	N/A
35	21P004180	4/24/2021	Room 167 L	Faucet	Initial	0.0021	5/5/2021	N/A
39	21P004181	4/24/2021	170 Garage	Faucet	Initial	0.014	5/5/2021	N/A
40	21P004182	4/24/2021	213 Faculty Break Room	Faucet	Initial	0.0069	5/5/2021	N/A
41	21P004183	4/24/2021	216 Tall Fountain	Fountain	Initial	<0.0010	5/5/2021	N/A
42	21P004184	4/24/2021	Room 217 Boys Bathroom (1)	Faucet	Initial	0.002	5/5/2021	N/A
43	21P004185	4/24/2021	Room 217 Boys Bathroom (2)	Faucet	Initial	<0.0010	5/5/2021	N/A
44	21P004186	4/24/2021	217 Girls Bathroom (1)	Faucet	Initial	<0.0010	5/5/2021	N/A
45	21P004187	4/24/2021	217 Girls Bathroom (2)	Faucet	Initial	0.0017	5/5/2021	N/A
46	21P004188	4/24/2021	217 Girls Bathroom (3)	Faucet	Initial	0.0018	5/5/2021	N/A
47	21P004189	4/24/2021	217 Next to Fountain	Fountain	Initial	<0.0010	5/5/2021	N/A
48	21P004190	4/24/2021	230 Faculty Womens	Faucet	Initial	<0.0010	5/5/2021	N/A
49	21P004191	4/24/2021	232 Boys Bathroom (1)	Faucet	Initial	<0.0010	5/5/2021	N/A
50	21P004192	4/24/2021	232 Boys Bathroom (2)	Faucet	Initial	<0.0010	5/5/2021	N/A
52	21P004193	4/24/2021	232 Fountain (1)	Fountain	Initial	<0.0010	5/5/2021	N/A
53	21P004194	4/24/2021	232 Fountain (2)	Fountain	Initial	<0.0010	5/5/2021	N/A
54	21P004195	4/24/2021	243 A Tall Fountain	Fountain	Initial	<0.0010	5/5/2021	N/A
55	21P004196	4/24/2021	234 Girls Bathroom (1)	Faucet	Initial	0.0014	5/5/2021	N/A

SCHOOL NAME: #94 West Hertel Academy 489 Hertel Avenue 106 outlets

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
56	21P004197	4/24/2021	234 Girls Bathroom (2)	Faucet	Initial	<0.0010	5/5/2021	N/A
57	21P004198	4/24/2021	243 A Boys Bathroom (1)	Faucet	Initial	<0.0010	5/5/2021	N/A
58	21P004199	4/24/2021	243 A Boys Bathroom (2)	Faucet	Initial	<0.0010	5/5/2021	N/A
59	21P004200	4/24/2021	243 Girls Bathroom (1)	Faucet	Initial	0.0013	5/5/2021	N/A
60	21P004201	4/24/2021	243 Girls Bathroom (2)	Faucet	Initial	<0.0010	5/5/2021	N/A
61	21P004202	4/24/2021	243 Girls Bathroom (3)	Faucet	Initial	<0.0010	5/5/2021	N/A
62	21P004203	4/24/2021	243 Boys Bathroom (3)	Faucet	Initial	<0.0010	5/5/2021	N/A
63	21P004204	4/24/2021	Boiler Room Faucet	Faucet	Initial	<0.0010	5/5/2021	N/A
64	21P004205	4/24/2021	Cafeteria Fountain (1)	Fountain	Initial	<0.0010	5/5/2021	N/A
65	21P004206	4/24/2021	Cafeteria Fountain (2)	Fountain	Initial	<0.0010	5/5/2021	N/A
66	21P004207	4/24/2021	Kitchen 1	Faucet	Initial	<0.0010	5/5/2021	N/A
67	21P004210	4/24/2021	Kitchen 2	Faucet	Initial	<0.0010	5/5/2021	N/A
68	21P004211	4/24/2021	Kitchen 3	Faucet	Initial	<0.0010	5/5/2021	N/A
69	21P004212	4/24/2021	Kitchen 4	Faucet	Initial	<0.0010	5/5/2021	N/A
70	21P004213	4/24/2021	Kitchen 5	Faucet	Initial	<0.0010	5/5/2021	N/A
71	21P004214	4/24/2021	Kitchen Bathroom	faucet	Initial	<0.0010	5/5/2021	N/A
72	21P004215	4/24/2021	Kitchen Handwashing Sink 1	Faucet	Initial	<0.0010	5/5/2021	N/A
75	21P004216	4/24/2021	Engineers Office Bathroom	Faucet	Initial	<0.0010	5/5/2021	N/A
76	21P004217	4/24/2021	Main Office Sink	Faucet	Initial	<0.0010	5/5/2021	N/A
77	21P004218	4/24/2021	Boys Bathroom Near 128 1	Faucet	Initial	<0.0010	5/5/2021	N/A
79	21P004219	4/24/2021	Boys Pool Locker Room Fountain	Fountain	Initial	<0.0010	5/5/2021	N/A
80	21P004220	4/24/2021	Girls Bathroom Near 128 1	Faucet	Initial	0.0023	5/5/2021	N/A
81	21P004221	4/24/2021	Girls Bathroom Near 128 2	Faucet	Initial	<0.0010	5/5/2021	N/A
82	21P004222	4/24/2021	Girls Pool Locker Room	Faucet	Initial	0.0044	5/5/2021	N/A
83	21P004223	4/24/2021	Girls Pool Locker Room Near Fountain	Faucet	Initial	0.0113	5/5/2021	N/A

SCHOOL NAME: #94 West Hertel Academy 489 Hertel Avenue**106 outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
84	21P004224	4/24/2021	Hallway Fountain Near Pool 1	Fountain	Initial	<0.0010	5/5/2021	N/A
85	21P004225	4/24/2021	Hallway Fountain Near Pool 2	Fountain	Initial	<0.0010	5/5/2021	N/A
86	21P004226	4/24/2021	1st Floor Womens Faculty	Faucet	Initial	0.0014	5/5/2021	N/A
87	21P004227	4/24/2021	Auditorium Bathroom Sink	Faucet	Initial	0.0045	5/5/2021	N/A
88	21P004228	4/24/2021	Boys Changing Room Sink	Faucet	Initial	<0.0010	5/5/2021	N/A
89	21P004229	4/24/2021	206 Elevator Drinking Fountain 1	Fountain	Initial	<0.0010	5/5/2021	N/A
90	21P004230	4/24/2021	206 Elevator Drinking Fountain 2	Fountain	Initial	<0.0010	5/5/2021	N/A
91	21P004231	4/24/2021	Womens Faculty Bathroom	Faucet	Initial	<0.0010	5/5/2021	N/A
92	21P004232	4/24/2021	Womens Faculty Bathroom 1st next to Handicap	Faucet	Initial	<0.0010	5/5/2021	N/A
93	21P004233	4/24/2021	Faculty Lunch Prep	Faucet	Initial	<0.0010	5/5/2021	N/A
94	21P004234	4/24/2021	Girls Changing Room	Faucet	Initial	<0.0010	5/5/2021	N/A
95	21P004235	4/24/2021	Mens Handicap Bathroom	Faucet	Initial	<0.0010	5/5/2021	N/A
96	21P004236	4/24/2021	Faculty Bathroom 1	Faucet	Initial	<0.0010	5/5/2021	N/A
97	21P004237	4/24/2021	Mens Faculty Bathroom 2	Faucet	Initial	<0.0010	5/5/2021	N/A
98	21P004238	4/24/2021	Clinic 150	Faucet	Initial	<0.0010	5/5/2021	N/A
99	21P004239	4/24/2021	Clinic 150 E	Faucet	Initial	<0.0010	5/5/2021	N/A
100	21P004240	4/24/2021	Clinic 150 F	Faucet	Initial	<0.0010	5/5/2021	N/A
101	21P004241	4/24/2021	144 Bubbler	Fountain	Initial	0.001	5/5/2021	N/A
102	21P004242	4/24/2021	160	Faucet	Initial	0.0016	5/5/2021	N/A
103	21P004243	4/24/2021	Boys Bathroom 217 3	Faucet	Initial	<0.0010	5/5/2021	N/A
104	21P004244	4/24/2021	2nd 230 Mens Faculty	Faucet	Initial	0.0019	5/5/2021	N/A
105	21P004245	4/24/2021	232 Boys Bathroom 3	Faucet	Initial	0.0026	5/5/2021	N/A
106	21P004246	4/24/2021	Girls Bathroom 234 3	Faucet	Initial	<0.0010	5/5/2021	N/A
107	21P004247	4/24/2021	Fountain Girls Changing Room	Fountain	Initial	0.0022	5/5/2021	N/A
108	21P004248	4/24/2021	Girls Bathroom 107B 1	Faucet	Initial	<0.0010	5/5/2021	N/A

SCHOOL NAME: #94 West Hertel Academy 489 Hertel Avenue**106 outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
109	21P004249	4/24/2021	Girls Bathroom 107B 2	Faucet	Initial	<0.0010	5/5/2021	N/A
110	21P004250	4/24/2021	Girls Bathroom 107B 3	Faucet	Initial	0.001	5/5/2021	N/A
111	21P004251	4/24/2021	Boys Bathroom 107B 1	Faucet	Initial	0.0011	5/5/2021	N/A
112	21P004252	4/24/2021	Boys Bathroom 107B 2	Faucet	Initial	<0.0010	5/5/2021	N/A
113	21P004253	4/24/2021	Boys Bathroom 107B 3	Faucet	Initial	0.0022	5/5/2021	N/A
114	21P004254	4/24/2021	105 Custodial	Faucet	Initial	<0.0010	5/5/2021	N/A