

**SCHOOL NAME: School #95 95 4th Street****151 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
1	21P007105	6/24/2021	Café boys Bathroom Faucet #1	Faucet	Initial	<0.0010	7/12/2021	N/A
2	21P007106	6/24/2021	Café Boys Bathroom Faucet #3	Faucet	Initial	<0.0010	7/12/2021	N/A
3	21P007107	6/24/2021	Café Boys Bathroom Faucet #5	Faucet	Initial	0.0022	7/12/2021	N/A
4	21P007108	6/24/2021	Café Employee Bathroom (230) Faucet	Faucet	Initial	<0.0010	7/12/2021	N/A
5	21P007109	6/24/2021	Café Girls Bathroom Faucet #1	Faucet	Initial	0.0012	7/12/2021	N/A
6	21P007110	6/24/2021	Café Girls Bathroom Faucet #5	Faucet	Initial	<0.0010	7/12/2021	N/A
7	21P007111	6/24/2021	Café Bottle Filler	Bottle Filler	Initial	<0.0010	7/12/2021	N/A
8	21P007112	6/24/2021	Faculty Kitchen Faucet	Faucet	Initial	<0.0010	7/12/2021	N/A
9	21P007113	6/24/2021	Kitchen Faucet #1	Faucet	Initial	<0.0010	7/12/2021	N/A
10	21P007114	6/24/2021	Kitchen Faucet #2	Faucet	Initial	<0.0010	7/12/2021	N/A
11	21P007115	6/24/2021	Kitchen Faucet #3	Faucet	Initial	<0.0010	7/12/2021	N/A
12	21P007116	6/24/2021	Kitchen Faucet #4	Faucet	Initial	<0.0010	7/12/2021	N/A
13	21P007117	6/24/2021	Kitchen Hand Sink Faucet	Faucet	Initial	0.0012	7/12/2021	N/A
14	21P007118	6/24/2021	Main Office Faucet	Faucet	Initial	0.0024	7/12/2021	N/A
15	21P007119	6/24/2021	Clinic 214 Faucet	Faucet	Initial	<0.0010	7/12/2021	N/A
16	21P007120	6/24/2021	Clinic 214E Faucet	Faucet	Initial	0.0041	7/12/2021	N/A
17	21P007121	6/24/2021	Clinic 214F Faucet	Faucet	Initial	0.0024	7/12/2021	N/A
18	21P007122	6/24/2021	Clinic Bathroom Faucet	Faucet	Initial	<0.0010	7/12/2021	N/A
19	21P007123	6/24/2021	Engineer Office 227 Faucet	Faucet	Initial	<0.0010	7/12/2021	N/A
20	21P007124	6/24/2021	Basement Sink Faucet - Pool Pump	Faucet	Initial	<0.0010	7/12/2021	N/A
1	S24547.01	5/21/2021	Room 139 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
2	S24547.02	5/21/2021	Boys Bathroom by 137 C2	Faucet	Initial	<0.001	7/16/2021	N/A
3	S24547.03	5/21/2021	Boys Bathroom by 137 C4	Faucet	Initial	<0.001	7/16/2021	N/A
4	S24547.04	5/21/2021	Room 142 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A

**SCHOOL NAME: School #95 95 4th Street****151 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
5	S24547.05	5/21/2021	Room 145 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
6	S24547.06	5/21/2021	Room 147 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
7	S24547.07	5/21/2021	Room 144 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
8	S24547.08	5/21/2021	Room 121 Bathroom - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
9	S24547.09	5/21/2021	Room 121 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
10	S24547.10	5/21/2021	Room 122 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
11	S24547.11	5/21/2021	Boys Bathroom by 124 C2	Faucet	Initial	<0.001	7/16/2021	N/A
12	S24547.12	5/21/2021	Boys Bathroom by 124 C4	Faucet	Initial	<0.001	7/16/2021	N/A
13	S24547.13	5/21/2021	Girls Bathroom by 124 A4	Faucet	Initial	<0.001	7/16/2021	N/A
14	S24547.14	5/21/2021	Girls Bathroom by 118 B1	Faucet	Initial	<0.001	7/16/2021	N/A
15	S24547.15	5/21/2021	Girls Bathroom by 118 B3	Faucet	Initial	0.003	7/16/2021	N/A
16	S24547.16	5/21/2021	Faculty Bathroom by 118	Faucet	Initial	0.003	7/16/2021	N/A
17	S24547.17	5/21/2021	Boys Bathroom by 118 D1	Faucet	Initial	0.003	7/16/2021	N/A
18	S24547.18	5/21/2021	Boys Bathroom by 118 D3	Faucet	Initial	0.002	7/16/2021	N/A
19	S24547.19	5/21/2021	Room 116 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
20	S24547.20	5/21/2021	Room 116 - Bathroom - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
21	S24547.21	5/21/2021	Room 115 Bathroom - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
22	S24547.22	5/21/2021	Room 115 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
23	S24547.23	5/21/2021	Room 113 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
24	S24547.24	5/21/2021	Room 113 - Bathroom - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
25	S24547.25	5/21/2021	Room 112 - Bathroom - Faucet	Faucet	Initial	0.001	7/16/2021	N/A
26	S24547.26	5/21/2021	Room 112 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
27	S24547.27	5/21/2021	Room 110 Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
28	S24547.28	5/21/2021	Room 110 Bathroom - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A

**SCHOOL NAME: School #95 95 4th Street****151 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
29	S24547.29	5/21/2021	Music Room 108 - Faucet	Faucet	Initial	0.001	7/16/2021	N/A
30	S24547.30	5/21/2021	Room 107 - Faucet	Faucet	Initial	0.002	7/16/2021	N/A
31	S24547.31	5/21/2021	Room 106 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
32	S24547.32	5/21/2021	Room 105 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
33	S24547.33	5/21/2021	Girls Bathroom by 104 B1	Faucet	Initial	<0.001	7/16/2021	N/A
34	S24547.34	5/21/2021	Girls Bathroom by 104 B2	Faucet	Initial	<0.001	7/16/2021	N/A
35	S24547.35	5/21/2021	Boys Bathroom by 101 D1	Faucet	Initial	<0.001	7/16/2021	N/A
36	S24547.36	5/21/2021	Boys Bathroom by 101 D2	Faucet	Initial	0.001	7/16/2021	N/A
37	S24547.37	5/21/2021	Theatre Girls Bathroom - Faucet C2	Faucet	Initial	0.001	7/16/2021	N/A
38	S24547.38	5/21/2021	Theatre Boys Bathroom - Faucet A1	Faucet	Initial	0.007	7/16/2021	N/A
39	S24547.39	5/21/2021	Theatre Boys Bathroom - Faucet A2	Faucet	Initial	0.011	7/16/2021	N/A
40	S24547.40	5/21/2021	Main Lobby Parent Bathroom - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
41	S24547.41	5/21/2021	Clinic - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
42	S24547.42	5/21/2021	Clinic - Faucet Bathroom	Faucet	Initial	0.002	7/16/2021	N/A
43	S24547.43	5/21/2021	Clinic - Faucet 214E	Faucet	Initial	0.016	7/16/2021	SIGNAGE
44	S24547.44	5/21/2021	Clinic - Faucet 214F	Faucet	Initial	0.019	7/16/2021	SIGNAGE
45	S24547.45	5/21/2021	Cafeteria Bubbler	Fountain	Initial	<0.001	7/16/2021	N/A
46	S24547.46	5/21/2021	Cafeteria Bottle Filler	Bottle Filler	Initial	<0.001	7/16/2021	N/A
47	S24547.47	5/21/2021	Main Entrance - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
48	S24547.48	5/21/2021	Main Entrance - Faucet 202	Faucet	Initial	0.002	7/16/2021	N/A
49	S24547.49	5/21/2021	Main Office Faculty	Faucet	Initial	<0.001	7/16/2021	N/A
50	S24547.50	5/21/2021	Main Office 205	Faucet	Initial	0.003	7/16/2021	N/A
51	S24547.51	5/21/2021	Stair J Bathroom Ladies	Faucet	Initial	<0.001	7/16/2021	N/A
52	S24547.52	5/21/2021	Stair J Bathroom Men	Faucet	Initial	<0.001	7/16/2021	N/A

**SCHOOL NAME: School #95 95 4th Street****151 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
53	S24547.53	5/21/2021	Stair G Bathroom Ladies	Faucet	Initial	<0.001	7/16/2021	N/A
54	S24547.54	5/21/2021	Stair G Bathroom Mens	Faucet	Initial	0.001	7/16/2021	N/A
55	S24547.55	5/21/2021	Room 134 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
56	S24547.56	5/21/2021	Room 133 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
57	S24547.57	5/21/2021	Room 132 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
58	S24547.58	5/21/2021	Girls Bathroom across from 132 A2	Faucet	Initial	0.001	7/16/2021	N/A
59	S24547.59	5/21/2021	Girls Bathroom across from 132 A4	Faucet	Initial	0.001	7/16/2021	N/A
60	S24547.60	5/21/2021	Room 131 - Faucet	Faucet	Initial	0.001	7/16/2021	N/A
61	S24547.61	5/21/2021	Room 129 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
62	S24547.62	5/21/2021	Room 128 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
63	S24547.63	5/21/2021	Room 127 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
64	S24547.64	5/21/2021	Room 126 - Faucet	Faucet	Initial	0.001	7/16/2021	N/A
65	S24547.65	5/21/2021	Room 339 Faculty Bathroom - Faucet Women's	Faucet	Initial	<0.001	7/16/2021	N/A
66	S24547.66	5/21/2021	Room 339 Faculty Bathroom - Faucet Men's	Faucet	Initial	0.003	7/16/2021	N/A
67	S24547.67	5/21/2021	Room 329 - Faucet	Faucet	Initial	0.001	7/16/2021	N/A
68	S24547.68	5/21/2021	Room 330 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
69	S24547.69	5/21/2021	Stair O Men's Bathroom	Faucet	Initial	0.002	7/16/2021	N/A
70	S24547.70	5/21/2021	Stair O Women's Bathroom	Faucet	Initial	0.003	7/16/2021	N/A
71	S24547.71	5/21/2021	Room 331 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
72	S24547.72	5/21/2021	Room 334 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
73	S24547.73	5/21/2021	Room 336	Faucet	Initial	<0.001	7/16/2021	N/A
74	S24547.74	5/21/2021	Room 333 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
75	S24547.75	5/21/2021	Room 312 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
76	S24547.76	5/21/2021	Stair N Men's Bathroom	Faucet	Initial	<0.001	7/16/2021	N/A

**SCHOOL NAME: School #95 95 4th Street****151 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
77	S24547.77	5/21/2021	Stair N Women's Bathroom	Faucet	Initial	0.001	7/16/2021	N/A
78	S24547.78	5/21/2021	Room 313 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
79	S24547.79	5/21/2021	Boys Bathroom across from 313	Faucet	Initial	0.002	7/16/2021	N/A
80	S24547.80	5/21/2021	Boys Bathroom across from 313	Faucet	Initial	0.002	7/16/2021	N/A
81	S24547.81	5/21/2021	Boys Bathroom across from 313	Faucet	Initial	<0.001	7/16/2021	N/A
82	S24547.82	5/21/2021	Boys Bathroom across from 313	Faucet	Initial	<0.001	7/16/2021	N/A
83	S24547.83	5/21/2021	Girls Bathroom by 308	Faucet	Initial	<0.001	7/16/2021	N/A
84	S24547.84	5/21/2021	Girls Bathroom by 308	Faucet	Initial	0.002	7/16/2021	N/A
85	S24547.85	5/21/2021	Faculty Bathroom by 308	Faucet	Initial	0.001	7/16/2021	N/A
86	S24547.86	5/21/2021	Boys Bathroom by 308	Faucet	Initial	0.002	7/16/2021	N/A
87	S24547.87	5/21/2021	Boys Bathroom by 308	Faucet	Initial	<0.001	7/16/2021	N/A
88	S24547.88	5/21/2021	Room 317 - Faucet	Faucet	Initial	0.001	7/16/2021	N/A
89	S24547.89	5/21/2021	Girls Bathroom by 317	Faucet	Initial	0.001	7/16/2021	N/A
90	S24547.90	5/21/2021	Girls Bathroom by 317	Faucet	Initial	0.001	7/16/2021	N/A
91	S24547.91	5/21/2021	Room 318 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
92	S24547.92	5/21/2021	Room 319 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
93	S24547.93	5/21/2021	Room 320 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
94	S24547.94	5/21/2021	Room 322 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
95	S24547.95	5/21/2021	Room 323 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
96	S24547.96	5/21/2021	Room 324 - Faucet	Faucet	Initial	0.001	7/16/2021	N/A
97	S24548.01	5/21/2021	Room 408 - Faucet	Faucet	Initial	0.001	7/16/2021	N/A
98	S24548.02	5/21/2021	Room 408 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
99	S24548.03	5/21/2021	Room 408 - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
100	S24548.04	5/21/2021	Room 408 - Faucet	Faucet	Initial	0.002	7/16/2021	N/A

**SCHOOL NAME: School #95 95 4th Street****151 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
101	S24548.05	5/21/2021	4th FI Women's Faculty Bathroom - Faucet	Faucet	Initial	0.015	7/16/2021	N/A
102	S24548.06	5/21/2021	4th FI Women's Faculty Bathroom - Faucet	Faucet	Initial	0.002	7/16/2021	N/A
103	S24548.07	5/21/2021	4th FI Men's Faculty Bathroom - Faucet	Faucet	Initial	<0.001	7/16/2021	N/A
104	S24548.08	5/21/2021	4th FI Men's Faculty Bathroom - Faucet	Faucet	Initial	0.010	7/16/2021	N/A
105	S24548.09	5/21/2021	4th FI Handicap Bathroom - Faucet	Faucet	Initial	0.008	7/16/2021	N/A
106	S24548.10	5/21/2021	4th FI Girls "Gang" Bathroom - Faucet D1	Faucet	Initial	0.002	7/16/2021	N/A
107	S24548.11	5/21/2021	4th FI Girls "Gang" Bathroom - Faucet D3	Faucet	Initial	<0.001	7/16/2021	N/A
108	S24548.12	5/21/2021	4th FI Girls "Gang" Bathroom - Faucet D5	Faucet	Initial	0.009	7/16/2021	N/A
109	S24548.13	5/21/2021	4th FI Boys "Gang" Bathroom - Faucet B1	Faucet	Initial	0.002	7/16/2021	N/A
110	S24548.14	5/21/2021	4th FI Boys "Gang" Bathroom - Faucet B3	Faucet	Initial	0.004	7/16/2021	N/A
111	S24548.15	5/21/2021	4th FI Boys "Gang" Bathroom - Faucet B4	Faucet	Initial	0.003	7/16/2021	N/A
112	S24548.16	5/21/2021	Pool Boys Locker Rm - Faucet C1	Faucet	Initial	0.002	7/16/2021	N/A
113	S24548.17	5/21/2021	Pool Boys Drinking Fountain C2	Fountain	Initial	0.001	7/16/2021	N/A
114	S24548.18	5/21/2021	Pool Boys Locker Rm - Faucet C4	Faucet	Initial	0.008	7/16/2021	N/A
115	S24548.19	5/21/2021	Pool Boys Locker Rm - Faucet	Faucet	Initial	0.003	7/16/2021	N/A
116	S24548.20	5/21/2021	Pool Men's Office - Faucet	Faucet	Initial	0.001	7/16/2021	N/A
117	S24548.21	5/21/2021	Pool Girls Locker Rm - Faucet C1	Faucet	Initial	0.014	7/16/2021	N/A
118	S24548.22	5/21/2021	Pool Girls Locker Rm - Drinking Fountain C2	Fountain	Initial	0.002	7/16/2021	N/A
119	S24548.23	5/21/2021	Pool Girls Locker Rm - Faucet C3	Faucet	Initial	0.002	7/16/2021	N/A
120	S24548.24	5/21/2021	Pool Women's Office - Faucet	Faucet	Initial	0.007	7/16/2021	N/A
121	S24548.25	5/21/2021	Girls Gym Locker Room - Faucet	Faucet	Initial	0.004	7/16/2021	N/A
122	S24548.26	5/21/2021	Gym Girls Office	Faucet	Initial	0.001	7/16/2021	N/A
123	S24548.27	5/21/2021	Gym Boys Office	Faucet	Initial	0.002	7/16/2021	N/A
124	S24548.28	5/21/2021	Gym Boys Locker Room - Faucet	Faucet	Initial	0.006	7/16/2021	N/A

**SCHOOL NAME: School #95 95 4th Street****151 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
125	S24548.29	5/21/2021	Outside Fac Dining - Faucet	Faucet	Initial	0.002	7/16/2021	N/A
126	S24548.30	5/21/2021	Kitchen Faucet B1	Faucet	Initial	<0.001	7/16/2021	N/A
127	S24548.31	5/21/2021	Kitchen Faucet B2	Faucet	Initial	<0.001	7/16/2021	N/A
128	S24548.32	5/21/2021	Kitchen Faucet C1	Faucet	Initial	0.003	7/16/2021	N/A
129	S24548.33	5/21/2021	Kitchen Faucet C2	Faucet	Initial	0.001	7/16/2021	N/A
130	S24548.34	5/21/2021	Kitchen Faucet D	Faucet	Initial	0.004	7/16/2021	N/A
131	S24548.35	5/21/2021	Kitchen Faucet - Hand Wash D	Faucet	Initial	0.002	7/16/2021	N/A