

**SCHOOL NAME: School #304 256 S. Elmwood Avenue****99 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
1	S23663.01	4/24/2021	Boiler Room	Faucet	Initial	<0.001	5/7/2021	N/A
2	S23663.02	4/24/2021	Room 118	Faucet	Initial	0.006	5/7/2021	N/A
3	S23663.03	4/24/2021	Kitchen Hand Wash	Faucet	Initial	0.007	5/7/2021	N/A
4	S23663.04	4/24/2021	Kitchen Prep Sink Center Table	Faucet	Initial	<0.001	5/7/2021	N/A
5	S23663.05	4/24/2021	Kitchen Pot Filler	Pot Filler	Initial	0.004	5/7/2021	N/A
6	S23663.06	4/24/2021	Kitchen Pot Filler	Pot Filler	Initial	0.004	5/7/2021	N/A
7	S23663.07	4/24/2021	Cafeteria Hand Wash	Faucet	Initial	0.003	5/7/2021	N/A
8	S23663.08	4/24/2021	Cafeteria Hand Wash	Faucet	Initial	0.003	5/7/2021	N/A
9	S23663.09	4/24/2021	Cafeteria Fountain	Fountain	Initial	<0.001	5/7/2021	N/A
10	S23663.10	4/24/2021	Cafeteria Fountain	Fountain	Initial	0.001	5/7/2021	N/A
11	S23663.11	4/24/2021	1st Boys Restrm across from Rm 101	Faucet	Initial	<0.001	5/7/2021	N/A
12	S23663.12	4/24/2021	1st Boys Restrm across from Rm 101	Faucet	Initial	0.001	5/7/2021	N/A
13	S23663.13	4/24/2021	1st Boys Restrm across from Rm 101	Faucet	Initial	0.001	5/7/2021	N/A
14	S23663.14	4/24/2021	1st Boys Restrm across from Rm 101	Faucet	Initial	<0.001	5/7/2021	N/A
15	S23663.15	4/24/2021	1st Girls Restrm across from Rm 102	Faucet	Initial	<0.001	5/7/2021	N/A
16	S23663.16	4/24/2021	1st Girls Restrm across from Rm 102	Faucet	Initial	<0.001	5/7/2021	N/A
17	S23663.17	4/24/2021	1st Girls Restrm across from Rm 102	Faucet	Initial	<0.001	5/7/2021	N/A
18	S23663.18	4/24/2021	1st Girls Restrm across from Rm 102	Faucet	Initial	<0.001	5/7/2021	N/A
19	S23663.19	4/24/2021	1st Girls Restrm across from Rm 102	Faucet	Initial	<0.001	5/7/2021	N/A
20	S23663.20	4/24/2021	Room 100K Faculty Bath	Faucet	Initial	0.002	5/7/2021	N/A
21	S23663.21	4/24/2021	Room 105 Weight Room Fountain	Fountain	Initial	0.038	5/7/2021	SHUT DOWN
22	S23663.22	4/24/2021	Coaches Office 113	Faucet	Initial	<0.001	5/7/2021	N/A
23	S23663.23	4/24/2021	2nd Floor - Boys Locker Room across from Rm 204	Faucet	Initial	0.002	5/7/2021	N/A
24	S23663.24	4/24/2021	2nd Floor - Boys Locker Room across from Rm 204	Faucet	Initial	0.001	5/7/2021	N/A
25	S23663.25	4/24/2021	2nd Floor - Woman's Coaches Office	Faucet	Initial	<0.001	5/7/2021	N/A

**SCHOOL NAME: School #304 256 S. Elmwood Avenue****99 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
26	S23663.26	4/24/2021	2nd Floor - Woman's Locker Room	Faucet	Initial	0.002	5/7/2021	N/A
27	S23663.27	4/24/2021	2nd Floor - Woman's Locker Room	Faucet	Initial	0.003	5/7/2021	N/A
28	S23663.28	4/24/2021	2nd Floor Hallway	Bottle Filler	Initial	<0.001	5/7/2021	N/A
29	S23663.29	4/24/2021	2nd FI Girls Bathroom Next to Rm 209	Faucet	Initial	0.003	5/7/2021	N/A
30	S23663.30	4/24/2021	2nd FI Girls Bathroom Next to Rm 209	Faucet	Initial	0.003	5/7/2021	N/A
31	S23663.31	4/24/2021	2nd FI Girls Bathroom Next to Rm 209	Faucet	Initial	0.009	5/7/2021	N/A
32	S23663.32	4/24/2021	2nd FI Girls Bathroom Next to Rm 209	Faucet	Initial	0.001	5/7/2021	N/A
33	S23663.33	4/24/2021	2nd Floor Rm 203 Lounge	Faucet	Initial	0.004	5/7/2021	N/A
34	S23663.34	4/24/2021	Room 201 Restroom	Faucet	Initial	0.004	5/7/2021	N/A
35	S23663.35	4/24/2021	Library 211	Faucet	Initial	0.003	5/7/2021	N/A
36	S23663.36	4/24/2021	2nd FI Girls Restroom across Room 225	Faucet	Initial	<0.001	5/7/2021	N/A
37	S23663.37	4/24/2021	2nd FI Faculty Restroom Next to Rm 226	Faucet	Initial	<0.001	5/7/2021	N/A
38	S23663.38	4/24/2021	3rd FI Faculty Restroom Next to Rm 222	Faucet	Initial	<0.001	5/7/2021	N/A
39	S23663.39	4/24/2021	2nd FI Boys Restroom Handicap across Rm 204 Fountain	Fountain	Initial	<0.001	5/7/2021	N/A
40	S23663.40	4/24/2021	2nd FI Boys Restroom Handicap across Rm 204 Fountain	Fountain	Initial	<0.001	5/7/2021	N/A
41	S23663.41	4/24/2021	2nd FI Boys Restroom Across from Rm 204 Handicap	Faucet	Initial	<0.001	5/7/2021	N/A
42	S23663.42	4/24/2021	Boys Restroom by 230	Faucet	Initial	0.002	5/7/2021	N/A
43	S23663.43	4/24/2021	Boys Restroom by 230	Faucet	Initial	0.021	5/7/2021	SIGNAGE
44	S23663.44	4/24/2021	2nd Floor Rm 218	Faucet	Initial	<0.001	5/7/2021	N/A
45	S23663.45	4/24/2021	Faculty by 218	Faucet	Initial	<0.001	5/7/2021	N/A
46	S23663.46	4/24/2021	3rd Faculty by 335	Faucet	Initial	<0.001	5/7/2021	N/A
47	S23663.47	4/24/2021	3rd FI Hall across from Rm 315 Fountain	Fountain	Initial	<0.001	5/7/2021	N/A
48	S23663.48	4/24/2021	3rd FI Hall across from Rm 315 Fountain	Fountain	Initial	<0.001	5/7/2021	N/A
49	S23663.49	4/24/2021	3rd FI Girls Restroom across from Rm 315	Faucet	Initial	<0.001	5/7/2021	N/A
50	S23663.50	4/24/2021	3rd FI Girls Restroom across from Rm 315	Faucet	Initial	0.002	5/7/2021	N/A

**SCHOOL NAME: School #304 256 S. Elmwood Avenue****99 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
51	S23663.51	4/24/2021	3rd FI Girls Restroom across from Rm 315	Faucet	Initial	<0.001	5/7/2021	N/A
52	S23663.52	4/24/2021	3rd FI Girls Restroom across from Rm 315	Faucet	Initial	0.015	5/7/2021	N/A
53	S23663.53	4/24/2021	3rd FI Girls Restroom across from Rm 315	Faucet	Initial	0.002	5/7/2021	N/A
54	S23663.54	4/24/2021	3rd FI Faculty Restroom Next to Rm 332	Faucet	Initial	<0.001	5/7/2021	N/A
55	S23663.55	4/24/2021	3rd FI Hall across from Rm 312 Fountain	Fountain	Initial	<0.001	5/7/2021	N/A
56	S23663.56	4/24/2021	3rd FI Hall across from Rm 312 Fountain	Fountain	Initial	<0.001	5/7/2021	N/A
57	S23663.57	4/24/2021	3rd FI Boys Restroom Handicap	Faucet	Initial	0.002	5/7/2021	N/A
58	S23663.58	4/24/2021	3rd FI Boys Restroom Handicap	Faucet	Initial	0.002	5/7/2021	N/A
59	S23663.59	4/24/2021	3rd FI Boys Restroom Handicap	Faucet	Initial	0.002	5/7/2021	N/A
60	S23663.60	4/24/2021	3rd FI Boys Restroom Handicap	Faucet	Initial	0.003	5/7/2021	N/A
61	S23663.61	4/24/2021	3rd FI Boys Restroom Handicap	Faucet	Initial	0.001	5/7/2021	N/A
62	S23663.62	4/24/2021	Room 320	Faucet	Initial	<0.001	5/7/2021	N/A
63	S23663.63	4/24/2021	Room 320	Faucet	Initial	<0.001	5/7/2021	N/A
64	S23663.64	4/24/2021	Room 320	Faucet	Initial	0.002	5/7/2021	N/A
65	S23663.65	4/24/2021	3rd FI Rm 305	Faucet	Initial	<0.001	5/7/2021	N/A
66	S23663.66	4/24/2021	4th FI Faculty Restroom Next to Rm 431	Faucet	Initial	<0.001	5/7/2021	N/A
67	S23663.67	4/24/2021	4th FI Hall across from Rm 413 Fountain	Fountain	Initial	0.005	5/7/2021	N/A
68	S23663.68	4/24/2021	4th FI Hall across form Rm 413 Fountain	Fountain	Initial	<0.001	5/7/2021	N/A
69	S23663.69	4/24/2021	4th FI Hall across from Rm 413 Girls Handicap	Faucet	Initial	0.003	5/7/2021	N/A
70	S23663.70	4/24/2021	4th FI Hall across from Rm 413 Girls Handicap	Faucet	Initial	0.008	5/7/2021	N/A
71	S23663.71	4/24/2021	4th FI Hall across from Rm 413 Girls Handicap	Faucet	Initial	0.001	5/7/2021	N/A
72	S23663.72	4/24/2021	4th FI Hall across from Rm 413 Girls Handicap	Faucet	Initial	0.004	5/7/2021	N/A
73	S23663.73	4/24/2021	4th FI Hall across from Rm 413 Girls Handicap	Faucet	Initial	0.002	5/7/2021	N/A
74	S23663.74	4/24/2021	4th FI Faculty Restroom Next to Rm 432	Faucet	Initial	<0.001	5/7/2021	N/A
75	S23663.75	4/24/2021	4th FI Boys Restroom Handicap	Faucet	Initial	0.014	5/7/2021	N/A

**SCHOOL NAME: School #304 256 S. Elmwood Avenue****99 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
76	S23663.76	4/24/2021	4th FI Boys Restroom Next to Rm 424	Faucet	Initial	<0.001	5/7/2021	N/A
77	S23663.77	4/24/2021	4th FI Boys Restroom Next to Rm 424	Faucet	Initial	0.001	5/7/2021	N/A
78	S23663.78	4/24/2021	4th FI Boys Restroom Next to Rm 424	Faucet	Initial	<0.001	5/7/2021	N/A
79	S23663.79	4/24/2021	5th FI Girls Restroom Handicap	Faucet	Initial	0.004	5/7/2021	N/A
80	S23663.80	4/24/2021	5th FI Girls Restroom Handicap	Faucet	Initial	0.007	5/7/2021	N/A
81	S23663.81	4/24/2021	5th FI Girls Restroom Handicap	Faucet	Initial	0.004	5/7/2021	N/A
82	S23663.82	4/24/2021	5th FI Girls Restroom Handicap	Faucet	Initial	0.002	5/7/2021	N/A
83	S23663.83	4/24/2021	5th FI Girls Restroom Handicap	Faucet	Initial	0.004	5/7/2021	N/A
84	S23663.84	4/24/2021	5th FI Girls Restroom Handicap	Faucet	Initial	<0.001	5/7/2021	N/A
85	S23663.85	4/24/2021	5th FI Faculty Restroom across from 525	Faucet	Initial	<0.001	5/7/2021	N/A
86	S23663.86	4/24/2021	5th FI Hall across from Rm 509 Fountain	Fountain	Initial	0.001	5/7/2021	N/A
87	S23663.87	4/24/2021	5th FI Hall across from Rm 509 Fountain	Fountain	Initial	<0.001	5/7/2021	N/A
88	S23663.88	4/24/2021	5th FI Hall Next to Rm 514 Fountain	Fountain	Initial	0.001	5/7/2021	N/A
89	S23663.89	4/24/2021	5th FI Hall Next to Rm 514 Fountain	Fountain	Initial	0.001	5/7/2021	N/A
90	S23663.90	4/24/2021	5th FI Boys Restroom Handicap	Faucet	Initial	0.002	5/7/2021	N/A
91	S23663.91	4/24/2021	5th FI Boys Restroom	Faucet	Initial	<0.001	5/7/2021	N/A
92	S23663.92	4/24/2021	5th FI Boys Restroom	Faucet	Initial	0.003	5/7/2021	N/A
93	S23663.93	4/24/2021	5th FI Boys Restroom	Faucet	Initial	0.001	5/7/2021	N/A
94	S23663.94	4/24/2021	5th FI Rm 513 Restroom	Faucet	Initial	<0.001	5/7/2021	N/A
95	S23663.95	4/24/2021	5th FI Rm 513 Restroom	Faucet	Initial	<0.001	5/7/2021	N/A
96	S23663.96	4/24/2021	5th FI Rm 513 C	Faucet	Initial	0.004	5/7/2021	N/A
97	S23663.97	4/24/2021	Rm 503 Music Room	Faucet	Initial	0.006	5/7/2021	N/A
98	S23663.98	4/24/2021	Hall Next to Girls Locker Room Fountain	Fountain	Initial	<0.001	5/7/2021	N/A
99	S23663.99	4/24/2021	Hall Next to Girls Locker Room Fountain	Fountain	Initial	<0.001	5/7/2021	N/A