

SCHOOL NAME: School #305 1500 Elmwood Avenue**95 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
1	S25474.01	6/17/2021	Pool Women's Locker Rm - Faucet A1	Faucet	Initial	0.020	8/9/2021	SIGNAGE
2	S25474.02	6/17/2021	Pool Women's Locker Rm - Faucet A2	Faucet	Initial	0.006	8/9/2021	N/A
3	S25474.03	6/17/2021	Rm 148 Bath - Faucet	Faucet	Initial	0.005	8/9/2021	N/A
4	S25474.04	6/17/2021	Team Locker Rm - Faucet	Faucet	Initial	0.002	8/9/2021	N/A
5	S25474.05	6/17/2021	Rm 150 Bath - Faucet	Faucet	Initial	0.172	8/9/2021	SIGNAGE
6	S25474.06	6/17/2021	Gym Men's Locker Rm - Faucet A1	Faucet	Initial	0.002	8/9/2021	N/A
7	S25474.07	6/17/2021	Gym Men's Locker Rm - Faucet A2	Faucet	Initial	0.002	8/9/2021	N/A
8	S25474.08	6/17/2021	Custodian Bath - Faucet	Faucet	Initial	<0.001	8/9/2021	N/A
9	S25474.09	6/17/2021	1st FL - Fountain near Rm 141	Fountain	Initial	<0.001	8/9/2021	N/A
10	S25474.10	6/17/2021	1st FL - Fountain near Rm 171	Fountain	Initial	0.002	8/9/2021	N/A
11	S25474.11	6/17/2021	Rm 172 - Bath Faucet	Faucet	Initial	0.001	8/9/2021	N/A
12	S25474.12	6/17/2021	Rm 177 - Faucet D1	Faucet	Initial	0.032	8/9/2021	SIGNAGE
13	S25474.13	6/17/2021	Rm 177 - Faucet D2	Faucet	Initial	0.009	8/9/2021	N/A
14	S25474.14	6/17/2021	Rm 177 - Faucet D3	Faucet	Initial	0.015	8/9/2021	N/A
15	S25474.15	6/17/2021	Rm 177 - Faucet D4	Faucet	Initial	0.017	8/9/2021	SIGNAGE
16	S25474.16	6/17/2021	Rm 177 - Faucet D5	Faucet	Initial	0.019	8/9/2021	SIGNAGE
17	S25474.17	6/17/2021	Rm 177 - Faucet D6	Faucet	Initial	0.705	8/9/2021	SIGNAGE
18	S25474.18	6/17/2021	1st FI - Fountain near Rm 185	Fountain	Initial	0.002	8/9/2021	N/A
19	S25474.19	6/17/2021	1st FL- Men's Faculty near 179	Faucet	Initial	0.008	8/9/2021	N/A
20	S25474.20	6/17/2021	1st FL - Women's Faculty near 179	Faucet	Initial	<0.001	8/9/2021	N/A
21	S25474.21	6/17/2021	Rm 186 - Faucet	Faucet	Initial	0.001	8/9/2021	N/A
22	S25474.22	6/17/2021	Rm 187 - Faucet B1	Faucet	Initial	0.010	8/9/2021	N/A
23	S25474.23	6/17/2021	Rm 187 - Faucet B2	Faucet	Initial	0.007	8/9/2021	N/A
24	S25474.24	6/17/2021	Rm 181 - Faucet	Faucet	Initial	0.001	8/9/2021	N/A
25	S25474.25	6/17/2021	1st FL - Fountain near Rm 179	Fountain	Initial	0.012	8/9/2021	N/A
26	S25474.26	6/17/2021	Rm 168 - Fountain	Fountain	Initial	0.002	8/9/2021	N/A
27	S25474.27	6/17/2021	Rm 167 - Fountain	Fountain	Initial	0.001	8/9/2021	N/A
28	S25474.28	6/17/2021	Rm 138 - Faucet	Faucet	Initial	<0.001	8/9/2021	N/A

SCHOOL NAME: School #305 1500 Elmwood Avenue
95 Outlets

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
29	S25474.29	6/17/2021	Rm 138 - Fountain	Fountain	Initial	<0.001	8/9/2021	N/A
30	S25474.30	6/17/2021	Rm 155 - Faucet B1	Faucet	Initial	0.015	8/9/2021	N/A
31	S25474.31	6/17/2021	Rm 155 - Faucet B2	Faucet	Initial	0.005	8/9/2021	N/A
32	S25474.32	6/17/2021	Rm 155 - Faucet B3	Faucet	Initial	0.004	8/9/2021	N/A
33	S25474.33	6/17/2021	Rm 137 - Faucet	Faucet	Initial	0.002	8/9/2021	N/A
34	S256474.34	6/17/2021	Rm 137 - Fountain	Fountain	Initial	0.013	8/9/2021	N/A
35	S25474.35	6/17/2021	1st FL - Men's near Rm 135 - Faucet	Faucet	Initial	0.002	8/9/2021	N/A
36	S25474.36	6/17/2021	1st FL - Women near Rm 135 - Faucet	Faucet	Initial	0.003	8/9/2021	N/A
37	S25474.37	6/17/2021	Rm 135 - Faucet Hand Sink	Faucet	Initial	0.011	8/9/2021	N/A
38	S25474.38	6/17/2021	Rm 135 - Faucet Staff Bathroom	Faucet	Initial	0.008	8/9/2021	N/A
39	S25474.39	6/17/2021	Rm 135 - Faucet D1	Faucet	Initial	0.009	8/9/2021	N/A
40	S25474.40	6/17/2021	Rm 135 - Faucet D2	Faucet	Initial	0.004	8/9/2021	N/A
41	S25474.41	6/17/2021	Rm 135 - Faucet B	Faucet	Initial	0.006	8/9/2021	N/A
42	S25474.42	6/17/2021	Rm 135 - Faucet B1	Faucet	Initial	0.002	8/9/2021	N/A
43	S25474.43	6/17/2021	Rm 135 - Faucet B2	Faucet	Initial	0.001	8/9/2021	N/A
44	S25474.44	6/17/2021	Rm 135 - Fountain B1	Fountain	Initial	0.007	8/9/2021	N/A
45	S25474.45	6/17/2021	Rm 135 - Fountain B2	Fountain	Initial	0.002	8/9/2021	N/A
46	S25474.46	6/17/2021	1st FL - Fountain near Rm 134	Fountain	Initial	0.739	8/9/2021	SHUT OFF
47	S25474.47	6/17/2021	Rm 131A - Faucet	Faucet	Initial	0.002	8/9/2021	N/A
48	S25474.48	6/17/2021	Rm 127 - Fountain	Fountain	Initial	0.003	8/9/2021	N/A
49	S25474.49	6/17/2021	Rm 128 - Faucet	Faucet	Initial	<0.001	8/9/2021	N/A
50	S25474.50	6/17/2021	Rm 128A - Faucet	Faucet	Initial	0.002	8/9/2021	N/A
51	S25474.51	6/17/2021	Rm 128B - Faucet	Faucet	Initial	0.011	8/9/2021	N/A
52	S25474.52	6/17/2021	Rm 128C - Faucet	Faucet	Initial	0.006	8/9/2021	N/A
53	S25474.53	6/17/2021	Rm 128 Bath - Faucet	Faucet	Initial	0.002	8/9/2021	N/A
54	S25474.54	6/17/2021	Rm 126 Bath - Faucet	Faucet	Initial	0.015	8/9/2021	N/A
55	S25474.55	6/17/2021	1st FL - Fountain near Rm 125	Fountain	Initial	0.003	8/9/2021	N/A
56	S25474.56	6/17/2021	1st FL - Men's near Rm 123 - Faucet C1	Faucet	Initial	0.016	8/9/2021	SIGNAGE

SCHOOL NAME: School #305 1500 Elmwood Avenue
95 Outlets

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
57	S25474.57	6/17/2021	1st FL - Men's near Rm 123 - Faucet C2	Faucet	Initial	0.018	8/9/2021	SIGNAGE
58	S25474.58	6/17/2021	1st FL - Men's near Rm 123 - Faucet C3	Faucet	Initial	0.042	8/9/2021	SIGNAGE
59	S25474.59	6/17/2021	1st FL - Women near Rm 123 - Faucet A1	Faucet	Initial	0.004	8/9/2021	N/A
60	S25474.60	6/17/2021	1st FL - Women near Rm 123 - Faucet A2	Faucet	Initial	0.003	8/9/2021	N/A
61	S25474.61	6/17/2021	1st FL - Women near Rm 123 - Faucet A3	Faucet	Initial	0.003	8/9/2021	N/A
62	S25474.62	6/17/2021	Rm 100 Staff - Faucet	Faucet	Initial	0.002	8/9/2021	N/A
63	S25474.63	6/17/2021	Rm 100 Bath - Faucet	Faucet	Initial	0.002	8/9/2021	N/A
64	S25474.64	6/17/2021	1st FL - Women near Rm 112 - Faucet	Faucet	Initial	<0.001	8/9/2021	N/A
65	S25474.65	6/17/2021	1st FL - Men's near Rm 115 - Faucet	Faucet	Initial	<0.001	8/9/2021	N/A
66	S25474.66	6/17/2021	Rm 113 - Faucet	Faucet	Initial	<0.001	8/9/2021	N/A
67	S25474.67	6/17/2021	1st FL - Fountain near Rm 113	Fountain	Initial	0.001	8/9/2021	N/A
68	S25474.68	6/17/2021	Rm 114 Bath - Faucet	Faucet	Initial	0.020	8/9/2021	SIGNAGE
69	S25474.69	6/17/2021	Rm 119 - Faucet	Faucet	Initial	0.001	8/9/2021	N/A
70	S25474.70	6/17/2021	Rm 116 - Faucet	Faucet	Initial	<0.001	8/9/2021	N/A
71	S25474.71	6/17/2021	Rm 116 - Faucet	Faucet	Initial	0.001	8/9/2021	N/A
72	S25474.72	6/17/2021	Rm 118A - Faucet	Faucet	Initial	<0.001	8/9/2021	N/A
73	S25474.73	6/17/2021	Rm 153 - Faucet	Faucet	Initial	0.003	8/9/2021	N/A
74	S25474.74	6/17/2021	2nd FL - Women near Rm 208 - Faucet C1	Faucet	Initial	0.009	8/9/2021	N/A
75	S25474.75	6/17/2021	2nd FL - Women near Rm 208 - Faucet C2	Faucet	Initial	0.048	8/9/2021	SIGNAGE
76	S25474.76	6/17/2021	2nd FL - Women near Rm 222 - Faucet C3	Faucet	Initial	0.029	8/9/2021	SIGNAGE
77	S25474.77	6/17/2021	2nd FL - Men's near Rm 208 - Faucet A2	Faucet	Initial	0.004	8/9/2021	N/A
78	S25474.78	6/17/2021	2nd FL - Fountain near Rm 210	Fountain	Initial	0.002	8/9/2021	N/A
79	S25474.79	6/17/2021	Rm 214 Bath - Faucet to right facing them	Faucet	Initial	0.001	8/9/2021	N/A
80	S25474.80	6/17/2021	Rm 214 South - Bath - Faucet to left facing them	Faucet	Initial	0.001	8/9/2021	N/A
81	S25474.81	6/17/2021	2nd FL - Fountain near Rm 222	Fountain	Initial	0.001	8/9/2021	N/A
82	S25474.82	6/17/2021	Rm 311 Bath - Faucet to right facing them	Faucet	Initial	0.001	8/9/2021	N/A
83	S25474.83	6/17/2021	Rm 311 Bath - Faucet to left facing them	Faucet	Initial	0.002	8/9/2021	N/A
84	S25474.84	6/17/2021	3rd FL - Women near Rm 302 - Faucet C1	Faucet	Initial	0.014	8/9/2021	N/A

SCHOOL NAME: School #305 1500 Elmwood Avenue**95 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
85	S25474.85	6/17/2021	3rd FL - Women near Rm 302 - Faucet C2	Faucet	Initial	0.034	8/9/2021	SIGNAGE
86	S25474.86	6/17/2021	3rd FL - Women near Rm 302 - Faucet C3	Faucet	Initial	0.017	8/9/2021	SIGNAGE
87	S25474.87	6/17/2021	3rd FL - Men's near Rm 303 - Faucet A2	Faucet	Initial	0.003	8/9/2021	N/A
88	S25474.88	6/17/2021	3rd FL - Men's near Rm 303 - Faucet A3	Faucet	Initial	0.005	8/9/2021	N/A
89	S25474.89	6/17/2021	4th FL - Women near Rm 403 - Faucet C1	Faucet	Initial	0.006	8/9/2021	N/A
90	S25474.90	6/17/2021	4th FL - Women near Rm 403 - Faucet C2	Faucet	Initial	0.006	8/9/2021	N/A
91	S25474.91	6/17/2021	4th FL - Women near Rm 403 - Faucet C3	Faucet	Initial	0.003	8/9/2021	N/A
92	S25474.92	6/17/2021	4th FL - Men's near Rm 403 - Faucet A1	Faucet	Initial	0.003	8/9/2021	N/A
93	S25474.93	6/17/2021	4th FL - Men's near Rm 403 - Faucet A2	Faucet	Initial	0.003	8/9/2021	N/A
94	S25474.94	6/17/2021	4th FL - Men's near Rm 403 - Faucet A3	Faucet	Initial	0.002	8/9/2021	N/A
95	S25474.95	6/17/2021	4th FL - Fountain near Rm 419	Fountain	Initial	<0.001	8/9/2021	N/A