

SCHOOL NAME: School #355/363/366 at Building #200 2885 Main Street**44 Outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
1	S25024.01	6/4/2021	Rm 008	Faucet	Initial	0.007	7/28/2021	N/A
2	S25024.02	6/4/2021	Rm 002 Parent - Faucet B1	Faucet	Initial	0.018	7/28/2021	SIGNAGE
3	S25024.03	6/4/2021	Rm 002 Parent - Faucet B2	Faucet	Initial	0.014	7/28/2021	N/A
4	S25024.04	6/4/2021	Rm 002 Parent - Faucet B3	Faucet	Initial	0.013	7/28/2021	N/A
5	S25024.05	6/4/2021	Rm 002 Parent - Faucet B4	Faucet	Initial	0.009	7/28/2021	N/A
6	S25024.06	6/4/2021	Rm 002 Parent - Faucet B5	Faucet	Initial	0.004	7/28/2021	N/A
7	S25024.07	6/4/2021	Rm 002 Parent - Faucet B6	Faucet	Initial	0.005	7/28/2021	N/A
8	S25024.08	6/4/2021	Rm 150 Bath - Faucet	Faucet	Initial	<0.001	7/28/2021	N/A
9	S25024.09	6/4/2021	Rm 125 Bath - Faucet	Faucet	Initial	0.004	7/28/2021	N/A
10	S25024.10	6/4/2021	Rm 109 Bath - Faucet	Faucet	Initial	0.002	7/28/2021	N/A
11	S25024.11	6/4/2021	Rm 199 - Faucet	Faucet	Initial	0.001	7/28/2021	N/A
12	S25024.12	6/4/2021	Faculty near Rm 186 - Faucet	Faucet	Initial	<0.001	7/28/2021	N/A
13	S25024.13	6/4/2021	Rm 170 Bath - Faucet	Faucet	Initial	0.004	7/28/2021	N/A
14	S25024.14	6/4/2021	Rm 268 - Faucet	Faucet	Initial	0.010	7/28/2021	N/A
15	S25024.15	6/4/2021	Rm 250 Faculty Bath - Faucet	Faucet	Initial	<0.001	7/28/2021	N/A
16	S25024.16	6/4/2021	Rm 251 - Faucet	Faucet	Initial	0.002	7/28/2021	N/A
17	S25024.17	6/4/2021	Fountain near 242	Faucet	Initial	<0.001	7/28/2021	N/A
18	S25024.18	6/4/2021	Rm 211A - Faucet	Faucet	Initial	0.003	7/28/2021	N/A
19	S25024.19	6/4/2021	Rm 203 - Faucet	Faucet	Initial	0.001	7/28/2021	N/A
20	S25024.20	6/4/2021	Faculty Bath near Rm 370 - Faucet	Faucet	Initial	<0.001	7/28/2021	N/A
21	S25024.21	6/4/2021	Fountain by 394	Faucet	Initial	<0.001	7/28/2021	N/A
22	S25024.22	6/4/2021	Rm 399 - Faucet Left Bathroom	Faucet	Initial	0.001	7/28/2021	N/A
23	S25024.23	6/4/2021	Rm 399 - Faucet Right Bathroom	Faucet	Initial	0.004	7/28/2021	N/A
24	S25024.24	6/4/2021	Rm 399 - Exam Room N	Faucet	Initial	0.007	7/28/2021	N/A

SCHOOL NAME: School #355/363/366 at Building #200 2885 Main Street
44 Outlets

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
25	S25024.25	6/4/2021	Rm 399	Faucet	Initial	<0.001	7/28/2021	N/A
26	S25024.26	6/4/2021	Rm 399 - Exam Room M	Faucet	Initial	0.004	7/28/2021	N/A
27	S25024.27	6/4/2021	Rm 399 - Exam Room L	Faucet	Initial	0.012	7/28/2021	N/A
28	S25024.28	6/4/2021	Rm 399 Exam Room E	Faucet	Initial	0.003	7/28/2021	N/A
29	S25024.29	6/4/2021	Rm 399 - Exam Room F	Faucet	Initial	<0.001	7/28/2021	N/A
30	S25024.30	6/4/2021	Rm 350 Faculty Bath - Faucet	Faucet	Initial	<0.001	7/28/2021	N/A
31	S25024.31	6/4/2021	Cafeteria Boys Bath - Faucet	Faucet	Initial	<0.001	7/28/2021	N/A
32	S25024.32	6/4/2021	Cafeteria Boys Bath - Faucet	Faucet	Initial	<0.001	7/28/2021	N/A
33	S25024.33	6/4/2021	Kitchen - Faucet B1	Faucet	Initial	0.004	7/28/2021	N/A
34	S25024.34	6/4/2021	Kitchen - Faucet B2	Faucet	Initial	0.002	7/28/2021	N/A
35	S25024.35	6/4/2021	Kitchen Faucet Center	Faucet	Initial	0.040	7/28/2021	work order to replace
36	S25024.36	6/4/2021	Kitchen Faucet Hand Wash	Faucet	Initial	0.004	7/28/2021	N/A
37	S25024.37	6/4/2021	Kitchen Faucet D1	Faucet	Initial	0.005	7/28/2021	N/A
38	S25024.38	6/4/2021	Kitchen Faucet D2	Faucet	Initial	0.008	7/28/2021	N/A
39	S25024.39	6/4/2021	Faculty Bath near Rm 482 Faucet	Faucet	Initial	<0.001	7/28/2021	N/A
40	S25024.40	6/4/2021	Rm 404 - Faucet	Faucet	Initial	0.002	7/28/2021	N/A
41	S25024.41	6/4/2021	Fountain by 422	Fountain	Initial	0.003	7/28/2021	N/A
42	S25024.42	6/4/2021	18	Faucet	Initial	0.007	7/28/2021	N/A
43	S25024.43	6/4/2021	Boiler House - Faucet	Faucet	Initial	0.003	7/28/2021	N/A
44	S25024.4	6/4/2021	Boiler House - Bathroom Faucet	Faucet	Initial	0.004	7/28/2021	N/A